

Operation Manual

PRODUCT NAME

Digital Pressure Switch

MODEL / Series / Product Number

ZSE20C(F) ISE20C(H)

SMC Corporation

Table of Contents

Safety Instructions	3
Model Indication and How to Order	10
Summary of Product parts	12
Definition and terminology	13
Mounting and Installation	17
Installation	17
Piping	20
Wiring	22
Outline of Settings [Measurement mode]	25
Pressure Setting	26
3 Step Setting Mode	27
Simple Setting Mode	29
Function Selection Mode	31
Function selection mode	31
Default setting	31
F 0 Units selection function	33
F 1 Setting of OUT1	34
F 2 Setting of OUT2	37
F 3 Digital filter setting	39
F 4 Auto-preset function	40
F 5 FUNC terminal setting	42
F 6 Fine adjustment of display value	44
F10 Sub display setting	45
F11 Display resolution setting	51
F80 Power saving mode	52
F81 Security code	53
F82 Input of line name	55
F90 Setting of all functions	56
F96 Input signal check	58
F97 Selection of copy function	59
F98 Output check	61
F99 Reset to default settings	63
Other Settings	64
Maintenance	68
Forgotten the security code	68
Troubleshooting	69
Specification	78
Specifications	78
Dimensions	81





Safety Instructions

These safety instructions are intended to prevent hazardous situations and/or equipment damage. These instructions indicate the level of potential hazard with the labels of "Caution," "Warning" or "Danger." They are all important notes for safety and must be followed in addition to International Standards (ISO/IEC)^{*1}, and other safety regulations.

*1) ISO 4414: Pneumatic fluid power - General rules and safety requirements for systems and their components ISO 4413: Hydraulic fluid power - General rules and safety requirements for systems and their components IEC 60204-1: Safety of machinery - Electrical equipment of machines - Part 1: General requirements ISO 10218-1: Robots and robotic devices - Safety requirements for industrial robots - Part 1:Robots



Danger indicates a hazard with a high level of risk which, if not avoided, will result in death or serious injury.

Warning indicates a hazard with a medium level of risk which, if not avoided, could result in death or serious injury.



Caution indicates a hazard with a low level of risk which, if not avoided, could result in minor or moderate injury.

1. The compatibility of the product is the responsibility of the person who designs the equipment or decides its specifications.

Since the product specified here is used under various operating conditions, its compatibility with specific equipment must be decided by the person who designs the equipment or decides its specifications based on necessary analysis and test results. The expected performance and safety assurance of the equipment will be the responsibility of the person who has determined its compatibility with the product. This person should also continuously review all specifications of the product referring to its latest catalog information, with a view to giving due consideration to any possibility of equipment failure when configuring the equipment.

- 2. Only personnel with appropriate training should operate machinery and equipment. The product specified here may become unsafe if handled incorrectly. The assembly, operation and maintenance of machines or equipment including our products must be performed by an operator who is appropriately trained and experienced.
- 3. Do not service or attempt to remove product and machinery/equipment until safety is confirmed.
 - 1. The inspection and maintenance of machinery/equipment should only be performed after measures to prevent falling or runaway of the driven objects have been confirmed.
 - When the product is to be removed, confirm that the safety measures as mentioned above are implemented and the power from any appropriate source is cut, and read and understand the specific product precautions of all relevant products carefully.
 - 3. Before machinery/equipment is restarted, take measures to prevent unexpected operation and malfunction.
- 4. Our products cannot be used beyond their specifications. Our products are not developed, designed, and manufactured to be used under the following conditions or environments. Use under such conditions or environments is not covered.
 - 1. Conditions and environments outside of the given specifications, or use outdoors or in a place exposed to direct sunlight.
 - 2. Use for nuclear power, railways, aviation, space equipment, ships, vehicles, military application, equipment affecting human life, body, and property, fuel equipment, entertainment equipment, emergency shut-off circuits, press clutches, brake circuits, safety equipment, etc., and use for applications that do not conform to standard specifications such as catalogs and operation manuals.
 - 3. Use for interlock circuits, except for use with double interlock such as installing a mechanical protection function in case of failure. Please periodically inspect the product to confirm that the product is operating properly.





Safety Instructions

We develop, design, and manufacture our products to be used for automatic control equipment, and provide them for peaceful use in manufacturing industries.

Use in non-manufacturing industries is not covered.

Products we manufacture and sell cannot be used for the purpose of transactions or certification specified in the Measurement Act.

The new Measurement Act prohibits use of any unit other than SI units in Japan.

Limited warranty and Disclaimer/Compliance Requirements

The product used is subject to the following "Limited warranty and Disclaimer" and "Compliance Requirements".

Read and accept them before using the product.

Limited warranty and Disclaimer

- 1. The warranty period of the product is 1 year in service or 1.5 years after the product is delivered, whichever is first.*2)
 - Also, the product may have specified durability, running distance or replacement parts. Please consult your nearest sales branch.
- 2. For any failure or damage reported within the warranty period which is clearly our responsibility, a replacement product or necessary parts will be provided.
 - This limited warranty applies only to our product independently, and not to any other damage incurred due to the failure of the product.
- Prior to using SMC products, please read and understand the warranty terms and disclaimers noted in the specified catalog for the particular products.

*2) Vacuum pads are excluded from this 1 year warranty.

A vacuum pad is a consumable part, so it is warranted for a year after it is delivered.

Also, even within the warranty period, the wear of a product due to the use of the vacuum pad or failure due to the deterioration of rubber material are not covered by the limited warranty

Compliance Requirements

- 1. The use of SMC products with production equipment for the manufacture of weapons of mass destruction (WMD) or any other weapon is strictly prohibited.
- 2. The exports of SMC products or technology from one country to another are governed by the relevant security laws and regulations of the countries involved in the transaction. Prior to the shipment of a SMC product to another country, assure that all local rules governing that export are known and followed.



Operator

- ♦ This operation manual is intended for those who have knowledge of machinery using pneumatic equipment, and have sufficient knowledge of assembly, operation and maintenance of such equipment. Only those persons are allowed to perform assembly, operation and maintenance.
- ♦ Read and understand this operation manual carefully before assembling, operating or providing maintenance to the product.

■Safety Instructions

Marning

■Do not disassemble, modify (including changing the printed circuit board) or repair. An injury or failure can result.

■Do not operate the product outside of the specifications.

Do not use for flammable or harmful fluids.

Fire, malfunction, or damage to the product can result.

Verify the specifications before use.

■Do not operate in an atmosphere containing flammable or explosive gases.

Fire or an explosion can result.

This product is not designed to be explosion proof.

■Do not use the product in a place where static electricity is a problem.

Otherwise it can cause failure or malfunction of the system.

■If using the product in an interlocking circuit:

- •Provide a double interlocking system, for example a mechanical system
- •Check the product regularly for proper operation

Otherwise malfunction can result, causing an accident.

- ■The following instructions must be followed during maintenance:
- •Turn off the power supply
- •Stop the air supply, exhaust the residual pressure and verify that the air is released before performing maintenance

Otherwise an injury can result.



ACaution

■Do not touch the terminals and connectors while the power is on.

Otherwise electric shock, malfunction or damage to the product can result.

■After maintenance is complete, perform appropriate functional inspections and leak tests.

Stop operation if the equipment does not function properly or there is a leakage of fluid.

When leakage occurs from parts other than the piping, the product might be faulty.

Disconnect the power supply and stop the fluid supply.


Do not apply fluid under leaking conditions.

Safety cannot be assured in the case of unexpected malfunction.


NOTE

- Follow the instructions given below when designing, selecting and handling the product.
- The instructions on design and selection (installation, wiring, environment, adjustment, operation, maintenance, etc.) described below must also be followed.
 - *Product specifications
 - •The direct current power supply to be used should be UL approved as follows:

 Circuit (of Class 2) which is of maximum 30 Vrms (42.4 V peak), with UL1310 Class 2 power supply unit or UL1585 Class 2 transformer.
 - •The product is a UL approved product only if it has a Rus mark on the body.
 - •Use the specified voltage.
 - Otherwise failure or malfunction can result.
 - Do not exceed the specified maximum allowable load.
 - Otherwise it can cause damage or shorten the lifetime of the Pressure switch.
 - •Design the product to prevent reverse current when the circuit is opened or the product is forced to operate for operational check.
 - Reverse current can cause malfunction or damage to the product.
 - •Input data to the Pressure switch is not deleted, even if the power supply is cut off. (Writing time: 10,000 times, Data duration: 20 years after power off)
 - •A pressure sensor of stainless steel diaphragm is used for this switch. The pressure sensor of this switch can be damaged by the rush inertia of water when the drain contained in water and air collide with the pressure sensor when vacuum is broken after vacuum adsorption is confirmed, and it may cause Inlet malfunction with the pressure indication. If there is a possibility of water or drainage getting in, narrow the diameter of the piping to the pressure switch, or make an orifice in the middle of the piping shown in the Fig. right. Extra attention is needed When the rear piping type model is used.



Pipe an orifice vertically (throttle) and so that no water (solution) remains between the switch and orifice.





- •Some fluids may generate static electricity when resin piping is used for piping. Take measures against static electricity with equipment when this switch is used in connection with resin piping. Also, the ground should be separate from that of the units that generate strong electromagnetic noise or high frequency, otherwise, the switch can be damaged by static electricity.
- •Applicable fluid is a fluid that does not corrode SUS630 and SUS304.

Do not use a fluid containing chemicals, synthetic oils including organic solvent, salt and corrosive gases.

Otherwise, damage to the product and malfunction can result.

Check the details of the specifications before using.

•Use the specified operating pressure.

Otherwise it can cause damage to the pressure switch or inability to measure correctly.

•Reserve a space for maintenance.

Allow sufficient space for maintenance when designing the system.

Product handling

- *Installation
- •Tighten to the specified tightening torque.

If the tightening torque is exceeded the mounting screws and brackets may be broken.

If the tightening torque is insufficient, the product can be displaced and loosen the mounting screws.

•Do not apply excessive stress to the product when it is mounted with a panel mount.

Otherwise damage to the product and disconnection from the panel mount can result.

- •Be sure to ground terminal FG when using a commercially available switch-mode power supply.
- •Do not drop, hit or apply shock to the Pressure switch.

Otherwise damage to the internal parts can result, causing malfunction.

- •Do not pull the lead wire forcefully, not lift the product by pulling the lead wire. (Tensile force 35 N or less) Hold the body when handling to avoid the damage of the Pressure switch which lead to cause the failure and malfunction.
- •For piping of the Pressure switch, hold the piping with a spanner on the metal part of the piping (Piping attachment).

Holding other part with spanner leads to damage the Pressure switch.

- •Eliminate any dust left in the piping by air blow before connecting the piping to the product. Otherwise it can cause damage or malfunction.
- •Do not insert metal wires or other foreign matter into the pressure measurement port. It can damage the pressure sensor causing failure or malfunction.
- •Never mount a Pressure switch in a location that will be used as a foothold.

The product may be damaged if excessive force is applied by stepping or climbing onto it.

- •If the entering of foreign material to the fluid is possible, install and pipe the filter or the mist separator to the inlet to avoid failure and malfunction.
- •Helium leakage test is conducted on the welding parts. Use a ferrule by Swagelok Company (Swagelok® fittings) as the TSJ fittings and packing, ground, etc. by Swagelok Company (VCR® fittings) as the URJ fittings. If a ferrule, packing or ground by other manufacturers are to be used, conduct helium leakage test before using those products.
- *: Swagelok® and VCR® are trademarks of Swagelok Company.

*Wiring

•Do not pull the lead wires.

In particular, never lift a Pressure switch equipped with fitting and piping by holding the lead wires.

Otherwise damage to the internal parts can result, causing malfunction or to be off the connector.

Avoid repeatedly bending or stretching the lead wire, or placing heavy load on them.

Repetitive bending stress or tensile stress can cause the sheath of the wire to peel off, or breakage of the wire. If the lead wire can move, fix it near the body of the product.

The recommended bend radius of the lead wire is 6 times the outside diameter of the sheath, or 33 times the outside diameter of the insulation material, whichever is larger.

Replace the damaged lead wire with a new one.

•Wire correctly.

Incorrect wiring can break the Pressure switch.



- •Do not perform wiring while the power is on.
- Otherwise damage to the internal parts can result, causing malfunction.
- •Do not route wires and cables together with power or high voltage cables.
- Otherwise the product can malfunction due to interference of noise and surge voltage from power and high voltage cables to the signal line. Route the wires (piping) of the product separately from power or high voltage cables.
- Confirm proper insulation of wiring.
- Poor insulation (interference from another circuit, poor insulation between terminals, etc.) can lead to excess voltage or current being applied to the product, causing damage.
- •Design the system to prevent reverse current when the product is forced to operate for operational check. Depending on the circuit used, insulation may not be maintained when operation is forced, allowing reverse current to flow, which can cause malfunction and damage the product.
- •Keep wiring as short as possible to prevent interference from electromagnetic noise and surge voltage. Do not use a cable longer than 30 m.
- Wire the DC(-) line(blue) as close as possible to the power supply.
- •When analog output is used, install a noise filter (line noise filter, ferrite element, etc.) between the switch-mode power supply and this product.

*Environment

- •Do not use the product in area that is exposed to corrosive gases, chemicals, sea water, water or steam. Otherwise failure or malfunction can result.
- •Do not use in a place where the product could be splashed by oil or chemicals.

 If the product is to be used in an environment containing oils or chemicals such as coolant or cleaning solvent, even for a short time, it may be adversely affected (damage, malfunction, or hardening of the lead wires).
- Do not use in an area where surges are generated.
- If there is equipment which generates a large amount of surge (solenoid type lifter, high frequency induction furnace, motor, etc.) close to the Pressure switch, this may cause deterioration or breakage of the internal circuit of the Pressure switch. Avoid sources of surge generation and crossed lines.
- •Do not use a load which generates surge voltage.
- When a surge-generating load such as a relay or solenoid is driven directly, use a load with a built-in surge suppressor.
- •The product is CE/UKCA marked, but not immune to lightning strikes. Take measures against lightning strikes in the system.
- •Mount the product in a place that is not exposed to vibration or impact.
- Otherwise failure or malfunction can result.
- •Prevent foreign matter such as remnant of wires from entering the Pressure switch.

 Take proper measures for the remnant not to enter the Pressure switch in order to prevent failure or malfunction.
- •Do not use the product in an environment that is exposed to temperature cycle.
- Heat cycles other than ordinary changes in temperature can adversely affect the inside of the product.
- •Do not expose the product to direct sunlight.
- If using in a location directly exposed to sunlight, shade the product from the sunlight.
- Otherwise failure or malfunction can result.
- •Keep within the specified fluid and ambient temperatures range.
- The fluid and ambient temperatures should be -5 to 50 °C. Operation under low temperature (5 °C or less) leads to cause damage or operation failure due to frozen moist in the fluid or air.
- Protection against freezing is necessary. Air dryer is recommended for elimination of drain and water.
- Avoid sudden temperature change even within specified temperature.
- •Do not operate close to a heat source, or in a location exposed to radiant heat. Otherwise malfunction can result.
- •Use operating fluid which does not corrode the part in contact with fluid which is made of SUS630 (for sensing part) or SUS304 (for fitting part).
- (Compatibility between fluid and material can be checked by contact to fluid supplier.)
- •When resin piping is used, depending on the fluid, static electricity may occur. When connecting the switch and sensor, please take adequate anti-static electricity measures on the equipment side, and do not use with a grounding that is shared with equipment that generates strong electromagnetic noise or high-frequency waves.

This can result in a switch or sensor being damaged by static electricity.



- *Adjustment and Operation
- •Turn the power on after connecting a load.
- Otherwise it can cause excess current causing instantaneous breakage of the Pressure switch.
- •Do not short-circuit the load.
- Although error is displayed when the Pressure switch load is short circuit, generated excess current lead to cause the damage of the Pressure switch.
- •Do not press the setting buttons with a sharp pointed object. It may damage the setting buttons.
- •If using the product to detect very small pressure rates, warm up the product for 10 to 15 minutes first. There will be a drift on the display of approximate ±1% immediately after the power supply is turned on, within 10 minutes.
- •Perform settings suitable for the operating conditions.

Incorrect setting can cause operation failure.

For details of each setting, refer to page 25 to 67 of this manual.

•Do not touch the LCD during operation.

The display can vary due to static electricity.

*Maintenance

•Turn off the power supply, stop the supplied air, exhaust the residual pressure and verify the release of air before performing maintenance.

There is a risk of unexpected malfunction.

•Perform regular maintenance and inspections.

There is a risk of unexpected malfunction.

Perform drainage regularly.

If condensate enters the secondary side, it can cause operating failure of pneumatic equipment.

•Do not use solvents such as benzene, thinner etc. to clean the Pressure switch.

They could damage the surface of the body and erase the markings on the body.

Use a soft cloth to remove stains. For heavy stains, use a cloth soaked with diluted neutral detergent and fully squeezed, then wipe up the stains again with a dry cloth.

Model Indication and How to Order

Pressure range

	Symbol	Content
Positive	ISE20C	-0.100 to
pressure	ISLZUC	1.000 MPa
Vacuum	ZSE20C	0.0 to
pressure	ZSEZUC	-101.0 kPa
Compound	ZSE20CF	-100.0 to
pressure	2362007	100.0 kPa
Positive	ISE20CH	-0.100 to
pressure	ISEZUCH	2.000 MPa

Output specification -

Symbol	Content
Х	NPN open collector 2 outputs
_ ^	(with copy function)
_	PNP open collector 2 outputs
ı	(with copy function)
R	NPN open collector 2 outputs
	+ Analog voltage *1
_	PNP open collector 2 outputs
ı	+ Analog voltage *1
S	NPN open collector 2 outputs
٥	+ Analog current *1
\/	PNP open collector 2 outputs
_ v	+ Analog current *1

^{*1:} Possible to switch to auto shift and copy.

Unit specification –

Symbol	Content	
Nil	With units selection function	
М	Fixed SI unit *3	
Р	With units selection function (psi initial value) *2	

^{*2:} The new Measurement Law prohibits the use of pressure switch with the units selection function in Japan. A unit label is attached.

Piping specification -

Symbol	Content	Symbol	Content
02	R1/4	C01	Rc1/8
N02	NPT1/4	A2	URJ1/4 (Face seal fittng)
F02	G1/4	B2	TSJ1/4 (Compression fittng)

- Option 3

Symbol	Content	
Nil	With operation manual	
Y	None	
К	With operation manual + calibration certificate	
Т	With calibration certificate	

Option 2 *4

Symbol	Content	
Nil	No option	
A1	Bracket A (rear piping)	
А3	Bracket C (bottom piping)	
В	Panel mount adapter (rear piping)	
E	Panel mount adapter (bottom piping)	
D	Panel mount adapter + Front protective cover (rear piping)	
F	Panel mount adapter + Front protective cover (bottom piping)	

*4: Selection differs depending on the piping direction. Refer to Option 2 correspondence table below.

Option 1

	- 1				
S	ymbol	Content			
	Nil	Without lead wire			
	W	Lead wire with connector (lead wire length 2 m, waterproof)		ZS-46-5F	

Piping direction

Symbol	Content
Nil	Rear piping
L	Bottom piping

Option 2 correspondence table

Option2			Piping direction	
Items	Symbol	Part No.	Nil (Rear piping)	L (Bottom piping)
Bracket A	A1	ZS-46-A1	0	×
Bracket C	A3	ZS-46-E	×	0
Danel mount adentar	В	ZS-46-B	0	×
Panel mount adapter	Е	ZS-35-B	×	0
Panel mount adapter L Front protective cover	D	ZS-46-D	0	×
Panel mount adapter + Front protective cover	F	ZS-35-E	×	0

^{*3:} Fixed unit kPa, MPa


oAccessories/Part numbers

If an option is required independently, order with the following part numbers.

Items	Part No.		Remarks	
Bracket A	ZS-46-A1	Rear piping	Self tapping screws: Nominal size 3 x 8L (2 pcs.)	
Bracket C	ZS-46-E	Bottom piping	Self tapping screws: Nominal size 3 x 10L (2 pcs.)	
Donal may not adopted	ZS-46-B		Rear piping	
Panel mount adapter	ZS-35-B	Bottom piping		
Panel mount adapter +	ZS-46-D		Rear piping	
Front protective cover	ZS-35-E		Bottom piping	
Lead wire with connector	ZS-46-5F	5 cores, 2 m, waterproof		
- · · · ·	ZS-27-01		Rear piping	
Front protective cover	ZS-35-01		Bottom piping	

Summary of Product parts

ONames of individual parts



Operation light: Displays the switch operating condition.

LCD display: Displays the current status of pressure, setting mode, selected display units and error code.

4 types of display can be selected for the main display: Single color of constant red or green; or switching from red to green or green to red corresponding to the output.

The indication for the sub display is orange.

button: Increases mode and ON/OFF set values.

button: Decreases mode and ON/OFF set values.

S button: Press this button to change mode and to confirm settings.

Unit display: Indicates the units currently selected. (Only for display units of kPa and MPa.)

■Definition and terminology

	Term	Definition
Α	Analog current output	Refer to "Analog output (function)".
	Analog output function	Function to output the voltage or current in proportion to the pressure.
	Analog voltage output	Refer to "Analog output (function)".
	Auto-preset	Performs pressure setting automatically by detecting the increase and decrease in pressure. For example, if this function is used for a suction test, the pressure setting will be completed by performing suction and release of the workpiece.
	Auto-shift	A function to correct the set value of the switch output in accordance with the applied pressure in case the switch operation is unstable due to pulsation of applied pressure. This function is used in applications such as vacuum adsorption. The pressure when a signal is externally input is set as a reference value with which the pressure that turns the switch on or off can be shifted.
В	Bottom value display (mode)	Shows the minimum pressure from when the power was supplied to the current time.
С	Chattering	The problem of the switch output turning ON and OFF repeatedly around the set value at high frequency due to the effect of pulsation.
	Chattering prevention function	A function to delay the response time of switch output in order to prevent chattering.
	Copy destination Pressure switch	A Pressure switch whose settings are copied to when using the copy function.
	Copy function	A function to copy a pressure setting value and function setting (Excludes finely adjusted displayed values and line names).
	Copy source Pressure switch	A Pressure switch whose settings are copied when using the copy function.

	Term	Definition
D	Delay time	The setting time from when the pressure applied to the pressure switch reaches the set value, to when the ON-OFF output actually begins working. Delay time setting can prevent the output from chattering.
	digit (Min. setting unit)	Shows how precisely the pressure can be displayed or set by the digital pressure switch. When 1 digit = 1 kPa, the pressure is displayed in increments of 1 kPa, e.g., 1, 2, 3,, 99, 100.
	Digital filter	Function to add digital filtering to the fluctuation of pressure value. Smooth the fluctuation of displayed value for sharp start up or fall of the pressure. When the function is valid, digital filtering is reflected to the ON/OFF of the switch output. Output chattering or flicker in the measurement mode display can be reduced by setting the digital filter. The response time indicates when the set value is 90% in relation to the step input.
	Display accuracy	Shows The maximum deviation between the displayed pressure value and the true pressure.
	Display color	Indicates the color of the number of digital display. Always green, always red, green (switch OFF) \rightarrow red (switch ON), red (switch OFF) \rightarrow green (switch ON) are available.
	Display resolving power	Indicate in how many the rated pressure range can be divided to display. (Example: When the value can be displayed down to 0.001 MPa for the product for 0 to 1 Mpa, the resolution is 1/1000)
	Display value fine adjustment (function)	Displayed pressure value can be adjusted within the range of $\pm 5\%$ R.D. ($\pm 5\%$ of displayed value). It is used if the true pressure value is known, or to eliminate differences between the displayed values of different instruments that are measuring the same pressure.
E	Error displayed	The code number displayed, identifying the error detected by the self-diagnosis function of the pressure switch. Refer to "Error indication function" on page 77 for details of the errors.
	Error output	Switches the switch output to ON/OFF when an error is displayed. Refer to "List of output modes" on page 36 for operating conditions. Refer to "Error indication function" on page 77 for details of the errors.
F	F.S. (full span/full scale)	Abbreviation of full span and full scale; difference between the minimum and maximum rated pressure values. means the maximum fluctuation range of the pressure switch rated value. For example, when the rated pressure range is -0.100 to 1.000 [MPa]: F.S. = 1.000 - (-0.100) = 1.100 [MPa] (Reference: 1%F.S. = 1.100 x 0.01 = 0.011 [MPa])
	Fine adjustment mode	Refer to "Display value fine adjustment (function)".
	Fluid contact part (or wetted part)	Part of the pressure switch which contacts detected fluid. Pressure sensor, seal and fitting are included.
	Function selection mode	A mode in which setting of functions is performed. It is a separate menu from the pressure setting. If any function settings need to be changed from the factory default, each setting can be selected with "F*". The setting items are: operation mode, output type, display color, digital filter, use of auto preset, analog/auto shift/copy, display value fine adjustment, sub screen display, display resolution, use of power saving mode and use of security code.

	Term	Definition	
Н	Hysteresis	Difference between the points at which the pressure switch is turned ON and OFF.	
	Hysteresis mode	Refer to the "List of output modes" on page 36.	
I	Insulation resistance	Insulation resistance of the product. The resistance between the electrical circuit and the case.	
K	Key-lock function	Function that prevents changes to the settings of the Pressure switch (disables button operation).	
L	Load impedance	Refer to "Max. load impedance".	
Manual pressure setup without using auto preset		Manual pressure setup without using auto preset. This term is used to distinguish between manual and auto preset pressure setup.	
	Maximum applied voltage	The maximum voltage that can be connected to the output of an NPN device.	
	Maximum load current	The maximum current that can flow to the output (output line) of the switch output.	
	Max. (Min.) load impedance	The maximum (minimum) load (resistance value and impedance) which can be connected to the output (output wire) of the analog current output.	
	Measurement mode	Operating condition in which pressure is being detected and displayed, and the switch function is working.	
	Min. setting unit	Refer to "digit".	
N	Normal output	One of the switch output types. In hysteresis mode the switch output is turned ON when pressure equal to or greater than the switch output set value is detected. In window comparator mode, the switch output is turned ON when pressure between the switch output set values (P1L to P1H) is detected. (Refer to the "List of output modes" on page 36.)	
0	Operation light	A light that turns on when the switch output is ON.	
	Operation mode	Hysteresis mode, window comparator mode, Error output or Output off can be selected.	
Orifice This indicates a re		This indicates a restrictor.	
	Output impedance	The resistance value of a component between the voltage output element and the analog voltage output. It is indicated as a resistance value which is converted in accordance with the condition in which resistance is directly connected to the voltage output element. There may be an error in the output voltage depending on this output impedance and the input impedance of customers' equipment. (example: If the Pressure switch with output impedance of $1k\Omega$ is connected to the A/D converter to detect the analog output of 5V, the detected voltage by the A/D converter becomes $5(V) \times 1(M\Omega)/(1(k\Omega) + 1(M\Omega))$ $\rightleftharpoons 4.995(V)$, and there is an error of approximate 0.005 V).	
	Output style	The operation principle of the switch output. Normal output and reverse output can be selected. Please refer to the" List of output modes" on page 36 operating conditions.	
Р	Peak value display (mode)	Shows the maximum pressure from when the power was supplied to the current time.	
	Port size	The diameter of the connecting part of the switch for connecting with the object to be measured.	
	Power saving mode	Operating mode in which the digital display turns off and power consumption is reduced.	
	Pressure-sensing part	The pressure-detecting part of a pressure-detecting element.	
	Pressure setting	The set pressure value that determines the point at which the pressure switch turns ON and OFF.	
	Proof pressure	Pressure limit that if exceeded will result in mechanical and/or electrical damage to the product.	

	Term	Definition
R	R.D.	Current read value For example, when the display value is $1.000[MPa]$, $\pm 5\%R.D.$ is $\pm 5\%$ of $1.000[MPa]$, which becomes $\pm 0.05[MPa]$. When the display value is $0.800[MPa]$, $\pm 5\%R.D.$ is $\pm 5\%$ of $0.800[MPa]$, which becomes $\pm 0.04[MPa]$.
Rated pressure range specification Values outs		The pressure range within which the product will meet all published specifications. Values outside of this range can be set as long as they are within the set pressure range, but the specifications cannot be guaranteed.
	Repeatability	Variation in repeated measurement of pressure display or ON-OFF output point when the pressure changes at 25 centigrade.
	Residual voltage	The difference between the ideal ON voltage and the actual voltage when the switch output is on. Varies with load current. Ideally should be 0 V.
	Resolution	Refer to "Display resolution".
	Reversed output	One of the switch output types. In hysteresis mode the switch output is turned ON when pressure less than or equal to the switch output set value is detected. In window comparator mode, the switch output is turned ON when pressure is outside the switch output set values (n1L to n1H) is detected. (Refer to the "List of output modes" on page 36.)
	Ripple	A type of chattering.
S Set pressure range The pressure range that can be set for switch output.		The pressure range that can be set for switch output.
		A stainless steel pressure-detecting part of the pressure-detecting element. It is suitable for measuring fluid such as water.
	Switch output	Sometimes referred to as "ON-OFF output".
Т	TSJ fitting	TSJ is an abbreviation for Tube Swage Joint. As a fitting, a Swagelock fitting is recommended.
displayed. The display units can only be changed in		·
	URJ fitting	URS is an abbreviation for Union Ring Joint. As a fitting, the Swagelock VCR fitting is recommended.
W	Window comparator mode	An operating mode in which the switch output is turned on and off depending on whether the flow is inside or outside the range of two set values. (Refer to the "List of output modes" on page 36.)
	Withstand voltage	A measure of the product's resistance to a voltage applied between the electrical circuit and case. Durability in withstanding voltage. The product may be damaged if a voltage over this value is applied. (The withstand voltage is not the supply voltage used to power the product.)
Z	Zero-clear function	This function to adjust the displayed pressure to zero.

Mounting and Installation


■Installation

Mounting

- Mount the optional bracket and panel mount adapter to the pressure switch.
- •When the pressure switch is to be mounted in a place where water and dust splashes occur, insert a tube into the atmospheric vent port of the pressure switch. (Refer to "Tube attachment" on page 21.)


Mounting with bracket

- •Mount the bracket to the body with mounting screws (Self tapping screws), then set the body to the specified position.
 - *: Tighten the bracket mounting screws to a torque of 0.5±0.05 N·m. Self tapping screws are used, and should not be re-used several times.
 - <Rear piping>
 - •Bracket A (Part No.: ZS-46-A1)



<Bottom piping>

•Bracket C (Part No.: ZS-46-E)



Mounting with panel mount adapter

- <Rear piping>
- •Mount part (a) to the front of the body and fix it. Then insert the body with (a) into the panel until (a) comes into contact with the panel front surface. Next, mount part (b) to the body from the rear and insert it until (b) comes into contact with the panel for fixing.
 - •Panel mount adapter (Part No.: ZS-46-B)
 Panel mount adapter + Front protective cover (Part No.: ZS-46-D)

 Front protective cover (Opetion)

 Panel mount adapter


 Panel mount adapter

st: The panel mount adapter can be rotated through 90 degrees for mounting.


How to remove the panel mount adapter

•When removing the digital pressure switch with panel mount adapter from the installation, pull it forward while expanding the hooks on each side as shown below.

If the panel mount adapter is pulled forward with the hook caught, the product and the adapter may be damaged.




- <Bottom piping>
- Holding a panel between panel mount adapter A and B.
 Then insert pressure switch and mounting bracket into the panel in that order.
- •Panel mount adapter (Part No.: ZS-35-B)
 Panel mount adapter + Front protective cover (Part No.: ZS-35-E)




Front protective cover (Option)

■Piping

- oConnection using screw type fitting
 - •Connect suitable piping to the port.
 - •To connect the hexagon socket head plug or fitting to the pressure port, hold the hexagon part of the pressure port with a suitable spanner. Apply a tightening torque of 8 to 12 N•m.




When tightening, do not hold the pressure switch body with a spanner.



oTube attachment

- •When the pressure switch is used in a place where water and dust splashes may occur, insert a tube in the atmospheric vent port, and position the other end of the tube at safe position to protect the vent port from water and dust (see the figure bottom).
 - *: The tube should be inserted to the end of the atmospheric vent port.
 - *: SMC TU0425 (polyurethane, O.D ϕ 4, I.D ϕ 2.5) is a suitable tubing.



To a safe position to protect from water and dust.

■Wiring


Wiring connections

- •Connections should be made with the power supply turned off.
- •Use a separate route for the product wiring and any power or high voltage wiring. Otherwise, malfunction may result due to noise.
- •If a commercially available switching power supply is used, be sure to ground the frame ground (FG) terminal. If the switching power supply is connected for use, switching noise will be superimposed and it will not be able to meet the product specifications. In that case, insert a noise filter such as a line noise filter/ferrite between the switching power supplies or change the switching power supply to the series power supply.


o How to use connector

Connector attachment/detachment

- •When connecting the connector, insert it straight onto the pins, holding the lever and connector body, and lock the connector by pushing the lever hook into the concave groove on the housing.
- •To detach the connector, remove the hook from the groove by pressing the lever downward, and pull the connector straight out.



Connector pin numbers





oInternal circuit and wiring examples

-S/-R

(Analog output mode)

Switch output

NPN open collector output type-2 output

Max. 28 V, 80 mA

Residual voltage 1 V or less

R: Analog output 1 to 5 V

Output impedance 1 $k\Omega$


S: Analog output 4 to 20 mA

Max. load impedance

Power supply voltage 12 V: 300 Ω

Power supply voltage 24 V: 600 Ω

Min. load impedance 50 Ω




-S/-R

(Auto-shift input mode)
With auto-shift switch output
NPN open collector output type-

NPN open collector output type-2 output

Max. 28 V, 80 mA

Residual voltage 1 V or less



-X

(Copy function switch output)


-S/-R

(Copy input mode)

NPN open collector output type-2 output

Max. 28 V, 80 mA

Residual voltage 1 V or less



-V/-T

(Analog output mode)

Switch output

PNP open collector output type-2 output Max. 80 mA

Residual voltage 1 V or less

T: Analog output 1 to 5 V


Output impedance 1 kΩ

V: Analog output 4 to 20 mA

Max. load impedance Power supply voltage 12 V: 300 Ω

Power supply voltage 24 V: 600 Ω

Min. load impedance 50 Ω



-V/-T


(Auto-shift input mode)

With auto-shift switch output

PNP open collector output type-2 output

Max. 80 mA

Residual voltage 1 V or less



-Y

(Copy function switch output)


-V/-T

(Copy input mode)

PNP open collector output type-2 output

Max. 28 V, 80 mA

Residual voltage 1 V or less



Outline of Settings [Measurement mode]

Power is supplied.



The product code is displayed for approximately 3 sec. after supplying power.

*: Within approximately 0.2 second after power-on, the switch starts.




[Measurement mode]

Detects the pressure after power is supplied, and indicates the display and switch operating status. This is the basic mode; other modes should be selected for set-point changes and other function settings.

Measurement mode screen

Current pressure value (Main display)


Item (Sub display (left))



Set value or peak/bottom value (Sub display (right))

Sub display

In measurement mode, the display of the sub display can be temporarily changed by pressing the or buttons.



*: One arbitrary display mode can be added to the sub display by setting the [F10] sub display setting.

If the sub display is switched during the arbitrary display setting, the display will be returned to the arbitrary display 30 seconds later. (The default setting does not include arbitrary display.)



Press the **5** button once.



Press the **5** button between 1 and 3 sec.



Press the **S** button between 3 and 5 sec.



Set either of set value or hysteresis. (3 step setting mode) (Refer to page 27.) Select the set value, hysteresis and delay time. (Simple setting mode) (Refer to page 29.) Change the function settings.
(Function selection mode)
(Refer to page 31.)

Other Settings

- •Zero-clear function
- •Key-lock function (Refer to page 64.)

- *: The outputs will continue to operate during setting.
- *: If a button operation is not performed for 3 seconds during the setting, the display will flash.


 (This is to prevent the setting from remaining incomplete if, for instance, an operator were to leave during setting.)
- *: 3 step setting mode, simple setting mode and function selection mode settings are reflected each other.



Pressure Setting

Default settings

When the pressure exceeds the set value, the switch will be turned on. When the pressure falls below the set value by the amount of hysteresis or more, the switch will be turned off. The default setting is to turn on the pressure switch when the pressure reaches the center of the atmospheric pressure and upper limit of the rated pressure range. If this condition, shown to the below, is acceptable, then keep these settings.



•ISE20C

Item	Default setting
[P_1] Set value of OUT1	0.500 MPa
[H_1] Hysteresis of OUT1	0.050 MPa

Item	Default setting	
[P_2] Set value of OUT2	0.500 MPa	
[H_2] Hysteresis of OUT2	0.050 MPa	

ZSE20C

Item	Default setting
[P_1] Set value of OUT1	-50.5 kPa
[H_1] Hysteresis of OUT1	5.1 kPa

Item	Default setting
[P_2] Set value of OUT2	-50.5 kPa
[H_2] Hysteresis of OUT2	5.1 kPa

ZSE20CF

Item	Default setting
[P_1] Set value of OUT1	50.0 kPa
[H_1] Hysteresis of OUT1	5.0 kPa

Item	Default setting	
[P_2] Set value of OUT2	50.0 kPa	
[H_2] Hysteresis of OUT2	5.0 kPa	

•ISE20CH

Item	Default setting	
[P_1] Set value of OUT1	1.000 MPa	
[H_1] Hysteresis of OUT1	0.100 MPa	

Item	Default setting	
[P_2] Set value of OUT2	1.000 MPa	
[H_2] Hysteresis of OUT2	0.100 MPa	

Zero-clear of display

The display is reset to zero when the \(\simega \) and \(\simega \) buttons are pressed simultaneously for <u>1 second</u>. For the first operation, perform a zero-clear without pressure at measurement mode.



3 Step Setting Mode

3 step setting mode

In this mode, the set values can be input in just 3 steps.

Use this mode if the product is to be used straight away, after changing only the set values.


(The current pressure value is displayed on the main display.)

<Operation>

[3 step setting mode (hysteresis mode)]


In the 3 step setting mode, the set value (P_1 or n_1, P_2 or n_2) and hysteresis (H_1 or H_2) can be changed. Set the items on the sub display (set value or hysteresis) with or button. When changing the set value, follow the operation below. The hysteresis setting can be changed in the same way.

(1) Press the button once when the item to be changed is displayed on the sub display. The set value on the sub display (right) will start flashing.




- (2) Press the or button to change the set value.

 The set value can be increased with button and can be reduced with button.
 - Press the button once to increase the value by one digit, press and hold to continuously increase.



•Press the w button once to reduce the value by one digit, press and hold to continuously reduce.



- •When the △ and ✓ buttons are pressed and held simultaneously for <u>1 second or longer</u>, the set value is displayed as [- -], and the set value will be the same as the current pressure value automatically (snap shot function (Refer to page 64.)). Afterwards, it is possible to adjust the value by pressing the △ or ✓ button.
- (3) Press the button to complete the setting.



The Pressure switch turns on within a set pressure range (from P1L to P1H) during window comparator mode. Set P1L, the lower limit of the switch operation, and P1H, the upper limit of the switch operation and WH1 (hysteresis) following the instructions given on page 27. (When reversed output is selected, the sub display (left) shows [n1L] and [n1H].) Please refer to the "List of output modes" on page 36 for the relationship between the set values and operation.

*: Set OUT2 in the same way.

Setting of the normal/reverse output switching and hysteresis/window comparator mode switching are performed with the function selection mode [F 1] Setting of OUT1 or [F 2] Setting of OUT2.

Simple Setting Mode

<Operation>


[Simple setting mode (hysteresis mode)

In the simple setting mode, the set value, hysteresis and delay time can be changed while checking the current pressure value (main display).

(1) Press and hold the S button between 1 and 3 seconds in measurement mode. [SEt] is displayed on the main display. When the button is released while in the [SEt] display, the current pressure value is displayed on the main display, [P_1] or [n_1] is displayed on the sub display (left), and the set value is displayed on the sub display (right) (Flashing).



(2) Change the set value with or button, and press the button to set the value. Then, the setting moves to hysteresis setting. (The snap shot function can be used. (Refer to page 64.))




(3) Change the set value with or button, and press the button to set the value. Then, the setting moves to the delay time of the switch output.

(The snap shot function can be used. (Refer to page 64.))



(4) Press the or button, the delay time of the switch output can be selected. Delay time setting can prevent the output from chattering.





- (5) Press the button for <u>2 seconds or longer</u> to complete the setting.

 If the button is pressed for less than 2 seconds, the setting will moves to the OUT2 setting.

 - *2: After enabling the setting by pressing the button, it is possible to return to measurement mode by pressing the button for 2 seconds or longer.
 - *3: When the output mode (refer to page 34) is set to error output or output OFF, the simple setting mode cannot be used. (The setting changes to measurement mode by releasing the button when [SEt] is displayed.)
 - *4: When OUT2 set items are displayed on the sub screen of the measurement mode, step (1) will begin with the OUT2 setting [P_2] or [n_2].




In the window comparator mode, set P1L, the lower limit of the switch operation, and P1H, the upper limit of the switch operation, WH1 (hysteresis) and dt1 (delay time) following the instructions given on page 29. (When reversed output is selected, the sub display (left) shows [n1L] and [n1H].) Please refer to the "List of output modes" on page 36 for the relationship between the set values and operation.

*: Set OUT2 in the same way.

Function Selection Mode

■Function selection mode



*: Some products do not have all the functions. If no function is available or selected due to configuration of other functions, [- - -] is displayed on the sub display (right).

■Default setting

The default setting is as follows.

If no problem is caused by this setting, keep these settings.

To change a setting, enter function selection mode.

•[F 0] Units selection function Page 33

Units specification	Pressure range	Default setting
"NI:I" NA	ISE20C(H)	MPa
"Nil" or M	ZSE20C(F)	kPa
p	ISE20C(H)	:
P	ZSE20C(F)	psi

•[F 1] Setting of OUT1 Page 34

Item	Explanation	Default setting
Output mode	Either hysteresis mode, window comparator mode, error output or output off can be selected.	Hysteresis mode
Reversed output	Selects which type of switch output is used, normal or reversed.	Normal output
Pressure setting	Sets the ON and OFF point of the switch output.	ISE20C : 0.500 MPa ZSE20C : -50.5 kPa ZSE20CF : 50.0 kPa ISE20CH : 1.000 MPa
Hysteresis	Appropriate setting of the hysteresis will prevent the switch output from chattering.	ISE20C : 0.050 MPa ZSE20C : 5.1 kPa ZSE20CF : 5.0 kPa ISE20CH : 0.100 MPa
Delay time	Delay time of the switch output can be selected.	1.5 ms or less
Display color	Selects the output according to the display color.	OUT1 ON: Green OUT1 OFF: Red

•[F 2] Setting of OUT2 Page 37
Same setting as [F 1] OUT1.

Other parameter settings

Item	Page	Default setting	
[F 3] Digital filter setting	Page 39	0 ms	
[F 4] Auto-preset function	Page 40	Not used	
[F 5] FUNC terminal setting	Page 42	Analog output *	
[F 6] Fine adjustment of display value	Page 44	0%	
[F10] Sub display setting	Page 45	std (Standard)	
[F11] Display resolution setting	Page 51	1000-split	
[F80] Power saving mode	Page 52	OFF	
[F81] Security code	Page 53	OFF	
[F82] Input of line name	Page 55	AAAA	
[F90] Setting of all functions	Page 56	OFF	
[F96] Input signal check	Page 58	No configurable items	
[F97] Selection of copy check	Page 59	OFF	
[F98] Output check	Page 61	N/A (normal output)	
[F99] Reset to default settings	Page 63	OFF	

^{*:} For output specifications X and Y, "---" is displayed.

■[F 0] Units selection function

This setting is only available for models with the units selection function.

The unit that can be displayed is different depending on the pressure range.

(kPa/MPa can still be selected if the product does not have the units selection function.)

<Operation>


Press the or button in function selection mode to display [F 0].

Press the button. Move on to display unit selection.

Display unit selection

Press the or button to select the display unit.





Press the button to set. Return to function selection mode.

[F 0] Units selection function completed

Available display unit and minimum set value

Unit	ZSE20CF	ZSE20C	ISE20C	ISE20CH
MPa	0.001	0.001	0.001	0.001
kPa	0.1	0.1	1	1
kgf/cm ²	0.001	0.001	0.01	0.01
bar	0.001	0.001	0.01	0.01
psi	0.02	0.01	0.1	0.2
InHg	0.1	0.1	-	-
mmHg	1	1	-	-

■[F 1] Setting of OUT1

Set the output mode of OUT1.

Output turns on when the pressure is greater than the set value. The default setting is to turn on the pressure switch when the pressure reaches the center of the atmospheric pressure and upper limit of the rated pressure range.


The display color changes according to the OUT1 output status. It will turn Green when the output is ON and it will be Red when the output is OFF.

Please refer to the "List of output modes" on page 36 for the relationship between the set items and operation.




Press the or button in function selection mode to display [F 1].

Press the button. Move on to output mode setting.



Press the (5) button to set. Move on to reversed output setting.



Press the button to set. Move on to pressure setting.

Pressure setting

Set the pressure based on the setting method on page 27.



Hysteresis mode: [P 1]

Window comparator mode: [P1L] [P1H]

"P" is changed to "n" as $[P_1] \rightarrow [n_1]$ when reversed output is selected.

The snap shot function can be used.

(Refer to page 64.)

[OFF] Output off is selected

Press the 5

button to move on to display color setting.

Press the <a> button to set.



Move on to hysteresis setting.




[Err] Error output is

Press the button

to move on to display

selected

color setting.




Press the 🕥 button to set. 🔻 Return to function selection mode.

[F 1] Setting of OUT1 completed

- *2: After enabling the setting by pressing the button, it is possible to return to the measurement mode by keeping pressing the button for 2 seconds or longer.





- *1: The applicable errors are Er6, 8, 9, o.r as well as Er1 or 2 (excluding the error output).
- *: The chart above shows the OUT1 operation. For OUT2, all "1" in the chart will be changed to "2". (example P_1 -> P_2)

If the point at which the switch output changes is outside of the set pressure range due to the selection of normal or reversed output, the hysteresis value is automatically adjusted.



■[F 2] Setting of OUT2

Set the output mode of OUT2.


Output turns on when the pressure is greater than the set value. The default setting is to turn on the pressure switch when the pressure reaches the center of the atmospheric pressure and upper limit of the rated pressure range.

Please refer to the "List of output modes" on page 36 for the relationship between the set items and operation.



Press the or button in function selection mode to display [F 2].


Press the **S** button. Move on to output mode setting.



Press the button to set. Move on to reversed output setting.



Press the or button to select the reversed output.



Press the button to set. Move on to pressure setting.

Pressure setting

Set the pressure based on the setting method on page 27.



Hysteresis mode: [P_2]

Window comparator mode: [P2L] [P2H]

"P" is changed to "n" as $[P_2] \rightarrow [n_2]$ when reversed output is selected.

The snap shot function can be used. (Refer to page 64.)



[Err] Error output is

selected

Press the button to move on to display color setting.




Press the button to set. Move on to hysteresis setting.

selected Press the 5 button to move on to display color setting.

[OFF] Output off is





Press the 🕥 button to set. 🔻 Return to function selection mode.

[F 2] Setting of OUT2 completed

- *1: Selected item becomes valid after pressing the button.
- *2: After enabling the setting by pressing the button, it is possible to return to the measurement mode by keeping pressing the button for 2 seconds or longer.



■[F 3] Digital filter setting


The Digital filter can be selected to filter the pressure measurement.

Output chattering or flicker in the measurement mode display can be reduced by setting the digital filter.

<Operation>

Press the or button in function selection mode to display [F 3].

Press the button. Move on to digital filter setting.



Press the button to set. Return to function selection mode.

[F 3] Digital filter setting completed

- *1: Each set value is a guideline for 90% response time.
- *2: Both the switch output and pressure display are affected. When only switch output needs to be affected, select the delay time setting (page 29, 35 and 38).

■[F 4] Auto-preset function

This function will automatically calculate and set the optimum pressure based on the actual operating condition, when hysteresis mode has been selected.


<Operation>


Press the or button in function selection mode to display [F 4].

Press the **S** button. Move on to Auto-preset function.

Auto-preset function

Press the or button to select the auto-preset function.





Press the button to set. Return to function selection mode.

[F 4] Auto-preset function completed

Press the button in measurement mode to perform the pressure setting. Then, press the button again to change the pressure while the display is flashing. (Refer to page 41 for details.)

Auto-preset

When auto-preset is selected in function selection mode, the set value can be calculated and memorized from the measured pressure. Repeating the suction and release of the workpiece to be set for several times will automatically optimize the set value.

(1) Selection of auto-preset OUT1 mode

Press the button in measurement mode to display [AP1 REdY]. (If setting of OUT1 is not necessary, select [AP1 REdY], and then press the and buttons simultaneously for 1 second or longer. The display will move to [AP2 REdY]).



(2) Preparation of equipment for OUT1

Prepare the equipment for which the pressure of OUT1 is to be set.

(3) Setting of auto-preset for OUT1

Press the button, [AP1 RUn] will be displayed.

Measurement starts. Operate the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device to change the pressure.

(If the number of the device the device to change the pressure.

(If the number of the device the device



(4) Selection of auto-preset OUT2 mode

Press the button to set [P_1],[H_1] ([n_1],[H_1] in reverse output mode) to display [AP2 REdY]. (If the setting of OUT2 is not necessary, press the buttons simultaneously for <u>1 second</u> or longer after [AP2 REdY] display. The display will move to measurement mode).

(5) Preparation of equipment for OUT2

Prepare equipment for which the pressure of OUT2 is to be set, and set the value of OUT2 as in OUT1. [AP2 RUn] will be displayed and measurement will start.

(If the and buttons are pressed simultaneously for 1 second or longer while "AP2 RUn" is displayed, measurement will be stopped and measurement mode will return).

(6) Complete setup

Press the button to set the set value of [P_2] and [H_2] and complete the auto-preset mode. Then, measurement mode returns.

([n_2], [H_2] in reverse output mode.)

The settings in auto-preset will be as follows in OUT1.

•Normal output •Reversed output

 $P_1 = A - (A - B)/4$ $n_1 = B + (A - B)/4$ A = Maximum pressure $H_1 = |(A - B)/2|$ $H_1 = |(A - B)/2|$ B = Minimum pressure

In the OUT2 setting, the above P_1, n_1 and H_1 will be P_2, n_2 and H_2 respectively.

If setting is not necessary press the and buttons simultaneously for 1 second or longer.

■[F 5] FUNC terminal setting

When the product with analog output/auto shift input function is used, the FUNC terminal setting can be selected.

Analog output: Outputs proportional output according to the applied pressure.

Auto-shift: The display indicates the change of relative flow from the reference value.


Auto-shift zero: The display is set to zero when the signal is input, and therefore the display indicates the change of relative flow from the reference value.


Copy input: Copies the set value. Refer to "[F97] Selection of copy function" on page 59.

<Operation>

Press the or button in function selection mode to display [F 5].


Press the button. Move on to FUNC terminal setting.





button to set.

effective output.



[F 5] FUNC terminal setting completed

Conditions and explanations for auto-shift function

- •Maintain a constant pressure for 5 ms or longer from the end of the auto-shift input signal.
- •The sub screen displays "ASin ooo" for approximately 1 second during auto-shift input, and the pressure value is stored as the corrective value "C_5".
- •With the corrected value stored, the set value is compensated.
- •When the set value is corrected, , the switch output will operate in accordance with the delay time, within 5 ms after the auto-shift input.
- •If the measurement pressure during the auto-shift input operation exceeds the set pressure range, the corrected value will not be stored, but "ASin o.r" will be displayed on the sub screen for approximately 1 second.
- •If the measurement value during auto-shift input is within the set pressure range, and the set value corrected by auto-shift (including hysteresis) exceeds the set pressure range, the set value will be corrected to the upper or lower value (whichever is closer).
- (The correction is performed when the auto-shift input is applied at the pressure beyond the set pressure range. If the auto-shift input is applied again at the pressure within the set pressure range, the correction is released and the product operates according to the set value).
- •The corrected value memorized on "C_5" can be displayed on the sub screen in measurement mode. (Refer to "Sub display" on page 46.)
- •The corrected value [C_5] after auto-shift input will disappear when the power is turned off, and will reset to zero (initial value) when the power is returned.

Using the auto-shift input, the acceptable set range is as follows:

Range	Set pressure range	Acceptable set range
Compound pressure	-105.0 to 105.0 kPa	-210 to 210.0 kPa
1 MPa	-0.105 to 1.050 MPa	-1.155 to 1.155 MPa
2 MPa	-0.105 to 2.100 MPa	-2.20 to 2.205 MPa
Vacuum pressure	10.0 to -105.0 kPa	-115.0 to 115.0 kPa



■[F 6] Fine adjustment of display value

This function is to manually perform a fine adjustment of the displayed pressure value. Pressure can be adjusted in the following range of $\pm 5\%$ R.D.

<Operation>

Press the or button in function selection mode to display [F 6].

Press the

Move on to fine adjustment of display value.

Fine adjustment of display value

Press the or button to change adjustment rate.

When adjustment rate is changed, the pressure value after the adjustment will be displayed on the main screen.

Pressure after adjustment

Adjustment rate

Press the button to set. Return to function selection mode.

[F 6] Fine adjustment of display value completed


■[F10] Sub display setting

Change the display style of the sub display.

<Operation>

Press the or button in function selection mode to display [F10].

Press the button. Move on to sub display setting.



Sub display (left) setting

Set the sub display (left) from the selection list on page 47.

Press the button to set. Move to sub display (right) setting.

Sub display (right) setting

Set the sub display (right) from the selection list on page 47.

Press the 👅 button to set. 🔻 Return to function selection mode.

When other than

[dUAL] 2 value

display is selected

Press the button
to set.

Return to function selection mode.

[F10] Sub display setting completed


<Sub display>

Standard


The Standard display function displays the items and values on the sub display.

The displayed item varies depending on the setting of the output mode. Select the displayed items by pressing the or button in measurement mode.

(Hysteresis mode, error output, switch output off)



(Window comparator mode)



•2 value display
The 2 value display function displays the items listed below on the right and left side of the sub display.

List of items for selection

	D	Sub display		D -
Item	Details	Left side	Right side	Remarks
P_1 (n_1)	Set value for OUT1 hysteresis mode	0	0	When hysteresis mode is selected
H_	OUT1 hysteresis mode	0	0	When hysteresis mode is selected
PIL (n IL)	OUT1 Window comparator mode set value (Lower side)	0	0	When window comparator mode is selected
P IH (n IH)	OUT1 Window comparator mode set value (Upper side)	0	0	When window comparator mode is selected
MIH (OUT1 window comparator mode	0	0	When window comparator mode is selected
P_2 (n_2)	Set value for OUT2 hysteresis mode	0	0	When hysteresis mode is selected
H_2	OUT2 hysteresis mode	0	0	When hysteresis mode is selected
P2L (n2L)	OUT2 Window comparator mode set value (Lower side)	0	0	When window comparator mode is selected
P2X (n2X)	OUT2 Window comparator mode set value (Upper side)	0	0	When window comparator mode is selected
MHZ	OUT2 window comparator mode	0	0	When window comparator mode is selected
H_H ,	Pressure peak value	0	х	
H_Lo	Pressure bottom value	Х	0	
C_5	Auto-shift reference value	0	0	When auto-shift input is selected
Un it	Pressure display unit	0	0	
RAnG	Rated pressure range	0	0	
Md I	OUT1 output mode/output style	0	Х	
1195	OUT2 output mode/output style	Х	0	
LinE	String of random characters	0	0	
off	Display OFF	0	0	

Table showing the rated pressure range when RAnG is selected.

Pressure range	Rated pressure	Characters displayed on the sub display	
Vacuum pressure	-101.0 kPa	VACU	
Compound pressure	100 kPa	Eoñ l	
Positive pressure	1 MPa	PoS 1	
Positive pressure	2 MPa	Po52	

Table showing the output mode and output form when Md1 and Md2 are selected.

Output mode	Output style	Display style
Lh ratavasia mada	Normal output	
Hysteresis mode	Reversed output	
Window comparator mode	Normal output][
	Reversed output	- -
Error output	Normal/Reversed output	
Switch output off	-	<u>0</u>


When using the 2 value display function, 3 step setting is not available for the display. (When setting 3 step, select each set value to be displayed by pressing the or button.)

When output operation mode is changed after selecting the 2 value display, the selected display items will not be applicable and [- - -] will be displayed. In this case, select items for the 2 value display setting again.

Level bar display

The Level bar display is a function used to visualize the pressure and the ON area for the switch output on the sub display.

Threshold bar (Switch output ON area)



The display style varies depending on the setting of the output mode.

(In hysteresis mode or window comparator mode)

The threshold bar displaying the switch output ON area is displayed according to the table below, using the output mode.

(During error output or when the output is off)

The threshold bar will not be displayed. Only the pressure value meter is displayed.

Output mode	Output style	Threshold bar display style	
	Normal output		
Hysteresis mode	Reversed output	n_1	
Manda and a sanda	Normal output	P1L P1H	
Window comparator mode	Reversed output	n1L n1H	
Error output	Normal/Reversed output	No indication	
Switch output off	-	No indication	

The Level bar display resolution (pressure for one "O") varies depending on the output mode.

Output mode	Display resolution	
Hysteresis mode	1/10 of P_1(n_1), P_2(n_2)	
Window comparator mode	1/4 of P1H–P1L(n1H–n1L), P2H–P2L(n2H–n2L)	
Error output	Positive pressure, vacuum pressure: Rated maximum pressure - 1/7 of the atmospheric pressure Compound pressure: Rated maximum pressure - 1/4 of the atmospheric pressure	
Switch output off	Positive pressure, vacuum pressure: Rated maximum pressure - 1/7 of the atmospheric pressure Compound pressure: Rated maximum pressure - 1/4 of the atmospheric pressure	

During an error output or when the output setting is off, the pressure value meter at the atmospheric pressure is displayed according to the table below.

Rated range	Display at atmospheric pressure		
Vacuum pressure			
Compound pressure			
Positive pressure			

Character string display

The Character string display function will display the specified characters on the sub display (right). Character setting is performed using the function [F82] Input of line name.



•Display OFF

The Sub display is not displayed.

■[F11] Display resolution setting

This function is to change the pressure display resolution.

The flicker of the display can be reduced.

<Operation>

Press the or button in function selection mode to display [F11].

Press the


button.

Move on to display resolution setting.

Display resolution setting

Press the \bigcirc or \bigcirc button to select the display resolution.





[F11] Display resolution setting completed

The units that allow display resolution to be selected are [MPa], [kPa(ZSE20C(F) only)], [kgf/cm²], [bar], [psi] and [inHg]

(The units [kgf/cm²], [bar], [psi] and [inHg] can only be set when using a product with units selection function.)

Page 33 [F 0] Units selection function

^{*:} It may not be possible to change the resolution depending on the unit of pressure selected.

■[F80] Power saving mode

Power saving mode can be selected.

When selected and no buttons are pressed for 30 seconds, the pressure switch will shift to power saving mode.




Press the or button in function selection mode to display [F80].

Press the button. Move on to power saving mode.



Press the or button to select the power saving mode.





Press the button to set. Return to function selection mode.

[F80] Power saving mode completed

In power saving mode, when buttons are pressed the display is normal, but if no buttons are pressed for 30 seconds, it will revert to power saving mode. (Power saving is only enabled in measurement mode)

During power saving mode, [ECo] will flash in the sub display and the operation light is ON (only when the switch is ON).





At switch ON

At switch OFF

■[F81] Security code

The security code can be turned on or off and the security code can be changed when unlocked.

<Operation>


Press the or button in function selection mode to display [F81].

Press the button. Move on to security code.

Security code

Press the or button to select the setting of security code.





[on] (use) is selected

Press the S button to set.

Move on to security code checking.

Security code checking

Press the or button to input the security code on the sub display (right). (The default setting is [000].)*




For instructions on how to enter the security code, refer to "How to input and change the security code" on page 67.

If the security code entered is incorrect, [FAL] will be displayed, and the security code must be entered again.

If the wrong security code is entered 3 times, [nG] is displayed and the device returns to function selection mode.

Move on to security code changing.



Security code changing

Press the or button to input the changed security code on the main display. *



For instructions on how to enter the security code, refer to "How to input and change the security code" on page 67.

After entry, the changed security code will flash by pressing the button for 1 second.

(At this point, the changing of the security code is not completed)



Return to the change of setting again by pressing the



Press the button for <u>1 second</u> to set.



Return to function selection mode.

[F81] Security code completed

If the security code function is enabled, it is will be necessary to input a security code to release the key-lock.

*: If a key is not pressed for 30 seconds while entering the security code, function selection mode will return.

■[F82] Input of line name

Function to display the specified character string on the sub display.

To display in the measurement mode, select 2 value display [dUAL] or character string display [LinE] using the setting on [F10] Sub display setting.


<Operation>

Press the or button in function selection mode to display [F82].

Press the button. Move on to input of line name.

Input of line name

Press the or button to input the line name displayed on the sub display (right).



(The most significant digit flashes when the 🔳 button is pressed at the least significant digit.)

The order of displayed characters is A \rightarrow b \rightarrow • • • \rightarrow Y \rightarrow (Z) \rightarrow 0 \rightarrow 1 \rightarrow • • • \rightarrow 9 \rightarrow symbol \rightarrow space.

(Characters which can be displayed are different for 1 digit on the left and 3 digits on the right.)

Pressing the and button simultaneously adds/deletes the dot (decimal point).

The set line name flashes by pressing the button for <u>1 second or longer</u>. (At this point, the setting of the line name is not complete.)

[F82] Input of line name completed

•Characters which can be displayed for each digit are as follows.

(Pattern for 3 digits on the right)

Characters Q, X, Z, /, or * cannot be displayed.

A B C D E F G H I J K L M N O P R S T U V W Y

O 1 2 3 4 5 6 7 8 9 Symbol Space (Dot)

(Pattern for 1 digit on the left)

Characters A to Z can be displayed (the same as the 3 digits on the right).



<Pattern for 3 digits on the right>

0 1 2 3 4 5 6 7 8 9 Symbol K M N R V W Space (Dot)



Special function setting


■[F90] Setting of all functions

All functions can be set in turn.



Press the or button in function selection mode to display [F90].

Press the button. Move on to setting of all functions.



*: Setting of each function

Every time the button is pressed, the display moves to the next function in order of "Setting of each function" on page 57. Set by using the and buttons.

For details of how to set each function, refer to the relevant setting of function section in this manual.

[F90] Setting of all functions completed

Measurement mode

Setting of each function

Order	Function		
1	Display unit selection		
2	Setting of OUT1		
3	Setting of OUT2		
4	Digital filter setting		
5	Auto-preset function		
6	FUNC terminal setting		
7	Fine adjustment of display value		
8	Sub display setting		
9	Display resolution setting		
10	Power saving mode		
11	Security code		
12	Input of line name		

- *: Function set before returning to the measurement mode is maintained.

■[F96] Input signal check

Checks the input status of the FUNC terminal when the auto-shift input is set.

<Operation>

Press the or button in function selection mode to display [F96].

Input signal check

Displays the current input status on the sub screen.



5 in of F

Without input signal



With input signal



There is no corresponding function

Press the or button.

Return to function selection mode.



Press the **S** button for <u>2</u> second or longer.

[F96] Setting of input signal check completed

Measurement mode

■[F97] Selection of copy function

The set values of pressure and functions (except for corrected value of fine adjustment of display value and line name) can be copied. When the pressure range, output and unit specifications are the same, this function becomes available. The set value can be copied to up to 10 pressure switches simultaneously.

<Connection>

Connect the pressure switches with the power supply turned off.

Connect the FUNC terminals of the copy source Pressure switch and the copy destination Pressure switches, and then turn on the power supply.

The copy source pressure switch is the switch from which the setting is to be copied.

The copy destination Pressure switch is the switch to which the setting is to be copied.

When the output specifications of the copy destination side pressure switch are R, S, T or V, they should be set to copy input in accordance with the [F 5] FUNC terminal setting (page 42) beforehand.

Copy destination Pressure switch

Copy source

Pressure switch

1 block

2 blocks

0UT2

0UT2

0UT1

DC(+)

Brown

DC(+)

Brown

DC(+)

Brown

DC(-)

Blue

Copy line

Copy line

Copy destination Pressure switch

Copy source

Pressure switch

1 block

2 blocks

Copy line

DC(-)

Blue


Copy line

Copy line

<Operation>


Press the or button of the copy source Pressure switch in function selection mode to display [F97].


Press the button. Move on to selection of copy function.



12 to 24 VDC

Return to function selection mode.







Copy ready status



Even though the power supply is turned OFF, the copy ready status will be retained.

Press the button to start copying.



	The copy source Pressure switch		The copy destination Pressure sw	
Sending/ Receiving	F 	Main display: Red	Cors SLAGAU _O E	Main display: Green
Сору	[_Du]		•When completed normally.	Main display: Green
completed		Main display: Red	•When error occurs.	Main display: Red

(Copy source) Press the 5 button.



The copy can be made continuously and the copy ready status can be held even if the power supply is turned off.



Copy is ready

To complete the copy function, press the and buttons simultaneously for 1 second or longer.

(Copy source) Press the and **buttons** simultaneously for 1 second or longer.

(Сору destination) When completed normally. Press the 5

[F97] Setting of selection of copy function completed

Measurement mode

- *: When the copy destination pressure switch displays [Er13], it indicates a sending and receiving error of the copy function. Press the and buttons simultaneously for 1 second or longer to return to measurement mode. Then, check the wiring and specifications of the switch and retry the copy function.
- *: When copy is conducted so that the analog output is used, set the FUNC terminal setting of the copy source pressure switch to Aout, then conduct a copy. The FUNC terminal setting of the copy destination pressure switch will be Aout when the copy is complete.



■[F98] Output check

Correct operation of the switch output can be confirmed.

The output can be turned ON/OFF manually.

<Operation>

Press the or button in function selection mode to display [F98].

Press the button. Move on to output check.




Press the or button to select output check.





Normal output Forcibly output (Output not checked) (Output is checked)







Move on to OUT1 output check.

[n] (Normal output) is selected
Press the button to set.

Return to function selection mode.







^{*:} Measurement mode can return from any setting item by pressing the button for 2 seconds or longer.

■[F99] Reset to default settings

If the product settings are uncertain, the default values can be restored.

<Operation>


Press the or button in function selection mode to display [F99].

Press the button. Move on to reset to default settings.


Reset to default settings

Press the or button to select reset to default settings.





Unused Reset to the default setting



Return to function selection mode.

[on] (reset to default settings) is selected

Press the sand buttons simultaneously for second or longer.

All settings are returned to the default values. Return to function selection mode.

[F99] Reset to default settings completed

Other Settings

Snap shot function

The current pressure value can be stored to the switch output ON/OFF set point.

When the items of sub display (left) below are selected in 3 step setting mode, simple setting mode or function selection mode ([F 1] Setting of OUT1, [F 2] Setting of OUT2), by pressing the and buttons simultaneously for 1 second or longer, the value of the sub display (right) shows [- - -], and the values corresponding to the current pressure values are automatically displayed.

Output mode	Configurable items	Sub display (left)	Snap shot function
Livetava sia va ada	OUT1, OUT2 set value	P_1 (n_1), P_2 (n_2)	0
Hysteresis mode	Hysteresis	H_	0
Window comparator mode	OUT1, OUT2 set value	P.IL (n.IL), P.IX (n.IX) P2L (n2L), P2X (n2X)	0
	Hysteresis		Х

•OUT1 set value and OUT2 set value

The value is set to the same value as the display value (current pressure value).

(There is a range which cannot be set to the current pressure depending on the hysteresis. In that case, the value is set to the closest value.)

•Hysteresis

The hysteresis is calculated from the equation below and set.

Normal output: (OUT1(2) set value) - (current pressure value) Reverse output: (current pressure value) - (OUT1(2) set value)

If the calculation result becomes 0 or less, [Err] is displayed on the sub display (right) and the set value is not changed.

Afterwards, it is possible to adjust the value by pressing the or button.


Peak/bottom value indication

The maximum (minimum) pressure when the power is supplied is detected and updated.

In peak/bottom indication mode, the current pressure is displayed.

Press the or button in measurement mode to switch the sub-display (left) to the display shown below.

Peak/bottom values are displayed on the sub display (right) at the same time as the current pressure value on the main display.



Peak/bottom values are maintained even if the power supply is cut.

When the sub displays (right) displays [- - -] and the maximum (minimum) pressure value are cleared.

oZero-clear function

The displayed value can be adjusted to zero if the pressure being measured is within $\pm 7\%$ F.S ($\pm 3.5\%$ F.S. for compound pressure) of the zero point set at the time of default settings.

(The zero clear range varies by ±1%F.S. due to variation between individual products.)

In measurement mode, when the and buttons are pressed for <u>1 second or longer</u> simultaneously, the main display shows [- - -], and the reset to zero. The display returns to measurement mode automatically.



Key-lock function

The key-lock function is used to prevent errors occurring due to unintentional changes of the set values. If the subtron is pressed while the keys are locked, [LoC] is displayed on the sub display (left) for approximately 1 second.

(Each setting and peak/bottom values are displayed with and buttons. In that case, the sub screen will return after 30 seconds.)

<Operation - Without security code input ->


(1) Press the button for <u>5 seconds or longer</u> in measurement mode. When [oPE] is displayed on the main display, release the button.

The current setting [LoC] or [UnL] will be displayed on the sub display.

(To release key-lock repeat the above operation.)



(2) Select the key-locking/un-locking with or button, and press the button to set.



<Operation – With security code input ->


Locking

(1) Press the button for <u>5 seconds or longer</u> in measurement mode. When [oPE] is displayed on the main display, release the button.

The current setting [LoC] or [UnL] will be displayed on the sub display.



(2) Select the key [LoC] with or button, and press the button to set.




Unlocking

The current setting [LoC] or [UnL] will be displayed on the sub display.



(2) Select the un-locking [UnL] with or button. Setting is recognized by pressing the button, then security code is required.



(3) For instructions on how to enter the security code, refer to "How to input and change the security code" on page 67.



(4) If inputted security code is correct, the indication of the main display changes to [UnL], and pressing the one of , so we button releases key-lock and the measurement mode returns. If the security code entered is incorrect, [FAL] will be displayed, and the security code must be entered again. If the wrong security code is entered 3 times, [LoC] is displayed and the device returns to measurement mode.



How to input and change the security code


The left most digit starts flashing.

Press the or button to select a value.

(If the button is pressed at the last digit, the first digit will start flashing.)

After the setting is complete, Press and hold the button for <u>1 second or longer</u>.

(If an operation is not performed for <u>30 seconds</u> during input or change of the security code, it will return to measurement mode.)



Maintenance

How to reset the product after a power cut or forcible de-energizing

The setting of the product will be retained as it was before a power cut or de-energizing. The output condition is also basically recovered to that before a power cut or de-energizing, but may change depending on the operating environment. Therefore, check the safety of the whole installation before operating the product. If the installation is using accurate control, wait until the product has warmed up (approximately 10 to 15 minutes).

Forgotten the security code

If you have forgotten your security code, please contact SMC directly.





Troubleshooting

Troubleshooting

Applicable pressure switch: ZSE20C(F)/ISE20C(H)

When any failure occurs with this product, the following chart can be used to identify the cause of the failure. If a cause applicable to the troubles cannot be identified and normal operation is recovered by replacement with a new product, this indicates that the product itself was faulty. Problems with the product may be due to the operating environment (installation etc). Please consult SMC.





$\circ \textbf{Troubleshooting list}$

Problem No.	Problem	Problem possible causes	Investigation method	Countermeasures
1	•Output remains ON. Indicator LED remains ON. •Output remains OFF.	Incorrect pressure setting	(1) Check the set pressure. (2) Check the operation mode, hysteresis and output type. (hysteresis mode/window comparator mode, normal/reversed output)	(1) Reset the pressure setting.(2) Reset the function settings.
	Indicator LED remains OFF.	Product failure		Replace the product.
2	Output remains ON. Indicator LED	Incorrect wiring	Check the wiring of the output. Check if the load is connected directly to DC(+) or DC(-).	Correct the wiring.
	works correctly.	Product failure		Replace the product.
	Incorrect wiring	Check the wiring of the output. Check if the load is connected directly to DC(+) or DC(-).	Correct the wiring.	
3	Output remains OFF.	Unsuitable model selection	Check if PNP is used when NPN should have been selected, or the other way around.	Review the selected model (output type).
Indicator LED works correctly.		Broken lead wire	Check if there is bending stress applied to any parts of the lead wire. (bending radius and tensile force applied)	Correct the wiring conditions. (adjust the tensile force and increase the bending radius.)
		Product failure		Replace the product.
Switch output generates chattering.	Incorrect wiring	Check the wiring. Check if the brown and blue wires are connected to DC(+) and DC(-) respectively, and if the output wiring is loose (contact failure).	Correct the wiring.	
	generates chattering.	Incorrect settings	(1) Check the set pressure.(2) Check that the hysteresis range is not too narrow.(3) Check the delay time setting. Check if the delay time is too short.	(1) Reset the pressure setting.(2) Increase the hysteresis.(3) Reset the function settings.
		Product failure		Replace the product.

Problem No.	Problem	Problem possible causes	Investigation method	Countermeasures
5	Slow switch output response	Incorrect pressure setting	Check the pressure setting. Check that the detected pressure and the set pressure value are not the same or not too close.	Reset the pressure setting. Set the pressure setting value so it is not too close to the detected pressure.
		I Incorrect wiring	Check that the analog output is connected to a load.	Correct the wiring.
6 (s			(1) Check that the correct load is connected.(2) Check that the impedance of the input equipment (A/D transformer) is suitable.	Connect a suitable load.
			Check if the product satisfies the specified accuracy after 10 minutes warm up time.	After energizing, the display and output can drift. For detecting fine pressures, warm up the product for 10 to 15 minutes.
		Product failure		Replace the product.

Problem No.	Problem	Problem possible causes	Investigation method	Countermeasures
		Over current to the output (Er1 and 2)	 (1) Check that the switch output load current is not more than 80 mA. (2) Check that the connected load satisfies the specifications, and check the load for short circuits. (3) Check that any relay is connected with a surge voltage suppressor. (4) Check if the wiring is not in the same route as (or bundled together with) a high voltage cable or power cable. 	 (1), (2) Connect the load as specified. (3) Use a relay with a surge voltage suppressor or take measures to prevent noise. (4) Separate the wiring route from any high voltage cable or power cable.
7	An over current error (Er1, Er2) is displayed. System error (Er0, Er4, Er6, Er7, Er8 or Er9) is displayed. Copy error (Er13) is displayed. The display shows "HHH". Residual pressure error (Er3) is displayed.	Incorrect operation of the internal data of the Pressure switch (Er0, Er4, Er6, Er7, Er8, Er9)	(1) Check that there is no noise interference such as static electricity, and check for noise sources.(2) Check that the power supply voltage is within the range 12 to 24 VDC ±10%.	 (1) Remove the noise and the noise source (or take measures to prevent noise interference), and reset the product or turn off the power supply. Then, supply the power again. (2) Supply a correct voltage of 12 to 24 VDC ±10%.
		Copy function has been operated incorrectly (Er13)	Refer to Trouble No.18.	
		Applied pressure is above the upper limit (HHH)	(1) Check that the pressure is not above the upper limit of the set pressure range.(2) Check that foreign matter has not entered the piping.	(1) Adjust the pressure to within the set pressure range.(2) Take measures to prevent foreign matter from entering the piping.
		Applied pressure is below the lower limit (LLL)	(1) Check that the pressure is not below the lower limit of the set pressure range.(2) Check that foreign matter has not entered the piping.	(1) Adjust the pressure to within the set pressure range.(2) Take measures to prevent foreign matter from entering the piping.
		Pressure is not atmospheric pressure at zero-clear operation (Er3)	Check that during the zero clear operation, pressure above ±7% F.S. (±3.5%F.S. for compound pressure) was not applied.	Return the applied pressure to atmospheric pressure, and retry the zero clear operation.
		Product failure		Replace the product.

Problem No.	Problem	Problem possible causes	Investigation method	Countermeasures	
	Displayed value fluctuates.	Incorrect power supply	Check that the power supply voltage is within the range 12 to 24 VDC ±10%.	Supply the correct voltage of 12 to 24 VDC ±10%.	
8		Incorrect wiring	Check the wiring to the power supply. Check that the brown and blue wires are connected to DC(+) and DC(-) respectively and that the output wiring is not loose (contact failure).	Correct the wiring.	
		Factory pressure change	Check if the factory pressure has changed.	If the fluctuation is not acceptable, the product display resolution can be changed. Digital filter setting also needs to be improved.	
		Incorrect power supply	Check that the power supply voltage is within the range 12 to 24 VDC ±10%.	Supply the correct voltage of 12 to 24 VDC ±10%.	
9	Display turns OFF. Part of the display is missing.	Incorrect wiring	Check the power supply wiring. Check that the brown and blue wires are connected to DC(+) and DC(-) respectively and that the output wiring is not loose (contact failure).	Correct the wiring.	
		Power saving mode	Check if the power saving mode is selected.	Reset the function settings.	
		Product failure		Replace the product.	
10	Display is flashing.	Wiring failure	(1) Check the power supply wiring.(2) Check if there is bending stress applied to any parts of the lead wire.	ing stress conditions (reduce the	
11	Pressure display difference when using 2 or more Pressure switches.	Dispersion within the display accuracy range Product failure	display accuracy range. The dispersion is within the dispersion is display accuracy display accuracy		

Problem No.	Problem	Problem possible causes	Investigation method	Countermeasures
		Foreign matter	Check if any foreign matter has entered the piping port.	Install a 5 µm filter to prevent foreign matter from entering the piping port. Also, clean the filter regularly to prevent drainage deposits.
12	The pressure display accuracy does not satisfy the specifications.	Air or fluid leakage	Check if air or fluid are leaking from the piping.	Rework the piping. If an excessive tightening torque is applied, the mounting bracket, screws or the product may be damaged.
		Insufficient warm-up time	Check if the product satisfies the specified accuracy after 10 minutes warm up time.	After energizing, the display and output can drift. For detecting fine pressures, warm up the product for 10 to 15 minutes.
		Product failure		Replace the product.
The display unit cannot be changed.		Improper model selection (selection of model "without units selection function")	Check that the product No. printed on the product is equipped with unit switching function.	Unit selection function is not available for models which are fixed to SI units. (kPa↔MPa can be selected) *: The units selection function is not available in Japan due to a new measurement law. *: It is fixed to the SI unit "kPa", "MPa".
		Product failure		Replace the product.
14	The buttons cannot be	Key lock mode	Check if the key lock mode is turned on.	Turn off the key lock mode.
	operated.	Product failure		Replace the product.
15	The product is loose.	Incorrect installation	Check that the panel mount adapter and the product are correctly assembled.	Mount the product on the panel correctly.
		Product failure		Replace the product.
The product is		Air or fluid leakage	Check if air or fluid are leaking from the piping.	Rework the piping. If an excessive tightening torque is applied, the mounting bracket, screws or the product may be damaged.
		Product failure		Replace the product.
17	Copy function error Unable to copy	Incorrect wiring	(1) Check the wiring connection at the FUNC terminal. (2) Check the power supply wiring.	
	- Shable to copy	Product failure		Replace the product.

Problem No.	Problem	Problem possible causes	Investigation method Countermeasures	
18		Incorrect wiring	(1) Check the wiring connection at the FUNC terminal.Check the power supply wiring.(2) Check the lead wire lengths.	(1) Correct the wiring.(2) The maximum transmitting distance of the copy function is 4 m. Shorten the lead wire to 4 m or less.
	Copy error [Er13] is displayed on the copy destination pressure switch.	Improper model selected Improper model selected Improper model source Pressure switch and the copy destination Pressure switch are different from each other	Check the model numbers. Copying is available when the pressure range, output specification and units specification are identical.	
		Too many pressure switches connected	Check the number of connected copy destination Pressure switches.	The number of connected products for which copying is possible is up to 10 pcs. Reduce the number to 10 pcs. or less.
		Product failure		Replace the product.
19	The operation is unstable.	Effect of line pressure fluctuation because hysteresis is too narrow or delay time of the switch is too short	(1) Check the set pressure values (hysteresis)(2) Check the delay time.	(1) Check the pressure setting.(2) Reset the function settings.
19	(chattering)	Incorrect wiring or broken lead wire	(1) Check the power supply wiring.(2) Check if there is bending stress applied to any parts of the lead wire.	(1) Correct the wiring (2) Correct the wiring conditions (reduce the tensile force and increase the bending radius).
		Product failure		Replace the product.

oError indication function

This function is to display error location and content when a problem or error has occurred.

Error	Error displayed	Description Description	Measures
Over current error	Er I Er Z	The switch output load current is 80 mA or more.	Turn the power off and remove the cause of the over current. Then supply the power again.
Residual pressure error	IEro	During zero clear operation, pressure greater than ±7% F.S. (±3.5% F.S. for compound pressure) is present. Note that the mode is returned to measurement mode automatically 1 second later. The zero clear range varies by ±1% F.S. due to variation between individual products.	Release the applied pressure to atmospheric pressure, and retry the zero clear operation.
Pressurizing	HHH	Pressure exceeding the upper limit of the set pressure range is applied.	Reset applied pressure to a level within the set
error		Pressure exceeding the lower limit of the set pressure range is applied.	pressure range.
System error	Er [] Er 4 Er 6 Er 7 Er 8 Er 9	Displayed if an internal data error has occurred.	Turn the power off and on again. If the failure cannot be solved, contact SMC.
Copy error	Fr 13 SLAu	Copy function is operated incorrectly.	Press the and buttons simultaneously for 1 second or more to clear the error. Then check the wiring and model before copying again.

If the error cannot be reset after the above measures are taken, or errors other than above are displayed, please contact SMC.



Specification

■Specifications

<u>■Spe</u>	cilica	110115					
Product No.			ZSE20C (Vacuum pressure)	ZSE20CF (Compound pressure)	ISE20C (Positive pressure)	ISE20CH (Positive pressure)	
Applic	able flu	uid	Fluids which do not corrode SUS630, SUS304				
oec.	Rated	pressure range	0.0 to -101.0 kPa	-100.0 to 100.0 kPa	-0.100 to 1.000 MPa	-0.100 to 2.000 MPa	
Pressure spec.	Display/Set pressure range		10.0 to -105.0 kPa	-105.0 to 105.0 kPa	-0.105 to 1.050 MPa	-0.105 to 2.100 MPa	
Pre	Displa	ay/Min. setting unit	0.1 kPa 0.001 MPa				
	Proof	pressure	500	kPa	2 MPa	4 MPa	
Power supply spec.	Powe	r supply voltage	12	to 24 VDC±10%,	ripple max. 10% (p	-p)	
rer su	Curre	nt consumption		35 mA	or less		
Pow	Protec	ction		Polarity p	protection		
	Displa	ay accuracy	±2%F.	S. ±1 digit (at ambi	ent temperature 25	5±3 °C)	
acy	Repea	atability		±0.2%F.8	S. ±1 digit		
Accuracy	Analo	g output accuracy	±2.5	5%F.S. (at ambient	temperature 25±3	°C)	
AC	Analo	g output linearity	±1%F.S.				
	Temp	erature characteristics	±3%F.S. (25 °C standard)				
	Output type		NPN or PNP open collector 2 outputs				
	Output mode		Hysteresis mode, window comparator mode, error output, switch output off				
	Switch operation			Normal output,	reversed output		
	Maximum load current			80	mA		
tput	Maximum applied voltage (NPN output)		28 V				
Switch output		al voltage drop dual voltage)	1 V or less (Load current 80 mA)				
Sv	Delay	time *1	1.5 ms or less (delay time available for anti-chattering function: 20,100,500,1000,2000 or 5000 ms)				
	Hysteresis	Hysteresis mode	Variable from 0 *2				
	Hyst	Window comparator mode		73.132.10			
	Short	circuit protection		Prov	vided		
	Voltage output	Output type	Voltage out	out: 1 to 5 V	Voltage output: 0.6 to 5 V	Voltage output: 0.8 to 5 V	
tput	> s	Output impedance		Approx	x. 1 kΩ		
Analog output	utput	Output type	Current outpu	ut: 4 to 20 mA	Current output: 2.4 to 20 mA	Current output: 3.2 to 20 mA	
Ans	Current output	Load impedance	l		power supply voltage of 12 VDC) power supply voltage of 24 VDC)		
#	Input	type	Min. lead impedance: 50 Ω				
Auto-shift input			Non-voltage input : 0.4 V or less				
Auto	Input mode Input time		Select from auto-shift, auto-shift zero				
1	Input	une	5 ms or more				

Product No.		ZSE20C (Vacuum pressure)	ZSE20CF (Compound pressure)	ISE20C (Positive pressure)	ISE20CH (Positive pressure)	
	Unit *3	MPa, kPa, kgf/cm², bar, psi, lnHg, mmHg		MPa, kPa, kg	MPa, kPa, kgf/cm², bar, psi	
	Display type		LCD			
a	Number of displays	3-scr	een display (Main	display, sub display	/ x 2)	
Display	Display color		1) Main display: Red/Green 2) Sub display: Orange			
	Number of display digits	Main display: 4 digits (7-segments) Sub display: 4 digits (Upper 1 digit 11-segments, 7-segments for other)				
	Operation light	LED is ON when switch output is ON (OUT1, OUT2: Orange)				
Digita	l filter *4	0, 10, 50, 100, 500, 1000, 5000 ms				
	Enclosure	IP65				
ent	Withstand voltage	250 VAC for 1 minute between terminals and housing				
ŭ.	Insulation resistance	$2~\text{M}\Omega$ or more between terminals and housing (with 50 VDC megger)				
Environment	Ambient temperature range	Operation: -5 to 50 °C, Storage: -10 to 60 °C (No condensation or freezing)) °C	
	Operating humidity range	Operation, Storage: 35 to 85%RH (No condensation)				
Stand	ard	UL/CSA(E216656), CE/UKCA marked				
Lengt	h of lead wire with connector	2 m				

- *1: Value without digital filter (at 0 ms).
- *2: If the applied pressure fluctuates around the set value, the hysteresis must be set to a value more than the amount of fluctuation or chattering will occur.
- *3: This setting is only available for models with the units selection function. Only MPa or kPa is available for models without this function.
- *4: The response time indicates when the set value is 90% in relation to the step input.
- *5: Any products with tiny scratches, smears, or variations in the display color or brightness, which does not affect the performance of the product, are verified as conforming products.

oPiping/weight specifications

Product N	No.	02(L) N02(L) F02(L) C01(L) A2(L) B2(L)					B2(L)
Port size		R1/4 NPT1/4 G1/4 Rc1/8 URJ1/4 TSJ1/4				TSJ1/4	
Materials in fluid contact part	Pressure-sensing part	Pressure sensor: SUS630, Fitting: SUS304					
ŧ	Body (Rear piping)	51 g	51 g	48 g	47 g	54 g	46 g
Body (Rear piping) Body (Bottom piping)		77 g	78 g	74 g	65 g	81 g	72 g
\$	Lead wire with connector	+39 g					
Leakage 1 x 10 ⁻⁵ Pa • m³/s 1 x 10 ⁻⁶			1 x 10 ⁻¹⁰ l	Pa ∙ m³/s			


oCable specifications

Conductor area		0.15 mm² (AWG26)	
Outside diameter Color		1.0 mm	
Color		Brown, Blue, Black, White, Gray (5 core)	
Sheath	Finished outside diameter	φ3.5	




oAnalog output

Voltage output



Current output



Range	Rated pressure range	А	В	С
Vacuum	0.0 to -101.0 kPa	1	0	-101.0 kPa
Compound	-100.0 to 100.0 kPa	•	-100 kPa	100 kPa
Daniti va nananana	-0.100 to 1.000 MPa	-0.1 MPa	0	1 MPa
Positive pressure	-0.100 to 2.00 MPa	-0.1 MPa*	0	2 MPa


^{*:} Analog output is 0.8 [V] or 3.2 [mA] at the pressure A.

■Dimensions


Lead wire with connector

02 type 48.4 Atmospheric vent port 1.5 (N02: 48.9) 20 $4 \times \phi 2.6$ 30 25 8.5 11 depth 7 or less M5 x 0.8 thread depth 5 30 Ш \triangle Piping port 02: R1/4 N02: NPT1/4 \Box


F02 type




C01 type




A2 type




B2 type




02L type







F02L type




C01L type



A2L type





B2L type




oBracket mounting dimensions


Bracket A










Bracket C







oMounting dimensions of panel mount adapter (rear piping type)













oMounting dimension of panel mount adapter (rear piping type) + Front protective cover













oMounting dimensions of panel mount adapter (bottom piping type)









oMounting dimension of panel mount adapter (bottom piping type) + Front protective cover










oPanel cutout dimensions (rear piping type)

Mount individually




More than 2 pcs. (n pcs.) Close mounting <Horizontal>







<Vertical>




Panel cutout dimensions (bottom piping type)Mount individually



More than 2 pcs. (n pcs.) Close mounting <Horizontal>





Revision history

- A: Contents revised in several places. [July 2018]
- B: Contents revised in several places. [February 2020]
- C: Modified errors in text. [February 2021]
- D: Contents revised in several places. [February 2022]
- E: Contents revised in several places. [June 2023]
- F: Contents revised in several places. [December 2023]
- G: Contents revised in several places. [May 2024]
- H: Contents revised in several places. [August 2024]

SMC Corporation

Tel: + 81 3 5207 8249 Fax: +81 3 5298 5362

URL https://www.smcworld.com

Note: Specifications are subject to change without prior notice and any obligation on the part of the manufacturer. © SMC Corporation All Rights Reserved

