

# Electro-Pneumatic Regulator Electronic Vacuum Regulator



RoHS

IP65

- Stepless control of air pressure proportional to an electrical signal
- Added Fieldbus compliant specifications to Series ITV1000/2000/3000!

- Reduced wiring

Applicable Fieldbus protocols



Built-in communication board, so no converter needed.

- Added RS-232C specification to serial communications!

Compact/lightweight (Integrated communication parts)

Weight: **350 g** <sup>Note 1)</sup> (ITV1000)

Power consumption: **4 w** <sup>Note 1)</sup> or less

Note 1) Value for communications type. (PROFIBUS DP)



Note 2) ITV1000. Dimensions in parentheses ( ) are for the CC-Link or PROFIBUS DP.

## ▼ Electro-Pneumatic Regulators

### Series ITV0000

Maximum flow rate

**6 l/min (ANR)**

Set pressure: 0.6 MPa

Supply pressure: 1.0 MPa



### Series ITV1000

Maximum flow rate

**200 l/min (ANR)**

Set pressure: 0.6 MPa

Supply pressure: 1.0 MPa

Grease-free specification (wetted parts)



### Series ITV2000

Maximum flow rate

**1500 l/min (ANR)**

Set pressure: 0.6 MPa

Supply pressure: 1.0 MPa



### Series ITV3000

Maximum flow rate

**4000 l/min (ANR)**

Set pressure: 0.6 MPa

Supply pressure: 1.0 MPa



## ▼ Electronic Vacuum Regulators

### Series ITV009



### Series ITV209



Series **ITV**



CAT.EUS60-15Ff-UK

# Compact Electro-Pneumatic Regulator Series *ITV0000*

# Compact Vacuum Regulator Series *ITV009*

**Compact 15 mm**

With a simplified high-density circuit board design, an extremely compact size has been achieved.

**Lightweight 100 g**

**Realizes space-saving and reduction of weight for manifold use.**


Stations can easily be increased or decreased due to DIN rail mount design.



Model	Pressure range	Power supply voltage	Input signal	Output signal	Option
ITV001	0.1 MPa	24 VDC 12 VDC	4 to 20 mA DC 0 to 20 mA DC 0 to 5 VDC 0 to 10 VDC	Analogue output 1 to 5 V	<ul style="list-style-type: none"> <li>Cable connectors Straight type Right angle type</li> <li>Brackets Flat bracket L-bracket</li> </ul>
ITV003	0.5 MPa				
ITV005	0.9 MPa				
ITV009	-100 kPa				

## Cable connectors

Straight type and right angle type are available.




## Built-in One-touch fittings

## With error indication LED

## Brackets

Flat and L-brackets are available.



## Equivalent to IP65

● **Linearity: Within ±1% (F.S.)**


**Hysteresis: Within 0.5% (F.S.)**

**Repeatability: Within ±0.5% (F.S.)**

● **High-speed response time: 0.1 sec (Without load)**

● **High stability**

Sensitivity within 0.2% (F.S.)



# Electro-Pneumatic Regulator Series *ITV1000/2000/3000*

# Electronic Vacuum Regulator Series *ITV209*



**Added Fieldbus compliant specifications to Series *ITV1000/2000/3000*!**


## Reduced wiring

Applicable Fieldbus protocols





**Added RS-232C specification to serial communications!**

- Sensitivity: Within 0.2% (F.S.)
- Linearity: Within ±1% (F.S.)
- Hysteresis: Within 0.5% (F.S.)
- IP65
- Cable connections in 2 directions



- Grease-free specification (Series ITV1000)







## Application examples



# Electro-Pneumatic Regulator Electronic Vacuum Regulator

## Series *ITV*

- Stepless control of air pressure proportional to an electrical signal.

Series	Model	Set pressure range	Input signal	Port size	Page
<b>Series ITV0000</b> 	ITV001□	0.001 to 0.1 MPa	Current type: 4 to 20 mA DC Current type: 0 to 20 mA DC Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC	Built-in One-touch fittings Metric size: ø4 Inch size: ø5/32	<b>1</b>
	ITV003□	0.001 to 0.5 MPa			
	ITV005□	0.001 to 0.9 MPa			
<b>Series ITV1000</b> 	ITV101□	0.005 to 0.1 MPa	Current type: 4 to 20 mA DC (Sink type) Current type: 0 to 20 mA DC (Sink type) Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC Preset input (4 points/16 points) 10 bit digital input CC-Link compatible DeviceNet™ compatible PROFIBUS DP compatible RS-232C communication	1/8, 1/4	<b>9</b>
	ITV103□	0.005 to 0.5 MPa			
	ITV105□	0.005 to 0.9 MPa			
<b>Series ITV2000</b> 	ITV201□	0.005 to 0.1 MPa	Current type: 4 to 20 mA DC (Sink type) Current type: 0 to 20 mA DC (Sink type) Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC Preset input (4 points/16 points) 10 bit digital input CC-Link compatible DeviceNet™ compatible PROFIBUS DP compatible RS-232C communication	1/4, 3/8	<b>9</b>
	ITV203□	0.005 to 0.5 MPa			
	ITV205□	0.005 to 0.9 MPa			
<b>Series ITV3000</b> 	ITV301□	0.005 to 0.1 MPa	Current type: 4 to 20 mA DC (Sink type) Current type: 0 to 20 mA DC (Sink type) Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC Preset input (4 points/16 points) 10 bit digital input CC-Link compatible DeviceNet™ compatible PROFIBUS DP compatible RS-232C communication	1/4, 3/8, 1/2	<b>9</b>
	ITV303□	0.005 to 0.5 MPa			
	ITV305□	0.005 to 0.9 MPa			
<b>Series ITV009□</b> 	ITV009□	-1 to -100 kPa	Current type: 4 to 20 mA DC Current type: 0 to 20 mA DC Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC	Built-in One-touch fittings Metric size: ø4 Inch size: ø5/32	<b>28</b>
	ITV009□	-1 to -100 kPa			
<b>Series ITV209□</b> 	ITV209□	-1.3 to -80 kPa	Current type: 4 to 20 mA DC (Sink type) Current type: 0 to 20 mA DC (Sink type) Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC Preset input (4 points/16 points) 10 bit digital input CC-Link compatible DeviceNet™ compatible PROFIBUS DP compatible RS-232C communication	1/4	<b>35</b>

# Compact Electro-Pneumatic Regulator Series *ITV0000*



## How to Order

For single unit and single unit for manifold

**ITV00** 1 0 - 3        

**Pressure range**

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa

**Power supply voltage**

0	24 VDC ±10%
1	12 to 15 VDC

**Input signal**

0	Current type 4 to 20 mA DC (sink type)
1	Current type 0 to 20 mA DC (sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC

**Built-in One-touch fittings type**

**For single unit**

Symbol	SUP <sup>1</sup>	OUT <sup>2</sup>	EXH <sup>3</sup>
—	Metric size (Light grey)	ø4	
U	Inch size (Orange)	ø5/32"	



**For manifold**

Symbol	SUP <sup>1</sup>	OUT <sup>2</sup>	EXH <sup>3</sup>	
—	Metric size (Light grey)	ø6	ø4	ø6
U	Inch size (Orange)	ø1/4"	ø5/32"	ø1/4"

**Cable connector (Option)**

N	Without cable connector
S	Straight type 3 m
L	Right angle type 2 m

**Bracket/Option for single unit only**

—	Without bracket
B	Flat Bracket 
C	L-bracket 

**Base type**

—	For single unit
M	For manifolds

## Manifold

**IITV00** - 02   - n

**Stations**

02	2 stations
03	3 stations
⋮	⋮
10	10 stations

**Option**

If a DIN rail longer than the specified stations is required, specify the applicable stations in two digits.  
(Maximum 10 stations)  
Example) IITV00-05-07

**One-touch fitting size for supply/exhaust parts (End plate)**

—	ø6 (Light grey)
U	ø1/4" (Orange)

Note) A DIN rail with the length specified by the number of stations is attached to the manifold. For dimensions of the DIN rail, refer to the external dimensions.

## How to Order Manifold Assembly (Example)

Indicate the part numbers of electro-pneumatic regulators and options to be mounted below the manifold part number.

Example)

Due to the common supply/exhaust feature, note that different pressure range combinations are not available.

**IITV00-03.....1 set (Manifold part no.)**


\*ITV0030-3MS.....2 sets (Electro-pneumatic regulator part no. (1, 2 stations))

\*ITV0030-3ML.....1 set (Electro-pneumatic regulator part no. (3 stations))


Indicate part numbers in order starting from the first station on the D side.

Note) Combination with having different pressure ranges is not available due to common supply/exhaust features.

The asterisk (\*) specifies mounting. Add an asterisk (\*) at the beginning of electro-pneumatic regulator part numbers to be mounted.



## Specifications



Model		ITV001□	ITV003□	ITV005□
<b>Minimum supply pressure</b>		Set pressure +0.1 MPa		
<b>Maximum supply pressure</b>		0.2 MPa	1.0 MPa	
<b>Set pressure range</b>		0.001 to 0.1 MPa	0.001 to 0.5 MPa	0.001 to 0.9 MPa
<b>Power supply</b>	<b>Voltage</b>	24 VDC ±10%, 12 to 15 VDC		
	<b>Current consumption</b>	Power supply voltage 24 VDC type: 0.12 A or less Power supply voltage 12 to 15 VDC type: 0.18 A or less		
<b>Input signal</b>	<b>Voltage type</b>	0 to 5 VDC, 0 to 10 VDC		
	<b>Current type</b>	4 to 20 mA DC, 0 to 20 mA DC		
<b>Input impedance</b>	<b>Voltage type</b>	Approximately 10 kΩ		
	<b>Current type</b>	Approximately 250 Ω		
<b>Output signal</b>	<b>Analogue output</b>	1 to 5 VDC (Output impedance: Approximately 1 kΩ) Output accuracy: Within ±6% (Full span)		
<b>Linearity</b>		Within ±1% (Full span)		
<b>Hysteresis</b>		Within 0.5% (Full span)		
<b>Repeatability</b>		Within ±0.5% (Full span)		
<b>Sensitivity</b>		Within 0.2% (Full span)		
<b>Temperature characteristics</b>		Within ±0.12% (Full span)/°C		
<b>Operating temperature range</b>		0 to 50°C (No condensation)		
<b>Enclosure</b>		Equivalent to IP65 *		
<b>Connection type</b>		Built-in One-touch fittings		
<b>Connection size</b>	<b>For single unit</b>	Metric size	①, ②, ③: ø4	
		Inch size	①, ②, ③: ø5/32"	
	<b>Manifold</b>	Metric size	①, ③: ø6, ②: ø4	
		Inch size	①, ③: ø1/4", ②: ø5/32"	
<b>Weight</b> <sup>Note 1)</sup>		100 g or less (without option)		

Note 1) Indicates the weight of a single unit.

For IITV00-n

Total weight (g) Stations (n) x 100 + 130 (Weight of end block A, B assembly) + Weight (g) of DIN rail

Note 2) When there is a downstream flow consumption, pressure may become unstable depending on piping conditions.

Note 3) When the power is turned on, a noise may be generated. This noise is normal and does not indicate a fault.

\* When using under the conditions equivalent to IP65, connect the fitting or tube to the breathing hole prior to use. (For details, refer to "Specific Product Precautions 1" on page 41)


## Accessories (Option)

### Bracket

Flat bracket assembly (includes 2 mounting screws)  
P39800022



L-bracket assembly (includes 2 mounting screws)  
P39800023




Tightening torque when assembling is 0.3 N·m.

### Cable connector

Straight type  
M8-4DSX3MG4




Right angle type  
P398000-501-2




## Working Principle

When the input signal rises, the air supply solenoid valve ① turns ON. Due to this, part of the supply pressure passes through the air supply solenoid valve ① and changes to output pressure. This output pressure feeds back to the control circuit ④ via the pressure sensor ③. Here, pressure corrections continue until output pressure becomes proportional to the input signal, enabling output pressure that is proportional to the input signal.

**Diagram of working principle**




**Block diagram**




**Series ITV001** □

**Linearity, Hysteresis**




**Repeatability**

With 50% of signal input




**Pressure Characteristics**

Set pressure: 0.05 MPa




**Flow Characteristics**

Supply pressure: 0.2 MPa




**Series ITV003** □

**Linearity, Hysteresis**




**Repeatability**

With 50% of signal input




**Pressure Characteristics**

Set pressure: 0.25 MPa



**Flow Characteristics**


Supply pressure: 0.6 MPa



# Series ITV0000


## Series ITV005

### Linearity, Hysteresis




### Repeatability

With 50% of signal input




### Pressure Characteristics

Set pressure: 0.45 MPa



### Flow Characteristics



Supply pressure: 1.0 MPa





## Dimensions


### For Single Unit



# Series ITV0000

## Dimensions



### Single unit for manifold




Note) For dimensions of the cable connector, refer to single unit on page 6.

## Dimensions

### Manifold




Note) When using under the conditions equivalent to IP65, connect the fittings or tubing to the breathing hole prior to use. (For details, refer to "Specific Product Precautions 1" on page 41).



#### Port Location

No.	1	2	3
ITV003	SUP	OUT	EXH
5			

Note) Stations are counted starting from the D side.



Note) For dimensions of the cable connector, refer to single unit on page 6.

	[mm]									
Manifold stations n	2	3	4	5	6	7	8	9	10	
L1	60	75	90	105	120	135	150	165	180	
L2	110.5	123	148	160.5	173	185.5	198	223	235.5	
Weight of DIN rail [g]	20	22	27	29	31	34	36	41	43	

# Electro-Pneumatic Regulator

## Series *ITV1000/2000/3000*



### How to Order

ITV **3** **0** **1** **0** - **0** **1** **F** **2** **S** -

**Model**

1	1000 type
2	2000 type
3	3000 type

**Pressure range**

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa

**Power supply voltage**

0	24 VDC
1	12 to 15 VDC

Note) Communication models (CC, DE, PR, RC) 16 points preset input and 10 bit digital input are available only for 24 VDC.

**Input signal/**

**Communication model**

0	Current type 4 to 20 mA DC (Sink type)
1	Current type 0 to 20 mA DC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC
40	4 points preset input
52	16 points preset input (Switch output/NPN output)
53	16 points preset input (Switch output/PNP output)
60	10 bit digital input
CC	CC-Link
DE	DeviceNet™
PR	PROFIBUS DP
RC	RS-232C communication

**Monitor output**

1	Analogue output 1 to 5 VDC
2	Switch output/NPN output
3	Switch output/PNP output
4	Analogue output 4 to 20 mA DC (Sink type/+COM type) <sup>Note 1)</sup>
—	None

Note) For -COM type, see page 25 for details.

**Thread type**

—	Rc
N	NPT
T	NPTF
F	G

• **Made to Order Specifications**  
Refer to pages 11, 25, 26 and 27 for details.

• **Pressure display unit**

—	MPa
2	kgf/cm <sup>2</sup>
3	bar
4	psi
5	kPa

Note) For the communication models, CC, DE, PR and RC, only “—” is available as it does not have a pressure display.

• **Cable connector type**

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector

Note) Order communication cable (other than RS-232C) separately. See below.

• **Bracket**

—	Without bracket
B	Flat bracket
C	L-bracket


• **Port size**

1	1/8 (1000 type)
2	1/4 (1000, 2000, 3000 type)
3	3/8 (2000, 3000 type)
4	1/2 (3000 type)


For communication cables, use the parts listed below (refer to the catalogue [M8/M12 Connector] CAT.ES100-73 for details) or order the product certified for the respective protocol (with M12 connector) separately.

Application	Communication cable part number	Remarks
CC-Link compatibility	PCA-1567720 (Socket type)	Dedicated Bus adapter supplied with the product.
	PCA-1567717 (Plug type)	
DeviceNet™ compatibility	PCA-1557633 (Socket type)	T-branch connector not supplied.
	PCA-1557646 (Plug type)	
PROFIBUS DP compatibility	PCA-1557688 (Socket type)	T-branch connector not supplied.
	PCA-1557691 (Plug type)	

# Electro-Pneumatic Regulator *Series ITV1000/2000/3000*



## JIS Symbol



Rated pressure




Figure 1. Input/output characteristics chart

## Communication Specifications (CC, DE, PR, RC)

Model	ITV□□□0-CC	ITV□□□0-DE	ITV□□□0-PR	ITV□□□0-RC
<b>Protocol</b>	CC-Link	DeviceNet™	PROFIBUS DP	RS-232C
<b>Version</b> <sup>Note 1)</sup>	Ver 1.10	Volume 1 (Edition 3.8), Volume 3 (edition 1.5)	DP-V0	—
<b>Communication speed</b>	156 k/625 k 2.5 M/5 M/10 M bps	125 k/250 k/500 k bps	9.6 k/19.2 k/45.45 k 93.75 k/187.5 k/500 k 1.5 M/3 M/6 M/12 M bps	9.6 kbps
<b>Configuration file</b> <sup>Note 2)</sup>	—	EDS	GSD	—
<b>I/O occupation area (input/output data)</b>	4 word/4 word, 32 bit/32 bit (per station, remote device station)	16 bit/16 bit	16 bit/16 bit	—
<b>Communication data resolution</b>	12 bit (4096 resolution)	12 bit (4096 resolution)	12 bit (4096 resolution)	10 bit (1024 resolution)
<b>Fail safe</b>	HOLD <sup>Note 3)</sup> /CLEAR (Switch setting)	HOLD/CLEAR (Switch setting)	CLEAR	HOLD
<b>Electric insulation</b> <sup>Note 4)</sup>	No	No	Yes	No
<b>Terminating resistor</b>	—	—	Built into the product (Switch setting)	—

Note 1) Note that version information is subject to change.

Note 2) Configuration files can be downloaded from the SMC's website: <http://www.smcworld.com>

Note 3) The output HOLD value when a CC-Link communications error occurs can be set based on the bit area data.

Note 4) The insulation between the electrical signal of the communication system and ITV power supply.

## Standard Specifications

Model	ITV101□ <sup>Note 10)</sup>	ITV103□ <sup>Note 10)</sup>	ITV105□ <sup>Note 10)</sup>
	ITV201□	ITV203□	ITV205□
	ITV301□	ITV303□	ITV305□
<b>Minimum supply pressure</b>	Set pressure +0.1 MPa		
<b>Maximum supply pressure</b>	0.2 MPa	1.0 MPa	
<b>Set pressure range</b> <sup>Note 1)</sup>	0.005 to 0.1 MPa	0.005 to 0.5 MPa	0.005 to 0.9 MPa
<b>Power supply</b>	<b>Voltage</b>	24 VDC ±10%, 12 to 15 VDC	
	<b>Current consumption</b>	Power supply voltage 24 VDC type: 0.12 A or less <sup>Note 8)</sup> Power supply voltage 12 to 15 VDC type: 0.18 A or less	
<b>Input signal</b>	<b>Current type</b> <sup>Note 2)</sup>	4 to 20 mA DC, 0 to 20 mA DC (Sink type)	
	<b>Voltage type</b>	0 to 5 VDC, 0 to 10 VDC	
	<b>Preset input</b>	4 points (Negative common), 16 points (No common polarity)	
<b>Input impedance</b>	<b>Digital input</b>	10 bit (parallel)	
	<b>Current type</b>	250 Ω or less <sup>Note 6)</sup>	
	<b>Voltage type</b>	Approx. 6.5 kΩ	
<b>Output signal (monitor output)</b> <sup>Note 3)</sup>	<b>Preset input</b>	Power supply voltage 24 VDC type: Approx. 4.7 kΩ; Power supply voltage 12 VDC type: Approx. 2.0 kΩ	
	<b>Digital input</b>	Approx. 4.7 kΩ	
	<b>Analogue output</b>	1 to 5 VDC (Output impedance: Approximately 1 kΩ) 4 to 20 mA DC (Sink type) (Load impedance: 250Ω or less) Output accuracy within ±6% (Full span)	
<b>Switch output</b>	NPN open collector output: Max. 30 V, 80 mA PNP open collector output: Max. 80 mA		
<b>Linearity</b>	Within ±1% (Full span)		
<b>Hysteresis</b>	Within 0.5% (Full span)		
<b>Repeatability</b>	Within ±0.5% (Full span)		
<b>Sensitivity</b>	Within 0.2% (Full span)		
<b>Temperature characteristics</b>	Within ±0.12% (Full span)/°C		
<b>Output pressure display</b> <sup>Note 4)</sup>	<b>Accuracy</b>	±2%F.S. ±1 digit	
	<b>Minimum unit</b>	MPa: 0.001, kgf/cm <sup>2</sup> : 0.01, bar: 0.01, psi: 0.1 <sup>Note 5)</sup> , kPa: 1	
<b>Ambient and fluid temperature</b>	0 to 50°C (No condensation)		
<b>Enclosure</b>	IP65		
<b>Weight</b> <sup>Note 9)</sup>	ITV10□□	Approx. 250 g (without options)	
	ITV20□□	Approx. 350 g (without options)	
	ITV30□□	Approx. 645 g (without options)	

Note 1) Please refer to Figure 1 for the relationship between set pressure and input. Because the maximum set pressure differs for each pressure display, refer to page 45.

Note 2) 2-wire type 4 to 20 mA DC is not available. Power supply voltage (24 VDC or 12 to 15 VDC) is required.

Note 3) Select either analogue output or switch output.

Further, when switch output is selected, select either NPN output or PNP output.

Note 4) Adjustment of numerical values such as the zero/span adjustment or preset input type is set based on the minimum units for output pressure display (e.g. 0.01 to 0.50 MPa). Note that the unit cannot be changed.

Note 5) The minimum unit for 0.9 MPa (130 psi) types is 1 psi.

Note 6) Value for the state with no over current circuit included. If an allowance is provided for an over current circuit, the input impedance varies depending on the input current. This is 350 Ω or less for an input current of 20 mA DC.

Note 7) The above characteristics are confined to the static state. When air is consumed on the output side, the pressure may fluctuate.

Note 8) For communication models, the maximum current consumption is 0.16 A or less.



Note 9) For communication models, add roughly 80 g to the weight (100 g for the PROFIBUS DP).

Note 10) The ITV1000 series is a Grease-free specification (Wetted parts).

# Series ITV1000/2000/3000

## Modular Products and Accessory Combinations

\* ITV10□□ models are not applicable.



Applicable products and accessories	Applicable model	
	ITV20□□	ITV30□□
① Air filter	AF30-A	AF40-A
② Mist separator	AFM30-A	AFM40-A
③ L-bracket	B310L	B410L
④ Spacer	Y30	Y40
⑤ Spacer with L-bracket (③ + ④)	Y30L	Y40L
⑥ Spacer with T-bracket	—	Y40T

## Accessories (Option)/Part No.

### [Bracket]

Applicable model	Description	Part No.
ITV10□□	Flat bracket assembly (including mounting screws)	P398010-600
ITV20□□, 30□□		P398020-600
ITV10□□	L-bracket assembly (including mounting screws)	P398010-601
ITV20□□, 30□□		P398020-601

### [Cable connector]

Applicable model	Description	Part No.	
Current type Voltage type 4 points preset input	Cable connector (4 cores)	Straight type 3 m	P398020-500-3
		Right angle type 3 m	P398020-501-3
16 points preset input	Power cable (4 cores)	Straight type 3 m	P398020-500-3
		Right angle type 3 m	P398020-501-3
	Signal cable (5 cores)	Straight type 3 m	P398020-502-3
		Right angle type 3 m	P398020-503-3
10 bit digital input	Cable connector (13 cores)	Straight type 3 m	INI-398-0-59
CC-Link PROFIBUS DP DeviceNet™	Power cable (4 cores)	Straight type 3 m	P398020-500-3
		Right angle type 3 m	P398020-501-3
RS-232C	Power cable (4 cores)	Straight type 3 m	P398020-500-3
		Right angle type 3 m	P398020-501-3
	Communication cables connector (5 cores)	Straight type 3 m	P398020-502-3
		Right angle type 3 m	P398020-503-3

Note 1) For the 10-bit digital type, there is no right angle type cable connector.

Note 2) Even when "with cable connector" is selected the communication cable is not included in the communication model (CC, DE, PR). Please order separately.

### [Bus adapter]

Applicable model	Description	Part No.
CC-Link	Bus adapter (Bus adapter supplied with the product.)	EX9-ACY00-MJ



### Made to Order

(Refer to pages 25, 26 and 27 for details.)

Symbol	Specifications
X256	Monitor analogue output 4-20mA (source type/-COM type)
X102	Reverse type
X224	High pressure type (SUP 1.2 MPa, OUT 1.0 MPa)
X25	Set pressure range 1 to 100 kPa (Except Series ITV3000)
X410	Linearity ±0.5% F.S. or less
X420	With alarm output
X88	High speed response type (Except Series ITV3000)
X26	For manifold mounting (Except Series ITV3000)


Note 1) Manifolds are compatible with 2 to 8 stations. Consult with SMC for 9 stations or more.

Note 2) Products without symbols are also compatible. Consult with SMC separately.


Model	Bracket tightening torque
ITV1000	0.76 ± 0.05 N·m
ITV2000/3000	1.5 ± 0.05 N·m

## Dimensions

### Flat bracket



### L-bracket




## Working Principles

When the input signal rises, the air supply solenoid valve ① turns ON, and the exhaust solenoid valve ② turns OFF. Therefore, supply pressure passes through the air supply solenoid valve ① and is applied to the pilot chamber ③. The pressure in the pilot chamber ③ increases and operates on the upper surface of the diaphragm ④.


As a result, the air supply valve ⑤ linked to the diaphragm ④ opens, and a portion of the supply pressure becomes output pressure.

This output pressure feeds back to the control circuit ⑧ via the pressure sensor ⑦. Here, a correct operation functions until the output pressure is proportional to the input signal, making it possible to always obtain output pressure proportional to the input signal.

### Working Principle Diagram




### Block diagram




# Series ITV1000/2000/3000

## Series ITV101


### Linearity




### Hysteresis




### Repeatability




### Pressure characteristics Set pressure: 0.05 MPa



### Flow characteristics Supply pressure: 0.2 MPa




### Relief flow characteristics Supply pressure: 0.2 MPa




## Series ITV201


### Linearity




### Hysteresis




### Repeatability




### Pressure characteristics Set pressure: 0.05 MPa



### Flow characteristics Supply pressure: 0.2 MPa




### Relief flow characteristics Supply pressure: 0.2 MPa






**Series ITV301**


**Linearity**




**Hysteresis**




**Repeatability**




**Pressure characteristics** Set pressure: 0.05 MPa



**Flow characteristics** Supply pressure: 0.2 MPa




**Relief flow characteristics** Supply pressure: 0.2 MPa




# Series ITV1000/2000/3000

## Series ITV103


### Linearity




### Hysteresis




### Repeatability




### Pressure characteristics Set pressure: 0.2 MPa



### Flow characteristics Supply pressure: 0.7 MPa




### Relief flow characteristics Supply pressure: 0.7 MPa




## Series ITV203


### Linearity




### Hysteresis




### Repeatability




### Pressure characteristics Set pressure: 0.2 MPa



### Flow characteristics Supply pressure: 0.7 MPa




### Relief flow characteristics Supply pressure: 0.7 MPa




## Series ITV303


### Linearity




### Hysteresis




### Repeatability




### Pressure characteristics Set pressure: 0.2 MPa



### Flow characteristics Supply pressure: 0.7 MPa




### Relief flow characteristics Supply pressure: 0.7 MPa




# Series ITV1000/2000/3000

## Series ITV105


### Linearity




### Hysteresis




### Repeatability




### Pressure characteristics Set pressure: 0.4 MPa



### Flow characteristics Supply pressure: 1.0 MPa




### Relief flow characteristics Supply pressure: 1.0 MPa




## Series ITV205


### Linearity




### Hysteresis




### Repeatability




### Pressure characteristics Set pressure: 0.4 MPa



### Flow characteristics Supply pressure: 1.0 MPa




### Relief flow characteristics Supply pressure: 1.0 MPa




## Series ITV305


### Linearity




### Hysteresis




### Repeatability




### Pressure characteristics Set pressure: 0.4 MPa



### Flow characteristics Supply pressure: 1.0 MPa





### Relief flow characteristics Supply pressure: 1.0 MPa



# Series ITV1000/2000/3000


## Dimensions

### ITV10□□ Flat bracket




Note) Do not attempt to rotate, as the cable connector does not turn.

### L-bracket




## Dimensions (16 points preset input, 10 bit digital input, CC-Link, DeviceNet™, PROFIBUS DP and RS-232C)


### 16 points preset input



### 10 bit digital input




### CC-Link/ITV10□0-CC




\* Dimensions not shown are same as on page 19.

### DeviceNet™/ITV10□0-DE




\* Dimensions not shown are same as on page 19.

### PROFIBUS DP/ITV10□0-PR



\* Dimensions not shown are same as on page 19.

### RS-232C/ITV10□0-RC




\* Dimensions not shown are same as on page 19.

### With power cable connector

\* ITV10□0-  
52  
53  
CC  
DE  
PR  
RC  
common dimensions

Note) Order communication cable (other than 16 points, RS-232C) separately. (Refer to page 9.)




Note) Do not attempt to rotate, as the cable connector does not turn.

# Series ITV1000/2000/3000

## Dimensions


ITV20□□

Flat bracket



Note) Do not attempt to rotate, as the cable connector does not turn.


L-bracket






## Dimensions (16 points preset input, 10 bit digital input, CC-Link, DeviceNet™, PROFIBUS DP and RS-232C)


### 16 points preset input



### 10 bit digital input




### CC-Link/ITV20□0-CC




\* Dimensions not shown are same as on page 21.

### DeviceNet™/ITV20□0-DE




\* Dimensions not shown are same as on page 21.

### PROFIBUS DP/ITV20□0-PR



\* Dimensions not shown are same as on page 21.

### RS-232C/ITV20□0-RC




\* Dimensions not shown are same as on page 21.

### With power cable connector

\* ITV20□0-  
52  
53  
CC  
DE  
PR  
RC

common dimensions



Note) Order communication cable (other than 16 points, RS-232C) separately. (Refer to page 9.)




Note) Do not attempt to rotate, as the cable connector does not turn.

# Series ITV1000/2000/3000

## Dimensions


### ITV30□□

#### Flat bracket




Note) Do not attempt to rotate, as the cable connector does not turn.

#### L-bracket




## Dimensions (16 points preset input, 10 bit digital input, CC-Link, DeviceNet™, PROFIBUS DP and RS-232C)


### 16 points preset input




### 10 bit digital input



### CC-Link/ITV30-CC




### DeviceNet™/ITV30-DE



\* Dimensions not shown are same as on page 23.


\* Dimensions not shown are same as on page 23.

### PROFIBUS DP/ITV30-PR



\* Dimensions not shown are same as on page 23.

### RS-232C/ITV30-RC




\* Dimensions not shown are same as on page 23.

### With power cable connector

\* **ITV30-CC-DE-PR-RC** common dimensions

Note) Order communication cable (other than 16 points, RS-232C) separately. (Refer to page 9.)



Note) Do not attempt to rotate, as the cable connector does not turn.

# Series ITV1000/2000/3000

## Made to Order Specifications 1

Please contact SMC for detailed dimensions, specifications and lead times.



### 1 Monitor Analogue output 4-20mA (source type/-COM)

ITV10   -  4       -  X256

ITV20   -  4       -  X256

ITV30   -  4       -  X256

Note 1)  in part number is the same model no. for the standard products.

### 4 Set Pressure Range 1 to 100 kPa

ITV10  1   -         -  X25

ITV20  1   -         -  X25

Set pressure range 1 to 100 kPa ●

Note) For preset input type, digital input type and communication models, consult SMC for availability.


### 2 Reverse Type

In compliance with input, inverse proportional pressure is displayed.

ITV10   -         -  X102

ITV20   -         -  X102

ITV30   -         -  X102



Input/output characteristics chart

Note 1)  in part number is the same model no. for the standard products.  
 Note 2) Except for preset input type and digital input type.  
 Note 3) For communication models, consult SMC for availability.

### 3 High Pressure Type (SUP 1.2 MPa, OUT 1.0 MPa)

ITV10  5   -         -  X224

ITV20  5   -         -  X224

ITV30  5   -         -  X224

High pressure type (SUP 1.2 MPa, OUT 1.0 MPa) ●

Note) For preset input type, digital input type and communication models, consult SMC for availability.


# Series ITV1000/2000/3000

## Made to Order Specifications 2

Please contact SMC for detailed dimensions, specifications and lead times.




### 5 Linearity: ±0.5% F.S. or less



### 6 With Alarm Output

Alarm is output if the set pressure is not reached or maintained for 5 seconds or more.



# Made to Order Specifications 3

Please contact SMC for detailed dimensions, specifications and lead times.



## 7 High-Speed Response Time Type

Pressure response with no load is approx. 0.1 sec.

**ITV 2 0 1 0 - 0 1 [ ] 2 [ ] S [ ] - X88**

**Model**

1	1000 type
2	2000 type

**Pressure range**

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa

**Power supply voltage**

0	24 VDC
1	12 to 15 VDC

**Input signal**

0	Current type 4 to 20 mA DC (Sink type)
1	Current type 0 to 20 mA DC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC

**Monitor output**

1	Analogue output 1 to 5 VDC
2	Switch output/NPN output
3	Switch output/PNP output
4	Analogue output 4 to 20 mA DC (sink type)

**Thread type**

—	Rc
N	NPT
T	NPTF
F	G

**Pressure display unit**

—	MPa
2*	kgf/cm <sup>2</sup>
3	bar
4*	psi
5	kPa

\* Under Japan's new Measurement Act, this is only for overseas sales (SI units are to be used inside Japan).

**Cable connector type**

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector

**Bracket**

—	Without bracket
B	Flat bracket
C	L-bracket

**Port size**

1	1/8 (1000 type)
2	1/4 (1000, 2000 type)
3	3/8 (2000 type)

## 8 Manifold Specifications (Except Series ITV3000)

2 through 8 station manifold.

### How to Order Manifolds

**IITV20 - [ ] 02 - 5**

**ITV1000, 2000**

**Connection thread type**

—	Rc
N	NPT
F	NPTF

**Stations**

2	2 stations
...	...
8	8 stations

**OUT port size**

02	1/4
03	3/8

### How to Order Manifold Mounted

ITV 1 0 [ ] [ ] - [ ] [ ] 1 [ ] [ ] - X26  
 ITV 2 0 [ ] [ ] - [ ] [ ] 2 [ ] [ ] - X26

- Note 1) [ ] in part number is the same model no. for the standard products.
- Note 2) For communication models, consult SMC for availability.
- Note 3) The thread type is Rc only.
- Note 4) For Series ITV1000, the port size is 1/8 only.
- Note 5) For Series ITV2000, the port size is 1/4 only.
- Note 6) The bracket accessory can not be selected.
- Note 7) Not applicable to Series ITV3000

IITV20-02-3 .....1 set (3 station manifold base part no.)  
 \*ITV1030-311S-X26 .....1 set (Electro-pneumatic regulator part no.) Note 2)  
 \*P398020-13 .....1 set (Blanking plate assembly part no.)  
 \*ITV2050-212S-X26 .....1 set (Electro-pneumatic regulator part no.) Note 2)


→ The \* is the symbol for mounting. Add the \* symbol at the beginning of part numbers for electro-pneumatic regulators, etc. to be mounted on the base.

Note) Refer to the table below for possible mixed combination.

Model	ITV101[ ]	ITV103[ ]	ITV105[ ]	ITV201[ ]	ITV203[ ]	ITV205[ ]
ITV101[ ]	●	—	—	●	—	—
ITV103[ ]	—	●	●	—	●	●
ITV105[ ]	—	●	●	—	●	●
ITV201[ ]	●	—	—	●	—	—
ITV203[ ]	—	●	●	—	●	●
ITV205[ ]	—	●	●	—	●	●

### How to Order Manifold Assemblies

#### Example



- Note 1) Electro-pneumatic regulators are counted starting from station 1 on the left side with the OUT ports in front.
- Note 2) The port size for mounted electro-pneumatic regulators is Rc 1/8 (ITV1000), Rc 1/4 (ITV2000) only.
- Note 3) When there is a large number of stations, use piping with the largest possible inside diameter for the supply side, such as steel piping.
- Note 4) The use of the straight type cable connector is recommended. To mount right angle type, be certain to check that no possible interference occurs.
- Note 5) When mounting a blanking plate and the regulator with different pressure set, please inform SMC of the order of a manifold station beside a purchase order.

# Compact Vacuum Regulator Series *ITV009*



## How to Order

For single unit and single unit for manifold

**ITV009 0 - 3** [ ] [ ] [ ] **N**

● **Pressure range**

9	-100 kPa
---	----------

● **Power supply voltage**

0	24 VDC ±10%
1	12 to 15 VDC

● **Input signal**

0	Current type 4 to 20 mA DC
1	Current type 0 to 20 mA DC
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC

● **Cable connector (Option)**

N	Without cable connector
S	Straight type 3 m
L	Right angle type 2 m

● **Bracket/Option for single unit only**

—	Without bracket	
B	Flat Bracket	
C	L-bracket	

● **Built-in One-touch fittings type**  
For single unit

Symbol	VAC <sup>1</sup>	OUT <sup>2</sup>	ATM <sup>3</sup>
—	Metric size (Light grey)	ø4	
U	Inch size (Orange)	ø5/32"	

For manifold

Symbol	VAC <sup>1</sup>	OUT <sup>2</sup>	ATM <sup>3</sup>	
—	Metric size (Light grey)	ø6	ø4	ø6
U	Inch size (Orange)	ø1/4"	ø5/32"	ø1/4"

● **Base type**

—	For single unit
M	For manifolds

## Manifold

**IITV00 - 02** [ ] - **n**

● **Stations**

02	2 stations
03	3 stations
⋮	⋮
10	10 stations

● **Option**  
If a DIN rail longer than the specified stations is required, specify the applicable stations in two digits.  
(Maximum 10 stations)  
Example) **IITV00-05-07**

● **One-touch fitting size for supply/exhaust parts (incl. plate)**

—	ø6 (light grey)
U	ø1/4" (orange)

Note) A DIN rail with the length specified by the number of stations is attached to the manifold. For dimensions of the DIN rail, refer to the external dimensions.

## How to Order Manifold Assembly (Example)

Indicate the part numbers of electro-pneumatic regulators and options to be mounted below the manifold part number.

Example)

Due to the common supply/exhaust feature, note that different pressure range combinations are not available.

**IITV00-03.....1 set (Manifold part no.)**


\*ITV0090-3MS.....2 sets (Vacuum regulator part no. (1, 2 stations))


\*ITV0090-3ML.....1 set (Vacuum regulator part no. (3 stations))

Indicate part numbers in order starting from the first station on the D side.

Note) Combination with having different pressure ranges is not available due to common supply/exhaust features.

The asterisk (\*) specifies mounting. Add an asterisk (\*) at the beginning of electro-pneumatic regulator part numbers to be mounted.





## Specifications

Model		ITV009 <input type="checkbox"/>	
Minimum supply pressure		Set pressure -1 kPa	
Maximum supply pressure		-101 kPa	
Set pressure range		-1 to -100 kPa	
Maximum flow rate		2 l/min (ANR) (Supply pressure: -101 kPa)	
Power supply	Voltage	24 VDC ±10%, 12 to 15 VDC	
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less Power supply voltage 12 to 15 VDC type: 0.18 A or less	
Input signal	Voltage type	0 to 5 VDC, 0 to 10 VDC	
	Current type	4 to 20 mA DC, 0 to 20 mA DC	
Input impedance	Voltage type	Approximately 10 kΩ	
	Current type	Approximately 250 Ω	
Output signal	Analogue output	1 to 5 VDC (Output impedance: Approximately 1 kΩ) Output accuracy: Within ±6% (Full span)	
Linearity		Within ±1% (Full span)	
Hysteresis		Within 0.5% (Full span)	
Repeatability		Within ±0.5% (Full span)	
Sensitivity		Within 0.2% (Full span)	
Temperature characteristics		Within ±0.12% (Full span)/°C	
Operating temperature range		0 to 50°C (No condensation)	
Enclosure		IP65 equivalent *	
Connection type		Built-in One-touch fittings	
Connection size	For single unit	Metric size	<input type="checkbox"/> 1, <input type="checkbox"/> 2, <input type="checkbox"/> 3: ø4
		Inch size	<input type="checkbox"/> 1, <input type="checkbox"/> 2, <input type="checkbox"/> 3: ø5/32"
	Manifold	Metric size	<input type="checkbox"/> 1, <input type="checkbox"/> 3: ø6, <input type="checkbox"/> 2: ø4
		Inch size	<input type="checkbox"/> 1, <input type="checkbox"/> 3: ø1/4", <input type="checkbox"/> 2: ø5/32"
Weight <sup>Note 1)</sup>		100 g or less (without option)	

Note 1) Indicates the weight of a single unit.

For IITV00-n

Total weight (g) Stations (n) x 100 + 130 (Weight of end block A, B assembly) + Weight (g) of DIN rail

Note 2) When there is a downstream flow consumption, pressure may become unstable depending on piping conditions.

\* When using under the conditions equivalent to IP65, connect the fitting or tube to the breathing hole prior to use. (For details, refer to "Specific Product Precautions 1" on page 41)


## Accessories (Option)

### Bracket

Flat bracket assembly (including 2 mounting screws)  
P39800022



L-bracket assembly (including 2 mounting screws)  
P39800023




Tightening torque when assembling is 0.3 N·m.

### Cable connector

Straight type  
M8-4DSX3MG4



Right angle type  
P398000-501-2







## Working Principle

When the input signal rises, the air supply solenoid valve ① turns ON. Due to this, part of the supply pressure passes through the air supply solenoid valve ① and changes to output pressure. This output pressure feeds back to the control circuit ④ via the pressure sensor ③. Here, pressure corrections continue until output pressure becomes proportional to the input signal, enabling output pressure that is proportional to the input signal.

### Diagram of working principle




### Block diagram




## Series ITV009

### Linearity, Hysteresis




### Repeatability

With 50% of signal input




### Pressure Characteristics

Set pressure: -10 kPa








### Flow Characteristics




## Dimensions

### For Single Unit



## Dimensions


### Single unit for manifold





Note) For dimensions of the cable connector, refer to single unit on page 32.

## Dimensions

### Manifold




Note) When using under the conditions equivalent to IP65, connect the fittings or tubing to the breathing hole prior to use.  
(For details, refer to "Specific Product Precautions 1" on page 41)



#### Port Location

No.	1	2	3
<b>ITV009</b> <span style="border: 1px solid black; padding: 0 2px;"> </span>	VAC	OUT	ATM

Note) Stations are counted starting from the D side.



Note) For dimensions of the cable connector, refer to single unit on page 32.

	[mm]									
Manifold stations n	2	3	4	5	6	7	8	9	10	
<b>L1</b>	60	75	90	105	120	135	150	165	180	
<b>L2</b>	110.5	123	148	160.5	173	185.5	198	223	235.5	
Weight of DIN rail [g]	20	22	27	29	31	34	36	41	43	

# Electronic Vacuum Regulator

## Series *ITV2090/2091*



### How to Order

ITV 209 0 - 0 1 F 2 □ S 5

● **Pressure range**

9	-1.3 to -80 kPa
---	-----------------

● **Power supply voltage**

0	24 VDC
1	12 to 15 VDC

Note) Communication models (CC, DE, PR, CR), 16 points preset input and 10 bit digital input are available only for 24 VDC.

● **Pressure display unit**

—	None
5	kPa

Note) For the communication models, CC, DE, PR and RC, only "—" is available as it does not have a pressure display.

● **Cable connector type**

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector

Note) Order communication cable (other than RS-232C) separately. See below.

● **Input signal/  
Communication model**

0	Current type 4 to 20 mA DC (Sink type)
1	Current type 0 to 20 mA DC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC
40	4 points preset input
52	16 points preset input (Switch output/NPN output)
53	16 points preset input (Switch output/PNP output)
60	10 bit digital input
CC	CC-Link
DE	DeviceNet™
PR	PROFIBUS DP
RC	RS-232C communication

● **Monitor output**

1	Analogue output 1 to 5 VDC
2	Switch output/NPN output
3	Switch output/PNP output
4	Analogue output 4 to 20 mA DC (Sink type)
—	None

● **Bracket**

—	Without bracket
B	Flat bracket
C	L-bracket

● **Port size**

2	1/4
---	-----

● **Thread type**

—	Rc
N	NPT
T	NPTF
F	G


For communications cables, use the parts listed below (refer to the catalogue [M8/M12 Connector] CAT.ES100-73 for details) or order the product certified for the respective protocol (with M12 connector) separately.

Application	Communication cable part number	Remarks
CC-Link compatibility	PCA-1567720 (Socket type)	Dedicated Bus adapter supplied with the product.
	PCA-1567717 (Plug type)	
DeviceNet™ compatibility	PCA-1557633 (Socket type)	T-branch connector not supplied.
	PCA-1557646 (Plug type)	
PROFIBUS DP compatibility	PCA-1557688 (Socket type)	T-branch connector not supplied.
	PCA-1557691 (Plug type)	

Stepless control of vacuum pressure in proportion to an electrical signal



## Piping/Wiring Diagram



## Standard Specifications

Model		ITV2090	ITV2091
Power supply	Voltage	24 VDC 10%	12 to 15 VDC
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less <sup>Note 6)</sup> Power supply voltage 12 to 15 VDC type: 0.18 A or less	
Minimum supply vacuum pressure <sup>Note 1)</sup>		Set pressure -13.3 kPa	
Maximum supply vacuum pressure		-101 kPa	
Set pressure range		-1.3 to -80 kPa	
Input signal	Current type <sup>Note 2)</sup>	4 to 20 mA DC, 0 to 20 mA DC	
	Voltage type	0 to 5 VDC, 0 to 10 VDC	
	Preset input	4 points (Negative common), 16 points (No common polarity)	
	Digital input	10 bit (parallel)	
Input impedance	Current type	250 Ω or less <sup>Note 3)</sup>	
	Voltage type	Approximately 6.5 kΩ	
	Preset input	Power supply voltage 24 VDC type: Approximately 4.7 kΩ Power supply voltage 12 VDC type: Approximately 2.0 kΩ	
	Digital input	Approx. 4.7 kΩ	
Output signal (Monitor output) <sup>Note 4)</sup>	Analogue output	1 to 5 VDC (Output impedance: Approximately 1 kΩ) 4 to 20 mA DC (Sink type) (Load impedance: 250 Ω or less) Output accuracy within ±6% (Full span)	
	Switch output	NPN open collector output: Max. 30 V, 80 mA PNP open collector output: Max. 80 mA	
Linearity		Within ±1% (Full span)	
Hysteresis		Within 0.5% (Full span)	
Repeatability		Within ±0.5% (Full span)	
Sensitivity		Within 0.2% (Full span)	
Temperature characteristics		Within ±0.12% (Full span)/°C	
Output pressure display	Accuracy	±2% F.S. ±1 digit	
	Units	kPa <sup>Note 5)</sup> Minimum display: 1	
Ambient and fluid temperature		0 to 50°C (No condensation)	
Enclosure		IP65	
Weight <sup>Note 7)</sup>		350 g	

Note 1) The minimum supply vacuum pressure should be 13.3 kPa less than the maximum vacuum pressure setting value.

Note 2) 4 to 20 mA DC is not possible with the 2-wire type. Power supply voltage (24 VDC or 12 to 15 VDC) is required.

Note 3) Value for the state with no over current circuit included. If an allowance is provided for an over current circuit, the input impedance varies depending on the input power supply. This is 350 Ω or less for an input current of 20 mA DC.

Note 4) When measuring ITV analogue output from 1 to 5 VDC, if the load impedance is less than 100 kΩ, the analogue output monitor accuracy of within ±6% (full span) may not be available. The product with the accuracy of within ±6% is supplied upon your request. Output pressure remains unaffected.

Note 5) Please contact SMC regarding indication with other units of pressure.

Note 6) For communication models, the maximum current consumption is 0.16 A or less.

Note 7) For communication models, add roughly 80 g to the weight (100 g for the PROFIBUS DP).

## Communication Specifications (CC, DE, PR, RC)


Model	ITV□0□0-CC□□	ITV□0□0-DE□□	ITV□0□0-PR□□	ITV□0□0-RC□□
Protocol	CC-Link	DeviceNet™	PROFIBUS DP	RS-232C
Version <sup>Note 1)</sup>	Ver 1.10	Volume 1 (Edition 3.8), Volume 3 (edition 1.5)	DP-V0	—
Communication speed	156 k/625 k 2.5 M/5 M/10 M bps	125 k/250 k/500 k bps	9.6 k/19.2 k/45.45 k 93.75 k/187.5 k/500 k 1.5 M/3 M/6 M/12 M bps	9.6 kbps
Configurion file <sup>Note 2)</sup>	—	EDS	GSD	—
I/O occupation area (input/output data)	4 word/4 word, 32 bit/32 bit (per station, remote device station)	16 bit/16 bit	16 bit/16 bit	—
Communication data resolution	12 bit (4096 resolution)	12 bit (4096 resolution)	12 bit (4096 resolution)	10 bit (1024 resolution)
Fail safe	HOLD <sup>Note 3)</sup> /CLEAR (Switch setting)	HOLD/CLEAR (Switch setting)	CLEAR	HOLD
Terminating resistor	—	—	Built into the product (Switch setting)	—

Note 1) Note that version information is subject to change.

Note 2) Configuration files can be downloaded from the SMC's website: <http://www.smcworld.com>

Note 3) The output HOLD value when a CC-Link communications error occurs can be set based on the bit area data.


## Working Principle



## Working Principle


When the input signal increases, the vacuum pressure solenoid valve ① turns ON, and the atmospheric pressure solenoid valve ② turns OFF. Because of this, VAC. and the pilot chamber ③ are connected, the pressure in the pilot chamber ③ becomes negative and acts on the top of the diaphragm ④. As a result, the vacuum pressure valve ⑤ which is linked to the diaphragm ④ opens, VAC. and OUT. are connected, and the set pressure becomes negative. This negative pressure feeds back to the control circuit ⑧ via the pressure sensor ⑦. Then, a correct operation works until a vacuum pressure proportional to the input signal is reached, and a vacuum pressure is obtained which is always proportional to the input signal.

## Block Diagram




## Series ITV209


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: -20 kPa



### Flow Characteristics

Supply vacuum pressure: -100 kPa



### Flow characteristics measurement conditions


- Exhaust flow rate of the vacuum pump used for measurement: 500 l/min (ANR)
- Inlet vacuum pressure: -100 kPa (When outlet flow rate is 0 l/min (ANR))
- Maximum flow rate: 132 l/min (ANR) (With inlet vacuum pressure at -39 kPa)



**Dimensions**


**ITV209** □

**Flat bracket**




Note) Do not attempt to rotate the cable connector, as it does not turn.

**L-bracket**




## Dimensions (16 points preset input, 10 bit digital input, CC-Link, DeviceNet™, PROFIBUS DP and RS-232C)


### 16 points preset input



### 10 bit digital input




### CC-Link/ITV2090-CC




\* Dimensions not shown are same as on page 38.

### DeviceNet™/ITV2090-DE




\* Dimensions not shown are same as on page 38.

### PROFIBUS DP/ITV2090-PR



\* Dimensions not shown are same as on page 38.


### RS-232C/ITV2090-RC



\* Dimensions not shown are same as on page 38.

### With power cable connector

\* ITV2090-  
52  
53  
CC  
DE  
PR  
RC  
common dimensions



Note) Order communication cable (other than 16 points, RS-232C) separately. (Refer to page 19.)

Note) Do not attempt to rotate the cable connector, as it does not turn.

## Accessories (Option)/Part No.

### [Bracket]

Description	Part No.
Flat bracket assembly (including mounting screws)	P398020-600
L-bracket assembly (including mounting screws)	P398020-601

### [Cable connector]

Applicable model	Description	Part No.	
Current type Voltage type 4 points preset input	Cable connector (4 cores)	Straight type 3 m	P398020-500-3
		Right angle type 3 m	P398020-501-3
16 points preset input	Power cable (4 cores)	Straight type 3 m	P398020-500-3
		Right angle type 3 m	P398020-501-3
	Signal cable (5 cores)	Straight type 3 m	P398020-502-3
		Right angle type 3 m	P398020-503-3
10 bit digital input	Cable connector (13 cores)	Straight type 3 m	INI-398-0-59
CC-Link PROFIBUS DP DeviceNet™	Power cable (4 cores)	Straight type 3 m	P398020-500-3
		Right angle type 3 m	P398020-501-3
RS-232C	Power cable (4 cores)	Straight type 3 m	P398020-500-3
		Right angle type 3 m	P398020-501-3
	Communication cables connector (5 cores)	Straight type 3 m	P398020-502-3
		Right angle type 3 m	P398020-503-3

Note 1) For the 10-bit digital type, there is no right angle type cable connector.


Note 2) Even when "with cable connector" is selected the communication cable is not included in the communication model (CC, DE, PR). Please order separately.

### [Bus adapter]


Applicable model	Description	Part No.
CC-Link	Bus adapter (Bus adapter supplied with the product.)	EX9-ACY00-MJ

## Dimensions

### Flat bracket



### L-bracket



Model	Bracket tightening torque
ITV1000	0.76 ± 0.05N·m
ITV2000/3000	1.5 ± 0.05N·m



# Series ITV0000/1000/2000/3000 Specific Product Precautions 1

Be sure to read before handling. Refer to back page for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

## Series ITV0000/009 Precautions

### Air Supply

#### ⚠ Caution

1. Install an air filter near this product on the supply side. Select a filtration degree of 5 μm or less.
2. Compressed air containing large amounts of drainage can cause malfunction of this product and other pneumatic equipment. As a countermeasure, install an aftercooler, air dryer or Drain Catch, etc.
3. If large amounts of carbon dust are generated by the compressor, it can accumulate inside this product and cause malfunction.


For details on the above compressed air quality, refer to SMC's "Air Preparation Systems".

### Wiring


#### ⚠ Caution

Connect the cable to the connector on the body with the wiring arranged as shown below. Proceed carefully, as incorrect wiring can cause damage.

Further, use DC power with sufficient capacity and a low ripple.




Terminal No.	1	2	3	4
Lead wire colour	Brown	White	Blue	Black
Wiring	Power	Signal	COM	Monitor



Note) A right angle type cable is also available. The entry direction for the right angle type connector is to downwards (SUP port side). Never turn the connector as it is not designed to turn. Using force to turn the connector will damage the connector coupling.


### Wiring Diagrams

#### Current signal type



Vs: Power Supply 24 VDC ±10%  
12 to 15 VDC  
A : Input signals 4 to 20 mA DC  
0 to 20 mA DC


#### Voltage signal type



Vs : Power Supply 24 VDC ±10%  
12 to 15 VDC  
Vin: Input signals 0 to 5 VDC  
0 to 10 VDC

### Monitor output wiring diagram

#### Analogue output, voltage type



### Handling

#### ⚠ Caution

1. Do not use a lubricator on the supply side of this product, as this can cause malfunction. When lubrication of terminal equipment is necessary, connect a lubricator on the output side of this equipment.
2. If electric power is shut off while pressure is being applied, pressure will be retained on the output side.  
However, this output pressure is held only temporarily and is not guaranteed. If exhausting of this pressure is desired, shut off the power after reducing the set pressure, and discharge the air using a residual pressure exhaust valve, etc.
3. If power to this product is cut off due to a power failure, etc. when it is in a controlled state, output pressure will be retained temporarily. Handle carefully when operating with output pressure released to the atmosphere, as air will continue to flow out.
4. If supply pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and a humming noise may be generated.  
Since the life of the product may be shortened, shut off the power supply also when supply pressure is shut off.
5. This product is adjusted for each specification at the time of shipment from the factory. Avoid careless disassembly or removal of parts, as this can lead to malfunction.
6. The optional cable connector is a 4 wire type. When the monitor output ( output or switch output) is not being used, keep it from touching the other wires as this can cause malfunction.
7. Please note that the right angle cable does not rotate and is limited to only one entry direction.

8. Take the following steps to avoid malfunction due to noise.
  - 1) Remove power supply noise during operation by installing a line filter, etc. in the AC power line.
  - 2) For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors and power lines, etc.
  - 3) Be sure to implement protective measures against load surge for induction loads (solenoid valves, relays, etc.).
9. The product characteristics are confined to the static state. When air is consumed on the output side, and especially used in the system with large leakage, pressure cannot approach the set pressure and the service life is drastically shortened with a humming noise of the solenoid valve.

10. For details on the handling of this product, refer to the instruction manual which is included with the product.

11. In locations where the body is exposed to water, dust, etc., there is a possibility that moisture or dust could enter the body through the breathing hole.

Mount a fitting and tube (M-3AU-3 fitting and TIU01m-mm tube recommended) onto the breathing hole and run the tube to a location not exposed to moisture or dust, etc.

Breathing hole  
M3 x 0.5

12. If this product will be used in a sealed environment, such as inside an inspection box, a ventilation fan should be installed to ensure adequate ventilation as this product can generate heat in some operating conditions.  
When the power is turned on, a noise may be generated as a means of checking the operating condition of the solenoid valve. This noise is normal and does not indicate a fault.



# Series ITV0000/1000/2000/3000 Specific Product Precautions 2

Be sure to read before handling. Refer to back page for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

## Series ITV1000/2000/3000/209 □ Precautions

### Piping


#### Warning

1. Screw piping together with the recommended proper torque while holding the side that has female threads.

Looseness or faulty sealing will occur if tightening torque is insufficient, while thread damage will result if the torque is excessive. Furthermore, if the side with the female threads is not held while tightening, excessive force will be applied directly to piping brackets, etc. causing damage or other problems.


Recommended proper torque: N · m

Connection thread	1/8	1/4	3/8	1/2
Torque	3 to 5	8 to 12	15 to 20	20 to 25



2. Do not allow twisting or bending moment to be applied other than the weight of the equipment itself.

Provide separate support for external piping, as damage may otherwise occur.



3. Since excessive moment loads and the propagation of vibrations, etc. can easily result from inflexible piping made of materials such as steel, avoid these problems by using flexible tubing for intermediate connections.

#### Caution


1. Preparation before piping

Before piping is connected, it should be thoroughly blown out with air (flushing) or washed to remove chips, cutting oil and other debris from inside the pipe.

2. Wrapping of pipe tape

When screwing together pipes and fittings, etc., be certain that chips from the pipe threads and sealing material do not get inside the piping.

Also, when pipe tape is used, leave 1.5 to 2 thread ridges exposed at the end of the threads.



### Operating Environment

#### Warning

1. Do not operate in locations having an atmosphere of corrosive gases, chemicals, sea water, or where there will be contact with the same.
2. Do not operate in locations where vibration or impact occurs.

#### Caution

1. In locations where the body is exposed to water, steam, dust, etc., there is a possibility that moisture or dust could enter the body through the EXH (solenoid) ports, thereby causing problems.
2. To overcome this, simply install tubing to each port, using the fittings, and extend the tubing so that the other end is at a location where no water splash, etc. occurs. Make sure not to bend, or block the I.D. of the tubing as this will have a detrimental affect on the pressure control.
3. Do not operate in locations where vibration or impact occurs.
4. In locations which receive direct sunlight, provide a protective cover, etc.
5. In locations near heat sources, block off any radiated heat.
6. In locations where there is contact with spatter from water, oil or solder etc., implement suitable protective measures.

### Air Supply

#### Warning

1. Employ suitable protective measures in locations where there is contact with water droplets, oil or welding spatter, etc.
2. Consult with SMC when used in power plants, or if instrumentation related.

#### Caution

1. Install an air filter near this product on the supply side. Select a filtration degree of 5 μm or less.
2. Compressed air containing large amounts of drainage can cause malfunction of this product and other pneumatic equipment. As a countermeasure, install an aftercooler, air dryer or Drain Catch, etc.
3. If large amounts of carbon dust are generated by the compressor, it can accumulate inside this product and cause malfunction. For details on the above compressed air quality, refer to SMC's "Air Preparation Systems".



# Series ITV0000/1000/2000/3000 Specific Product Precautions 3

Be sure to read before handling. Refer to back page for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

## Series ITV1000/2000/3000/209 □ Precautions

### Handling

#### ⚠ Caution

- Do not use a lubricator on the supply side of this product, as this can cause malfunction. When lubrication of terminal equipment is necessary, connect a lubricator on the output side of this equipment.
- If electric power is shut off while pressure is being applied, pressure will be retained on the output side.  
However, this output pressure is held only temporarily and is not guaranteed. If exhausting of this pressure is desired, shut off the power after reducing the set pressure, and discharge the air using a residual pressure exhaust valve, etc.
- If power to this product is cut off due to a power failure, etc. when it is in a controlled state, output pressure will be retained temporarily. Handle carefully when operating with output pressure released to the atmosphere, as air will continue to flow out.
- If supply pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and a humming noise may be generated. Since the life of the product may be shortened, shut off the power supply also when supply pressure is shut off.
- In this product, the output side pressure cannot be completely relieved within the range of 0.005 MPa or less. If it is desired to reduce the pressure completely to 0 MPa, install a 3 way valve or other device on the output side to exhaust the pressure.
- This product is adjusted for each specification at the time of shipment from the factory. Avoid careless disassembly or removal of parts, as this can lead to malfunction.
- The optional cable connector is a 4-wire type. When the monitor output (analogue output or switch output) is not being used, keep it from touching the other wires as this can cause malfunction.
- Please note that the right angle cable does not rotate and is limited to only one entry direction.
- Take the following steps to avoid malfunction due to noise.
  - Remove power supply noise during operation by installing a line filter, etc. in the AC power line.
  - For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors and power lines, etc.
  - Be sure to implement protective measures against load surge for induction loads (solenoid valves, relays, etc.).

### Handling

#### ⚠ Caution

- Due to the large volume of the output side, a loud exhaust noise will be produced when being used for the purpose of a relief function. Therefore, install a silencer (SMC Series AN200 or AN400) on the exhaust port (EXH port). The port sizes are Rc 1/8, Rc 1/4 and Rc 1/2.
- Specifications on page 10 is in case of static environment. Pressure may fluctuate when air is consumed at the output side.
- For details on the handling of this product, refer to the instruction manual which is included with the product.


### Design and Selection

#### ⚠ Caution

- The direct-current power supply to combine should be UL authorized power supply.
  - Limited voltage current circuit in accordance with UL 508.  
A circuit in which power is supplied by the secondary coil of a transformer that meets the following conditions.
    - Maximum voltage (with no load):  
30 Vrms (42.4 V peak) or less
    - Maximum current:
      - 8 A or less (including when short circuited)
      - limited by circuit protector (such as fuse) with the following ratings.

No load voltage (V peak)	Max. current rating
0 to 20 [V]	5.0
Above 20 to 30 [V]	100 Peak voltage

- A circuit using max. 30 Vrms or less (42.4 V peak), which is powered by UL1310 or UL1585 compatible Class-2 power supply.
- Operate these products only within the specified voltage.  
Using voltages beyond the specified levels could cause faults or malfunctions.
- Use 0 V as the baseline for the power supplied to the unit for output, control and input.





# Series ITV0000/1000/2000/3000 Specific Product Precautions 4


Be sure to read before handling. Refer to back page for Safety Instructions, "Handling Precautions for SMC Products" (M-E03-3) for Common Precautions.

## Series ITV1000/2000/3000/209 □ Precautions

### Wiring

#### Caution

Connect the cable to the connector on the body with the wiring arranged as shown below. Proceed carefully, as incorrect wiring can cause damage. Further, use DC power with sufficient capacity and a low ripple.




#### Current Signal Type Voltage Signal Type

1	Brown	Power supply
2	White	Input signal
3	Blue	GND (COMMON)
4	Black	Monitor output

#### Preset Input Type

1	Brown	Power supply
2	White	Input signal 1
3	Blue	GND (COMMON)
4	Black	Input signal 2



#### DeviceNet™, RS-232C, 16 points preset

Pin No.	IN/OUT communication connector				Signal connector
	CC-Link	DeviceNet™	PROFIBUS DP	RS-232C	16 points preset
1	SLD [-]	DRAIN [-]	No connection	No connection	Input signal 1 [Brown]
2	DB [White]	V+ [Red]	RxD/TxD-N [Green]	TxD [White]	Input signal 2 [White]
3	DG [Yellow]	V- [Black]	No connection	RxD [Blue]	Input signal 3 [Blue]
4	DA [Blue]	CAN_H [White]	RxD/TxD-P [Red]	GND [Black]	Input signal 4 [Black]
5	No connection	CAN_L [Blue]	No connection	No connection	Common [Grey]

Pin No.	Power supply connector				
	CC-Link	DeviceNet™	PROFIBUS DP	RS-232C	16 points preset
1 [Brown]	Vcc	Vcc	Vcc	Vcc	Vcc
2 [White]	FG	Can not connect	FG	No connection	No connection
3 [Blue]	GND	GND	GND	GND	GND
4 [Black]	No connection	Can not connect	No connection	FG	Monitor output

Note 1) The indicated wire colours are when a cable connector made by SMC is used.  
 Note 2) The cable is also available in a right angle type. (Communication cable: straight type only)  
 A right angle type connector is attached facing left (towards the SUP port). On communication models, the connector faces backwards (towards the EXH port). Do not attempt to rotate, as the connector does not turn.


■ **Trademark Information**  
 DeviceNet™ is a trademark of ODVA.

**Knock-down connectors** \* Order separately.

Part number	CC-Link compatibility		DeviceNet™ compatibility		PROFIBUS DP compatibility			
	Plug	Socket	Plug	Socket	Terminal Plug	Plug	Socket	Terminal Plug
	PCA-1557617	PCA-1557620	PCA-1557659	PCA-1557662	PCA-1557675	PCA-1557701	PCA-1557714	PCA-1557727


#### Wiring diagram

##### Current signal type




Vs : Power supply 24 VDC  
 12 to 15 VDC  
 A : Input signal 4 to 20 mA DC  
 0 to 20 mA DC

##### Voltage signal type




Vs : Power supply 24 VDC  
 12 to 15 VDC  
 Vin : Input signal 0 to 5 VDC  
 0 to 10 VDC

##### 4 points preset input type



Vs : Power supply 24 VDC  
 12 to 15 VDC  
 (Negative common)

##### 16 points preset input type



Vs : Power supply 24 VDC (No polarity)

One of the preset pressures P1 through P4 is selected by the ON/OFF combination of S1 and S2.

S1	OFF	ON	OFF	ON	OFF	ON	OFF	ON	OFF	ON
S2	OFF	OFF	ON	ON	OFF	ON	OFF	ON	OFF	ON
S3	OFF	OFF	OFF	OFF	ON	ON	OFF	ON	OFF	ON
S4	OFF	OFF	OFF	OFF	OFF	ON	OFF	ON	OFF	ON
Preset pressure	P01	P02	P03	P04	P05	...	P14	P15	P16	

\* For safety reasons, it is recommended that one of the preset pressures be set to 0 MPa.

\* Preset pressures are set based on the minimum unit for output display.

MPa	kgf/cm <sup>2</sup>	bar	psi	kPa
0.001	0.01	0.01	0.1	1

· Note that this is 1 psi for 130 psi types.

##### 10 bit digital input type

Wire Colour	Signal name
Pink-Black 2	Power supply (24 VDC)
Green-Black 2	Power supply (GND)
Blue	Signal Common (No Polarity)
Blue-Black 2	MSB 10 bit
Grey-Black 1	9 bit
Orange-Black 1	8 bit
Green-Black 1	7 bit
Pink-Black 1	6 bit
Blue-Black 1	5 bit
Grey	4 bit
Orange	3 bit
Green	2 bit
Pink	LSB 1 bit

Note) The wire colour is shown for when an option cable is used.



# Series ITV0000/1000/2000/3000 Specific Product Precautions 5


Be sure to read before handling. Refer to back page for Safety Instructions, “Handling Precautions for SMC Products” (M-E03-3) for Common Precautions.

## Series ITV1000/2000/3000/209□ Precautions


### Wiring

#### Monitor output wiring diagram


Analogue output: Voltage type




Analogue output: Current type  
(Sink type)



Switch output: NPN type



Switch output: PNP type



\* When 80 mA DC or more is applied, detecting device for overcurrent starts activating and then emits an error signal. (Error number “5”)

### Set Pressure Range

The set pressure range, by unit of standard measured pressure, is shown in the table below.

Set pressure range, by unit of standard measured pressure

Unit	Set pressure range			
	ITV□□01□	ITV□□03□	ITV□□05□	ITV209□
MPa	0.005 to 0.1	0.005 to 0.5	0.005 to 0.9	—
kgf/cm <sup>2</sup>	0.05 to 1	0.05 to 5	0.05 to 9	—
bar	0.05 to 1	0.05 to 5	0.05 to 9	—
psi	0.7 to 15	0.7 to 70	0.7 to 130	—
kPa	5 to 100	5 to 500	5 to 900	-1.3 to -80

### CE Marking

#### • Series ITV0000

Model	Ferrite core necessity	Recommended power supply cable
ITV0000-□□-Q	Unnecessary	M8-4DSX3MG4 (Straight type) P398000-501-2 (Right angle type)

Note) Recommended power supply cable length is 3 m. (P398000-501-2 is 2 m.) If any other length is desired, please consult with SMC.

#### • Series ITV1000/2000/3000

Model	Ferrite core necessity	Recommended power supply cable
ITV□□-□□	—	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
ITV□□-52□ ITV□□-53□	Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
	Signal	P398020-502-3 (Straight type) P398020-503-3 (Right angle type)
ITV□□-60□	—	INI-398-0-59 (Straight type)
ITV□□-CC□ Note 2) Note 3)	Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
	Communication	PCA-1567720 (Socket type) PCA-1567717 (Plug type)
ITV□□-DE□ Note 2) Note 4)	Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
	Communication	PCA-1557633 (Socket type) PCA-1557646 (Plug type)
ITV□□-PR□ Note 2) Note 4)	Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
	Communication	PCA-1557688 (Socket type) PCA-1557691 (Plug type)
ITV□□-RC□	Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
	Communication	P398020-502-3 (Straight type) P398020-503-3 (Right angle type)

Note 1) Recommended power supply cable length is 3 m. If any other length is desired, please consult with SMC.

Note 2) Even when the “with cable connector” type is selected, the communication connector is not included. Refer to the catalogue [M8/M12 Connector] for the details of the communication cable.

Note 3) For CC-Link compatible products, a dedicated Bus adapter is included with the product.

Note 4) For DeviceNet™ compatible products, and PROFIBUS DP compatible products, a T-branch connector is not included with the product.





# Series ITV0000/1000/2000/3000

## Specific Product Precautions 6

Be sure to read before handling. Refer to back page for Safety Instructions, “Handling Precautions for SMC Products” (M-E03-3) for Common Precautions.

### Series ITV009□/209□ Precautions




#### Handling

#### Caution

1. Connect the vacuum pump to the port, which is labelled “VAC”.
2. Pressure adjustment changes from “atmospheric pressure to vacuum pressure” when the input signal is increased, and from “vacuum pressure to atmospheric pressure” when the input signal is decreased.
3. When adjusting the vacuum pressure, be careful not to block the atmospheric pressure inlet port labelled “ATM”.
4. Since this product is designed exclusively for use with negative pressure, be careful not to apply positive pressure in error.
5. In cases where the vacuum pump being used has a relatively small capacity, or the piping has a small inside diameter, etc., large variations in the set pressure (the range of pressure variation when changing from no flow to flow state) may appear. In this situation, the vacuum pump or the piping, etc. should be changed. In cases where it is not practical to change the vacuum pump, install a capacity tank (volume depending on the operating conditions) on the VAC side.
6. The vacuum pressure response time after a change in the input signal is influenced by the internal volume on the setting side (including piping). Since the capacity of the vacuum pump also influences the response time, give careful consideration to these points before operation.
7. If the electric power is shut off when in a control state, the pressure on the setting side will go into a holding condition. However, this setting side pressure will be held only temporarily and is not guaranteed. In addition, when atmospheric pressure is desired, shut off the power after reducing the set pressure, and then introduce atmospheric pressure by using a vacuum release valve, etc.
8. If the power for this product is cut off by a power failure, etc. when it is in a controlled state, the setting side pressure will be held temporarily. Further, if operated without sealing the setting side so that atmospheric air is sucked in, handle with care as air will continue to be sucked in.
9. If the VAC side pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and may cause a humming noise. Since this may shorten the life of the product, be sure to shut off the power when the VAC side pressure is shut off.
10. The setting side pressure cannot be completely released from this product in the range below  $-1.3$  kPa. In cases where the pressure needs to be reduced completely to 0 kPa, install a 3 port valve, etc. on the setting side to discharge the residual pressure.
11. This product is adjusted for each specification at the factory before shipment. Avoid careless disassembly or removal of parts, as this can cause failure.
12. The optional cable connector is a 4-wire type. When the monitor output (analogue output, switch output) is not being used, keep it from touching the other wires, as this can cause malfunction.
13. Use caution that the right angle cable does not rotate and is limited to only one entry direction.
14. Take the following steps to avoid malfunction due to noise.
  - 1) Eliminate power supply noise during operation by installing a line filter, etc. in the AC power line.
  - 2) For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors and power lines, etc.
  - 3) Make sure to take protective measures against load surge for an induction load (solenoid valves, relays, etc.).
15. Refer to the instruction manual included with the product for details on its handling.

## Safety Instructions

These safety instructions are intended to prevent hazardous situations and/or equipment damage. These instructions indicate the level of potential hazard with the labels of “Caution,” “Warning” or “Danger.” They are all important notes for safety and must be followed in addition to International Standards (ISO/IEC)\*1), and other safety regulations.

-  **Caution:** Caution indicates a hazard with a low level of risk which, if not avoided, could result in minor or moderate injury.
-  **Warning:** Warning indicates a hazard with a medium level of risk which, if not avoided, could result in death or serious injury.
-  **Danger:** Danger indicates a hazard with a high level of risk which, if not avoided, will result in death or serious injury.

- \*1) ISO 4414: Pneumatic fluid power – General rules relating to systems.
- ISO 4413: Hydraulic fluid power – General rules relating to systems.
- IEC 60204-1: Safety of machinery – Electrical equipment of machines. (Part 1: General requirements)
- ISO 10218-1: Manipulating industrial robots - Safety. etc.

### Warning

- 1. The compatibility of the product is the responsibility of the person who designs the equipment or decides its specifications.**  
Since the product specified here is used under various operating conditions, its compatibility with specific equipment must be decided by the person who designs the equipment or decides its specifications based on necessary analysis and test results. The expected performance and safety assurance of the equipment will be the responsibility of the person who has determined its compatibility with the product. This person should also continuously review all specifications of the product referring to its latest catalogue information, with a view to giving due consideration to any possibility of equipment failure when configuring the equipment.
- 2. Only personnel with appropriate training should operate machinery and equipment.**  
The product specified here may become unsafe if handled incorrectly. The assembly, operation and maintenance of machines or equipment including our products must be performed by an operator who is appropriately trained and experienced.
- 3. Do not service or attempt to remove product and machinery/equipment until safety is confirmed.**
  1. The inspection and maintenance of machinery/equipment should only be performed after measures to prevent falling or runaway of the driven objects have been confirmed.
  2. When the product is to be removed, confirm that the safety measures as mentioned above are implemented and the power from any appropriate source is cut, and read and understand the specific product precautions of all relevant products carefully.
  3. Before machinery/equipment is restarted, take measures to prevent unexpected operation and malfunction.
- 4. Contact SMC beforehand and take special consideration of safety measures if the product is to be used in any of the following conditions.**
  1. Conditions and environments outside of the given specifications, or use outdoors or in a place exposed to direct sunlight.
  2. Installation on equipment in conjunction with atomic energy, railways, air navigation, space, shipping, vehicles, military, medical treatment, combustion and recreation, or equipment in contact with food and beverages, emergency stop circuits, clutch and brake circuits in press applications, safety equipment or other applications unsuitable for the standard specifications described in the product catalogue.
  3. An application which could have negative effects on people, property, or animals requiring special safety analysis.
  4. Use in an interlock circuit, which requires the provision of double interlock for possible failure by using a mechanical protective function, and periodical checks to confirm proper operation.

## Limited warranty and Disclaimer/ Compliance Requirements

The product used is subject to the following “Limited warranty and Disclaimer” and “Compliance Requirements”.  
Read and accept them before using the product.

### Limited warranty and Disclaimer

1. The warranty period of the product is 1 year in service or 1.5 years after the product is delivered, whichever is first.\*2)  
Also, the product may have specified durability, running distance or replacement parts. Please consult your nearest sales branch.
2. For any failure or damage reported within the warranty period which is clearly our responsibility, a replacement product or necessary parts will be provided. This limited warranty applies only to our product independently, and not to any other damage incurred due to the failure of the product.
3. Prior to using SMC products, please read and understand the warranty terms and disclaimers noted in the specified catalogue for the particular products.

\*2) Vacuum pads are excluded from this 1 year warranty.

A vacuum pad is a consumable part, so it is warranted for a year after it is delivered. Also, even within the warranty period, the wear of a product due to the use of the vacuum pad or failure due to the deterioration of rubber material are not covered by the limited warranty.

### Compliance Requirements

1. The use of SMC products with production equipment for the manufacture of weapons of mass destruction (WMD) or any other weapon is strictly prohibited.
2. The exports of SMC products or technology from one country to another are governed by the relevant security laws and regulations of the countries involved in the transaction. Prior to the shipment of a SMC product to another country, assure that all local rules governing that export are known and followed.

### Caution

- 1. The product is provided for use in manufacturing industries.**  
The product herein described is basically provided for peaceful use in manufacturing industries.  
If considering using the product in other industries, consult SMC beforehand and exchange specifications or a contract if necessary.  
If anything is unclear, contact your nearest sales branch.

### Caution

- SMC products are not intended for use as instruments for legal metrology.**  
Measurement instruments that SMC manufactures or sells have not been qualified by type approval tests relevant to the metrology (measurement) laws of each country. Therefore, SMC products cannot be used for business or certification ordained by the metrology (measurement) laws of each country.

## Safety Instructions

Be sure to read “Handling Precautions for SMC Products” (M-E03-3) before using.

### SMC Corporation (Europe)

Austria	☎ +43 (0)2262622800	www.smc.at	office@smc.at	Lithuania	☎ +370 5 2308118	www.smclt.lt	info@smclt.lt
Belgium	☎ +32 (0)33551464	www.smcpnematics.be	info@smcpnematics.be	Netherlands	☎ +31 (0)205318888	www.smcpnematics.nl	info@smcpnematics.nl
Bulgaria	☎ +359 (0)2807670	www.smc.bg	office@smc.bg	Norway	☎ +47 67129020	www.smc-norge.no	post@smc-norge.no
Croatia	☎ +385 (0)13707288	www.smc.hr	office@smc.hr	Poland	☎ +48 222119600	www.smc.pl	office@smc.pl
Czech Republic	☎ +420 541424611	www.smc.cz	office@smc.cz	Portugal	☎ +351 226166570	www.smc.eu	postpt@smc.smces.es
Denmark	☎ +45 70252900	www.smcdk.com	smc@smcdk.com	Romania	☎ +40 213205111	www.smcromania.ro	smcromania@smcromania.ro
Estonia	☎ +372 6510370	www.smcpnematics.ee	smc@smcpnematics.ee	Russia	☎ +7 8127185445	www.smc-pneumatik.ru	info@smc-pneumatik.ru
Finland	☎ +358 207513513	www.smc.fi	smc@smc.fi	Slovakia	☎ +421 (0)413213212	www.smc.sk	office@smc.sk
France	☎ +33 (0)164761000	www.smc-france.fr	info@smc-france.fr	Slovenia	☎ +386 (0)73885412	www.smc.si	office@smc.si
Germany	☎ +49 (0)61034020	www.smc.de	info@smc.de	Spain	☎ +34 902184100	www.smc.eu	post@smc.smces.es
Greece	☎ +30 210 2717265	www.smchellas.gr	sales@smchellas.gr	Sweden	☎ +46 (0)86031200	www.smc.nu	post@smc.nu
Hungary	☎ +36 23511390	www.smc.hu	office@smc.hu	Switzerland	☎ +41 (0)523963131	www.smc.ch	info@smc.ch
Ireland	☎ +353 (0)14039000	www.smcpnematics.ie	sales@smcpnematics.ie	Turkey	☎ +90 212 489 0 440	www.smcpnomatik.com.tr	info@smcpnomatik.com.tr
Italy	☎ +39 0292711	www.smcitalia.it	mailbox@smcitalia.it	UK	☎ +44 (0)845 121 522	www.smcpnematics.co.uk	sales@smcpnematics.co.uk
Latvia	☎ +371 67817700	www.smc.lv	info@smclv.lv				

SMC CORPORATION Akihbara UDX 15F, 4-14-1, Sotokanda, Chiyoda-ku, Tokyo 101-0021, JAPAN Phone: 03-5207-8249 FAX: 03-5298-5362