
# 4-Port Solenoid Valve Cassette Type Manifold



Rubber Seal




# Allows for the mixed mounting of 5 SJ series valve sizes



\*1 These values have been calculated according to ISO 6358 and indicate the flow rate under standard conditions with an inlet pressure of 0.6 MPa (relative pressure) and a pressure drop of 0.1 MPa.





### **Power consumption**

0.15 W\*1 (SJ3000/4000 with power-saving circuit) 0.23 W\*1 (SJ1000/2000 with power-saving circuit) \*1 Refer to page 140 for details.

### Connector type (Card edge type)

SJ1000, SJ2000, SJ3000, and SJ4000 series valves can be mounted together.

- · Easily increase or decrease the number of stations and easily replace valves
- ·The 34-pin connector allows for up to 16 stations with double solenoids or 32 stations with single solenoids.



conditions with an inlet pressure of 0.6 MPa (relative pressure) and a pressure drop of 0.1 MPa. \*2 Weight reduced by changing the valve body material

from zinc to aluminum

\* Weight (g) for the 5-station D sub-connector manifold/ single solenoids

Non plug-in individual wiring compliant




The manifold uses halogen-free lead wires.



#### 4-Port Solenoid Valve Cassette Type Manifold SJ1000/2000/3000/4000 Series

#### **Piping variations**

With One-touch fittings










The threaded type is not available for the 1(P) or 3/5(E) ports.

	SJ1000	SJ2000	SJ3000	SJ4000
Elbow fitting	_	•	•	_
Thread piping	_	•	•	_

#### With switch (Connector type)

- It is possible to shut off the signal of each valve individually.
- Manual operation is possible by switching the valve OFF, even if it is in an energized state.

\* SJ2000/3000 only



The valve coil is kept in a de-energized state even when there is an electric signal from the manifold side connector, and this enables manifold operation.

#### **Manual locking**


A sliding mechanism covers the manual override button to prevent unintentional operation.






# Connector mounting direction

Connecter mounting direction can be changed by sliding the switch.



#### Fittings are replaceable.

Fittings (including type and size) can be easily changed by removing a clip.



# Valve connection mechanism

Connection between valves can be secured using the valve lock switch. Connection can be confirmed by checking to see whether the connection hook is inserted into the connection groove of the adjacent valve.

\* Excludes the SJ4000






The word "FREE" can be seen when connection is unlocked.

#### **Light indication**






	SJ1000	SJ2000	SJ3000	SJ4000
Non-locking push type	•	•	•	•
Push-turn locking slotted type	•	•	•	•
Slide locking type	_	•	•	_

#### 4-position dual 3-port valve

- 3-port valves integrated into a single valve
- It is possible to control the 4(A) and 2(B) ports individually.
- Can be mounted on the same manifold as a 4-port valve
- 3 types of combinations are available.

A side	B side	Symbol
N.C. valve	N.C. valve	4(A) 2(B)  7
N.O. valve	N.O. valve	4(A) 2(B)  ZEAL 3 ZEAL 3  5(EA) 1(P) 3(EB)
N.C. valve	N.O. valve	4(A) 2(B)  75(EA) 1(P) 3(EB)





#### **Connector Type Manifold**

# D-sub connector


# **EX180 Integrated type (for output)** serial transmission system



- CC-Link (32 outputs), DeviceNet® (16 or 32 outputs)
- The connector allows for easy attaching/detaching of the SI unit and wiring.

Separated valve power unit and transmission power unit/Improved maintenance safety

Select between a T-branch or a straight type communication connector




# Flat ribbon cable

# **EX510 Gateway type serial transmission** system




- Max. 128 points (Input 64 points/Output 64 points)
- All wires can be plugged into the connector units.
- CC-Link, DeviceNet®, and PROFIBUS-DP compliant

### **Plug-in Cable Type Manifold**





#### 4-Port Solenoid Valve Cassette Type Manifold \$\int SJ1000/2000/3000/4000 \text{ Series}\$





#### 4-Port Solenoid Valve Cassette Type Manifold \$\int SJ1000/2000/3000/4000 \text{ Series}\$




It can be used, for example, when you wish to separate electrical control of valves in the same manifold or when

the number of control points is insufficient.






#### Intermediate connector block wiring example



- \* The U side solenoid valve with an intermediate connector block can be controlled.
- \* The intermediate connector block can be ordered using the manifold specification sheet.




#### 4-Port Solenoid Valve Cassette Type Manifold SJ1000/2000/3000/4000 Series


#### SUP/EXH block with regulator and pressure switch Details ➤ p. 111

This pressure regulator is intended to adjust the SUP pressure of the manifold. Additionally, a pressure switch and pressure gauge can be mounted on it.

\* Excludes the SJ4000



Lateral knob




**Upward knob** 




## Valve with speed controller Details > p. 111

As a speed controller is built into this valve, the cylinder speed can be adjusted on the valve side.


2 types, meter-in and meter-out, are provided.





Valve with speed controller

Pneumatic circuit (Installation example of a SUP/EXH block with regulator and pressure switch and a valve with speed controller)





#### 4-Port Solenoid Valve Cassette Type Manifold \$\int SJ1000/2000/3000/4000 \text{ Series}\$

#### Low-profile SUP/EXH block Details ➤ p. 117 (Made to order)

The width dimension of the SUP/EXH block is only 10.2 mm, smaller than the 15.5 mm width of the standard product, which allows for the length of the entire manifold to be reduced. \* Excludes the SJ4000

		[mm]
	Width	Reduction
Low-profile SUP/EXH block	10.2	5.3
Standard product	15.5	_





\* SJ1000 5-station manifold example

#### **Flow Rate Characteristics**

	Port	size	Flow rate characteristics						
Series	1(P)	4, 2	1 → 4/2 (	$(P \rightarrow A/B)$	4/2 → 3/5 (A/B → E)				
	3/5(E)	(A, B)	C [dm <sup>3</sup> /(s·bar)]	Q [l/min/(ANR)]*2	C [dm³/(s·bar)]	Q [l/min/(ANR)]*2			
SJ1000	C6	C2	0.12	26	0.13	28			
301000	Co	C4	0.26	56	0.30	65			
	C6	C2	0.13	28	0.13	28			
SJ2000		C6	C4	0.30	65	0.34	74		
		МЗ	0.18	39	0.20	43			
		C2	0.13	28	0.14	30			
SJ3000	C6	C4	0.38	82	0.45	97			
303000	00	C6	0.45	97	0.51	110			
		M5	0.40	87	0.45	97			

- The values are for an individually operated 2-position type manifold base with 5 stations.
   Excludes the SJ3000A (Large flow type) and SJ4000


#### Tube Releasing Tool Details ➤ Catalogue on https://www.smc.eu

Use this to remove tubing from the A, B and P, E ports.

Part	t no.	Applicable	TG-0204	TG-0608	TG-1012
Applicable	tubing O.D.	port	Ø 2/Ø 4	Ø 6/Ø 8	Ø 10
	SJ1000	For A, B port	•	_	_
	301000	For P, E port	_	•	-
Series	SJ2000	For A, B port	•	_	_
	502000	For P, E port	_	•	_
	SJ3000	For A, B port	•	•	_
		For P, E port	_	•	_
	SJ4000	For A, B port	_	•	-
	304000	For P, E port	_	•	•
TG-0204		TG-0608	Q	78 TG-10	12
	Ø 4				
	7		30.6		



# **Vacuum Release Valve with Restrictor**




- Power consumption: 0.15 W\*1 (with power-saving circuit)
- Width: 10 mm (same as the SJ3000 series)
- Equipped with restrictor to enable flow rate adjustment of release air
- Replaceable filters are built-in on the vacuum and release sides.
- Equipped with a pressure detection port which allows for the connection of a pressure switch, etc.
- Can be combined with 4-port solenoid valves, as well as SJ1000, 2000, and 3000 series valves (Special order)

(Please contact SMC for details.)

■ Enables 2-system pressure switching where the 1(P) port and the 3/5(E) port are set to different positive pressures

(In this case, flow can be adjusted on the P-port side only.)

\*1 Refer to page 140 for details.





# **Manifold Variations**

# **4-Port Solenoid Valve** SJ1000/2000/3000/4000 Series

**Vacuum Release Valve** with Restrictor

S	J3A6 Se	eries		D-sub co	Flat ribbo	EX1 (For ou	EX5 (Gatewa	Individ	
		Manifold type		△	Ĕ		3		
/e	Plug-in	Connector type	SJ1000/2000/ 3000/4000 SS5J1/2/3/4-60□	p. 29	p. 29	p. 61	*8 p. 77	*1 *7 *8 p. 30 p. 62 p. 78	
4-port solenoid valve	Plug-in	Cable type	SJ2000/3000 SS5J2/3-60L□	p. 33	p. 33	_	_	_	
4-	Non plug-	in	_	_	_	_	p. 95		
restrictor	Dlug in	Connector type	SJ3A6 SS3J3-V60□	p. 127	p. 127	p. 127	p. 127	*1 p. 128	
elease valve with restrictor	Plug-in	Cable type	SJ3A6 SS3J3-V60L□	p. 129	p. 129	_	_	_	
Vacuum release	Non plug-	in	SJ3A6 SS3J3-V60-□	_	_	_	_	p. 133	

<sup>\*1</sup> A linkage-printed circuit board is built into individual wiring valves so as to allow for use in combination with the plug-in types.

Connection

Parallel wiring | Serial transmission

on cable

onnector

Item

<sup>\*8</sup> Excludes the SJ4000



<sup>\*2</sup> Specify the required specifications on the manifold specification sheet.

<sup>\*3</sup> All single wiring or all double wiring can be specified.

<sup>\*4</sup> The vacuum release valve can only use double wiring.

<sup>\*5</sup> Only the SJ3000 size is available.

<sup>\*6</sup> Adding 1 additional station is possible up to the max. number of stations.

<sup>\*7</sup> Only the SJ2000 and SJ3000 sizes are available.

# SJ3A6 Series

				Mani	fold op	tions					Solenoid valve specifications				
		ii					_			¥		e suppi			
Mixed wiring Single/Double	Mixed type M60 SJ1000/2000/3000/4000	Block disk/ Different-pressure pneumatic circuit diagram	Blanking block	Dual flow fitting	Regulator block	SUP/EXH block with regulator and pressure switch	Valve with speed controller	Intermediate connector block	Increase of manifold stations	Low-profile SUP/EXH block	Non-polar	+/- common Polar	With power-saving circuit	With individual switch	Main valve fluororubber specification
*2	p. 29 p. 31	p. 103	p. 105	*5 p. 108	*8 p. 109	*8 p. 111	*5 p. 111	*8 p. 115	p. 90	*8 p. 117	*7			*7	*7 p. 116
*3	_	p. 103	p. 105	*5 p. 108	_	_	*5 p. 111	_	*6 p. 91	p. 117	_			_	p. 116
	*7 p. 95	p. 103	p. 105	*5 p. 108	p. 109	p. 111	*5 p. 111	_	p. 90	p. 117	_		_	_	p. 116
*4	_	p. 103	p. 105	_	_	_	_	p. 115	p. 90	p. 117			•		p. 116
*4	_	p. 103	p. 105	_	_	_	_	_	*6 p. 91	p. 117	_	•	•	_	p. 116
*4	_	p. 103	p. 105	_	_	_	_	_	p. 90	p. 117	_	•	_	_	p. 116

# CONTENTS

Manifold Variations		p. 9
4-Port Solenoid	Valve <i>SJ1000/2000/3000/4000</i> Serie	es
Common Specifications		p. 13
Construction		p. 18
Plug-in Connector Type M	anifold/Cable Type Manifold	p. 28
	D-sub Connector/Flat Ribbon Cable	
	How to Order: Connector Type	p. 29
	How to Order: Cable Type	p. 33
	Manifold Electrical Wiring: Connector Type, Cable Type	p. 35
Constant of the second	Dimensions: Connector Type, Cable Type	p. 37
222	EX180 Integrated Type (For Output) Serial Transmission Sys	stem
	How to Order: Connector Type	p. 61
	Dimensions: Connector Type	p. 65
A. A. C.	EX510 Gateway Type Serial Transmission System	
	How to Order: Connector Type	p. 77
	Dimensions: Connector Type	p. 79
	Manifold Exploded View: Connector Type, Cable Type	p. 86
	Manifold Exploded View (Mixed Specification): Connector Ty	<b>ype</b> p. 89
	How to Increase Manifold Stations: Connector Type, Cable Type	<b>)e</b> p. 90
Non Plug-in Individual Wir	ring Manifold	p. 94
	Individual Wiring	
	How to Order	p. 95
	Dimensions	p. 97
	Manifold Exploded View: Individual Wiring	p. 102
Manifold Options		p. 103
Made to Order		p. 116



Vacuum Belease	Valve with Restrictor SJ3A6 Series	p. 124
·		·
Plug-in Connector Type M	anifold/Cable Type Manifold	
	D-sub Connector/Flat Ribbon Cable/Serial Wiring (EX180/E	EX510)
	How to Order: Connector Type	p. 127
000000	How to Order: Cable Type	p. 129
	Dimensions: Connector Type, Cable Type	p. 131
Non Plug-in Individual Wi	ring Manifold	
	Individual Wiring	
	How to Order	p. 133
	Dimensions	p. 135
Manifold Exploded View: Conn	ector Type, Cable Type, Individual Wiring	p. 136
Specific Product Precautions		p. 138



# 4-Port Solenoid Valve SJ1000/2000/3000/4000 Series Common Specifications

#### **Manifold Specifications**

			D-sub connector		Flat ribbon cable		Serial	wiring	Individual wiring		
Model*1		Type 60F (Connector type/ Cable type	Type 60P (Connector type/ Cable type	Type 60PG (Connector type/ Cable type	Type 60PH (Connector type/ Cable type	Type 60S□ (EX180/ (Connector type)	Type 60S6B*4  EX510/ Connector type	Type 60*4			
Manifold	d type			Plug-in, Connecto	or type/Cable type		Plug-in, Co	nnector type	Non plug-in		
1(P: SUI	P), 3/5(E: E)	KH)			C	Common SUP, EX	Н				
Valve st	ations		Connector type: Cable type: 2	1 to 24 stations to 20 stations	1 to 18 stations (Type PG)	1 to 8 stations	1 to 32 stations	1 to 16 stations	1 to 20 stations		
Applicable connector		or	D-sub connector Compliant with MIL-C-24308 JIS-X-5101	Socket: 26 pins MIL type with strain relief	Flat ribbon cable connector Socket: 20 pins MIL type with strain relief Compliant with MIL-C-83503	Flat ribbon cable connector Socket: 10 pins MIL type with strain relief Compliant with MIL- C-83503	_	_	_		
	SJ1000			Connector type: positive common, negative common —							
Internal wiring	S.12000/3000/A1		Connector type: r	non-polar, positive o	common, negative o	common/Cable type:	positive common,	negative common	_		
wiilig	SJ4000		Connector type	: non-polar, positi	ve common, nega	ative common		_	_		
4(A), 2(B	) port	Location	Valve								
piping s	pecification	Direction	Horizontal, Upward, Downward (Elbow fittings are used for upward or downward. Upward and downward are not available for the SJ1000/4000								
	1(P), 3/5(E) port	SJ1000/ 2000/ 3000(A)		C6, C8, N7, N9*5							
Port		SJ4000				C10*6					
size		SJ1000				C2, C4					
	4(A),	SJ2000				C2, C4, N1, N3, M					
	2(B) port	SJ3000			C2, C	C4, C6, N1, N3, N	7, M5				
		SJ3000A				C4, C6					
		SJ4000				C6, C8					
Weight W [g]*2  (n: Number of SUP/EXH blocks m: Weight of DIN rail		SJ1000/ 2000/ 3000(A)		Low-		ard: W = 51n + m block specification		133* <sup>3</sup>			
worging		SJ4000			Manifold [D-su	b connector]: W =	81n + m + 144				

- \*1 The SJ1000/4000 series does not support cable connection or individual wiring.
- \*2 The weight W is the value for the D-sub connector manifold with internal pilot and SUP/EXH block straight fittings specifications only. To obtain the weight with solenoid valves mounted, add the solenoid valve weights given on page 16 for the appropriate number of stations. Refer to page 106 for the weight of the DIN rail. (Please contact SMC for the weight of the external pilot specification with elbow fittings.)
- \*3 Refer to page 117 for low-profile SUP/EXH block specifications.
- \*4 Not available for the SJ4000 series
- \*5 Inch size elbow fittings are not available.
- \*6 Metric/Inch size elbow fittings are not available.
- \* When many valves are operated simultaneously, use the B type (SUP/EXH both sides), supplying pressure to the 1(P) ports on both sides and exhausting from the 3/5(E) ports on both sides.



# Common Specifications **SJ1000/2000/3000/4000** Series

#### **Flow Rate Characteristics**

#### SJ1000 Series

Port siz	ze		Flow rate characteristics							
1(P)	4, 2	1 → 4/2 (P → A/B)				4/2 → 3/5	$4/2 \rightarrow 3/5 \text{ (A/B} \rightarrow \text{E)}$			
3/5(E)	(A, B)	C [dm³/(s·bar)]	b	Cv	Q [l/min (ANR)]*1	C [dm³/(s·bar)]	b	Cv	Q [l/min (ANR)]*1	
C8	C2	0.12	0.64	0.04	40	0.13	0.59	0.04	41	
08	C4	0.28	0.35	0.08	74	0.32	0.33	0.08	83	

#### SJ2000 Series

Port si	ze	Flow rate characteristics							
1(P)	4, 2		1 → 4/2	$(P \rightarrow A/B)$			4/2 → 3/5	5 (A/B → E)	
3/5(E)	(A, B)	C [dm <sup>3</sup> /(s·bar)]	b	Cv	Q [l/min (ANR)]*1	C [dm <sup>3</sup> /(s·bar)]	b	Cv	Q [l/min (ANR)]*1
	C2	0.13	0.55	0.04	40	0.13	0.50	0.04	38
C8	C4	0.33	0.16	0.08	77	0.36	0.13	0.08	83
	МЗ	0.18	0.52	0.06	54	0.20	0.29	0.06	51

#### SJ3000 Series

Port si	ze		Flow rate characteristics						
1(P)	4, 2		1 → 4/2	(P → A/B)			4/2 → 3/5	5 (A/B → E)	
3/5(E)	(A, B)	C [dm <sup>3</sup> /(s·bar)]	b	Cv	Q [l/min (ANR)]*1	C [dm <sup>3</sup> /(s·bar)]	b	Cv	Q [l/min (ANR)]*1
	C2	0.13	0.56	0.04	40	0.14	0.51	0.04	41
C8	C4	0.42	0.17	0.11	99	0.45	0.16	0.11	105
00	C6	0.55	0.10	0.12	125	0.56	0.11	0.12	128
	M5	0.40	0.28	0.11	100	0.45	0.15	0.11	105

#### SJ3000A Series

Port si	ze		Flow rate characteristics						
1(P)	4, 2		1 → 4/2	$(P \rightarrow A/B)$			4/2 → 3/5	5 (A/B → E)	
3/5(E)	(A, B)	C [dm <sup>3</sup> /(s·bar)]	b	Cv	Q [l/min (ANR)]*1	C [dm³/(s·bar)]	b	Cv	Q [l/min (ANR)]*1
	C4	0.53	0.34	0.17	138	0.75	0.21	0.20	181
C8	C6	0.68	0.27	0.19	170	0.76	0.19	0.21	181
	M5	0.55	0.33	0.16	143	0.75	0.21	0.20	181

#### SJ4000 Series

Port siz	ze		Flow rate characteristics						
1(P)	4, 2		1 → 4/2	$(P \rightarrow A/B)$			4/2 → 3/5	$S(A/B \rightarrow E)$	
3/5(E)	(A, B)	C [dm <sup>3</sup> /(s·bar)]	b	Cv	Q [l/min (ANR)]*1	C [dm <sup>3</sup> /(s·bar)]	b	Cv	Q [l/min (ANR)]*1
010	C6	1.47	0.36	0.43	389	2.34	0.34	0.70	611
C10	C8	2.14	0.24	0.58	525	2.61	0.20	0.68	625

 $<sup>\</sup>ast\,$  The values are for an individually operated 2-position type manifold base with 5 stations.



Please contact SMC for details on 4-position dual 3-port valves.

<sup>\*1</sup> These values have been calculated according to ISO 6358 and indicate the flow rate under standard conditions with an inlet pressure of 0.6 MPa (relative pressure) and a pressure drop of 0.1 MPa.


# D-sub connector



Flat ribbon cable



EX180 Integrated type (for output) serial transmission system



EX510 Gateway type serial transmission system



Individual wiring

#### **Solenoid Valve Specifications**

Fluid			Air	
	2-position	single	0.15 to 0.7	
Internal pilot	4-position	dual 3-port valve	0.15 to 0.7	
operating pressure range [MPa]	2-position	n double	0.1 to 0.7	
	3-position	1	0.2 to 0.7	
	Operating	pressure range	–100 kPa to 0.7	
External pilot	Pilot	2-position single		
operating pressure range [MPa]	pressure	2-position double	0.25 to 0.7	
range 3-position		3-position		
Ambient and fluid ter	mperatures	[ °C]	-10 to 50 (No freezing)	
	2-position single, double		10 (SJ4000: 5 Hz)	
Max. operating frequency [Hz]	4-position	dual 3-port valve	10 (334000. 3 Hz)	
	3-position	ı	3	
Manual override (Ma	nual anavat	tion)	Non-locking push type	
wanuai overniue (wa	iluai operai	lion)	Push-turn locking slotted type	
Pilot exhaust method	Internal p	ilot	Main and pilot valve common exhaust	
Filot extraust method	External p	oilot	Pilot valve individual exhaust	
Lubrication			Not required	
Mounting orientation			Unrestricted	
Impact/Vibration resistance [m/s²]			150/30	
Enclosure			Dustproof	

<sup>\*</sup> Impact resistance : No malfunction occurred when it is tested with a drop tester in the axial direction and at the right angles to the main valve and armature in both energized and de-energized states every once for each condition. (Value in the initial state)

Vibration resistance: No malfunction occurred in one sweep test between 45 and 2000 Hz in the axial direction and at the right angles to the main valve and armature in both energized and de-energized states for each condition. (Value in the initial state)

#### **Solenoid Specifications**

Coil rated voltage	e	24 VDC, 12 VDC* <sup>4</sup>			
Allowable voltage fluctuation		±10 % of rated voltage*1			
	Standard	SJ2000	0.55		
	Standard	SJ3000/4000	0.4		
Power consumption [W]	With power- saving circuit*3	SJ1000/2000	0.23*2 [Starting 0.55, Holding 0.23]		
	(Continuous duty type)	SJ3000/4000	0.15*2 [Starting 0.4, Holding 0.15]		
Surge voltage su	ippressor	Diode			
Indicator light		LED			

<sup>\*1</sup> For the allowable voltage fluctuation for Z and T types (with power-saving circuit), please observe the following range because they have voltage drop due to internal circuit.

Z type 24 VDC: -7 % to +10 %

12 VDC: -4 % to +10 %

T type 24 VDC: -5 % to +10 % 12 VDC: -6 % to +10 %

\*2 Refer to page 140 for details.

#### **Response Time**

Time of actuation	Response time [ms] (at 0.5 MPa)					
Type of actuation	SJ1000	SJ2000	SJ3000	SJ4000		
2-position single	16	16	16	26		
2-position double	10	10	10	12		
3-position	20	34	22	29		
4-position dual 3-port valve	18	30	30	30		

st Based on dynamic performance test, JIS B 8419:2010 (Coil temperature: 20 °C, at rated voltage)



<sup>\*3</sup> SJ1000 series available as power-saving type only. Standard type (without power-saving circuit) cannot be selected.

<sup>\*4</sup> The 12 VDC specification is not available for the SJ4000.

# Common Specifications *SJ1000/2000/3000/4000 Series*

## Weight

#### Model: SJ1000/2000 Series

Value medal	т.		Port size	Weight
Valve model	1	ype of actuation	4(A), 2(B)	[g]
	2-position	Single		34
	z-position	Double	C2	38
SJ1□60T-C2		Closed center	/ Ø 2 One- \	
301-001-02	3-position	Exhaust center	1 1	41
		Pressure center	\touch fitting/	
	4-position	Dual 3-port valve		38
	2-position	Single		36
	2-003111011	Double	C4	40
SJ1□60T-C4		Closed center	/ Ø 4 One- \	
301-001-04	3-position	Exhaust center	1 1	43
		Pressure center	\touch fitting/	
	4-position	Dual 3-port valve		40
	2-position	Single		43
		Double	C2	46
SJ2□60-C2	3-position	Closed center	/ Ø 2 One- \	
302-00-02		Exhaust center	1 1	50
		Pressure center	\touch fitting/	
	4-position	Dual 3-port valve		46
	2-position	Single		41
	2-position	Double	C4	44
SJ2□60-C4		Closed center	/ Ø 4 One- \	
002000	3-position		touch fitting	48
		Pressure center	\touch hung/	
	4-position	Dual 3-port valve		44
	2-position	Single		39
	- pooliion	Double		42
SJ2□60-M3		Closed center	M3 x 0.5	
COLLIGO IIIO	3-position		WIO X 0.0	46
		Pressure center		
	4-position	Dual 3-port valve		42

<sup>\*</sup> Please contact SMC for the weight of elbow fittings.

#### Model: SJ3000 Series

Valve model	T	ype of actuation	Port size	Weight
vaive model	21		4(A), 2(B)	[g]
	2-position	Single		63
	L pooliion	Double	C2	71
SJ3□60-C2		Closed center	/ Ø 2 One- \	
000000	3-position		1 1	75
		Pressure center	touch fitting	
	4-position	Dual 3-port valve		71
	2-position	Single		65
	2-003111011	Double	C4	73
SJ3□60-C4		Closed center	/ Ø 4 One- \	
303_00-04	3-position	Exhaust center	1 1	77
		Pressure center	\touch fitting/	
	4-position	Dual 3-port valve		73
	O nocition	Single		61
	2-position	Double	C6	69
SJ3□60-C6	3-position	Closed center	/ Ø 6 One- \	
3J3_60-C6		Exhaust center		73
		Pressure center	touch fitting	
	4-position	Dual 3-port valve		69
	2-position	Single		57
		Double		65
C IOTCO ME		Closed center	MENOO	
SJ3□60-M5	3-position	Exhaust center	M5 x 0.8	69
	i .	Pressure center		
	4-position	Dual 3-port valve	1	65
		Single	C4	53
SJ3□60A-C4		Sirigle	/ Ø 4 One- \	55
อบง⊔ซบA-C4		Double		64
		Double	\touch fitting/	04
		Single	C6	49
SJ3⊓60A-C6	2-position	Onigie	/ Ø 6 One- \	43
303_00A-C0	2-position	Double		60
		Double	\touch fitting/	
		Single		46
		J		
SJ3□60A-M5			M5×0.8	

 $<sup>\</sup>ast\,\,$  Please contact SMC for the weight of elbow fittings.


#### Model: SJ4000 Series

Valve model	Т	ype of actuation	Port size 4(A), 2(B)	Weight [g]	
	0	Single		111	
	2-position	Double	C6	121	
SJ4□60-C6		Closed center	/ Ø 6 One- \		
304_00-C0	3-position	Exhaust center	1 1	131	
		Pressure center	\touch fitting/		
	4-position	Dual 3-port valve		120	
	2-position	Single		108	
	2-position	Double	C8	118	
SJ4□60-C8		Closed center	/ Ø 8 One- \		
304_00-C6	3-position	Exhaust center	1 1	128	
		Pressure center	\touch fitting/		
	4-position	Dual 3-port valve		117	



#### **Connector Wiring Diagram**

For both serial and parallel wiring, additional valves are sequentially assigned pins on the connector. This makes it completely unnecessary to disassemble the connector unit.



# Construction

#### SJ1000/2000: Connector Type

#### **Symbol**


2-position single



2-position single with back pressure check valve




#### 2-position single




#### 2-position double




2-position double with back pressure check valve



#### 2-position double




#### 3-position closed center




3-position exhaust center



#### 3-position closed center/exhaust center/pressure center



### 3-position pressure center




#### **Component Parts**

No.	Description	Material	Note			
		Resin/HNBR				
1	Spool valve assembly	3-position solenoid valve:	_			
		\Aluminum/HNBR/				
2	Body	Zinc die-cast	_			
3	Adapter plate	Resin	White			
4	Pilot adapter	Resin	White			
5	Pilot valve assembly	_	_			
6	Body cover	Resin	White			
7	Port block	Resin	White			
8	Bottom cover	Resin	White			
9	Light cover	Resin	Light blue			

#### **Replacement Parts**

No.	Description		Part no.
10	One-touch fitting		Refer to the One-touch fitting part no. on page 142.
11	Clip	SJ1000	SJ1000-CL-1 (10 pcs.)
	Clip	SJ2000	SJ2000-CL-1 (10 pcs.)

#### SJ1260KT/SJ2260K [With back pressure check valve]







#### SJ1000/2000: Connector Type

#### **Symbol**


4-position dual 3-port valve SJ1A60T/SJ2A60 [N.C. valve x 2]




SJ1A60KT/SJ2A60K with back pressure check valve




#### SJ1A60T/SJ2A60 [N.C. valve x 2]




SJ1B60T/SJ2B60 [N.O. valve x 2]




SJ1B60KT/SJ2B60K with back pressure check valve




#### SJ1B60T/SJ2B60 [N.O. valve x 2]




#### SJ1C60T/SJ2C60 [N.C., N.O. valve x 1 (each)]



SJ1C60KT/SJ2C60K with back pressure check valve



#### SJ1C60T/SJ2C60 [N.C., N.O. valve x 1 (each)]




#### **Component Parts**

No.	Description	Material	Note
1	Spool valve assembly	Resin/HNBR	N.C. (Normally closed)
2	Spool valve assembly	Resin/HNBR	N.O. (Normally open)
3	Body	Zinc die-cast	_
4	Adapter plate	Resin	White
5	Pilot adapter	Resin	White
6	Pilot valve assembly	_	_
7	Body cover	Resin	White
8	Port block	Resin	White
9	Bottom cover	Resin	White
10	Light cover	Resin	Light blue

#### **Replacement Parts**

No.	Description		Part no.
11	One-touch fitting		Refer to the One-touch fitting part no. on page 142.
-10	Clip	SJ1000	SJ1000-CL-1 (10 pcs.)
12	SJ2000		SJ2000-CL-1 (10 pcs.)

#### SJ1A60KT/SJ2A60K [With back pressure check valve]



# Construction SJ1000/2000/3000/4000 Series

#### SJ3000: Connector Type

#### **Symbol**

2-position single




2-position single with back pressure check valve




2-position double




2-position double with back pressure check valve




3-position closed center




3-position exhaust center



3-position pressure center





**Component Parts** 


1 Spool valve assembly (3-p	Resin/HNBR osition solenoid valve: \ uminum/HNBR / inc die-cast*1	_ _
2 Body Z		_
	Б.	
3 Adapter plate	Resin	White
4 Pilot adapter	Resin	White
5 Pilot valve assembly	_	_
6 Body cover	Resin	White
7 Port block	Resin	White
8 Bottom cover	Resin	White
9 Light cover	Resin	Light blue

<sup>\*1</sup> Aluminum die-cast is used for the SJ3000A.


**Replacement Parts** 

No.	Description	Part no.
10	One-touch fitting	Refer to the One-touch fitting part no. on page 142.
11	Clip	SJ3000-CL-1 (10 pcs.)


#### 2-position single [SJ31□□(A)]




#### 2-position double [SJ32□□(A)]



#### 3-position closed center/exhaust center/pressure center




#### SJ3260K [With back pressure check valve]




#### SJ3000: Connector Type

#### **Symbol**


4-position dual 3-port valve SJ3A60 [N.C. valve x 2]




SJ3A60K with back pressure check valve




#### **SJ3A60** [N.C. valve x 2]




#### SJ3B60 [N.O. valve x 2]




SJ3B60K with back pressure check valve




SJ3B60 [N.O. valve x 2]




# SJ3C60 [N.C., N.O. valve x 1 (each)]



SJ3C60K with back pressure check valve



#### SJ3C60 [N.C. valve, N.O. valve x 1 (each)]




#### **Component Parts**

No.	Description	Material	Note
1	Spool valve assembly	Resin/HNBR	N.C. (Normally closed)
2	Spool valve assembly	Resin/HNBR	N.O. (Normally open)
3	Body	Zinc die-cast	_
4	Adapter plate	Resin	White
5	Pilot adapter	Resin	White
6	Pilot valve assembly	_	_
7	Body cover	Resin	White
8	Port block	Resin	White
9	Bottom cover	Resin	White
10	Light cover	Resin	Light blue

**Replacement Parts** 

. iop.	riopiacomoni i arto		
No.	Description	Part no.	
11	One-touch fitting	Refer to the One-touch fitting part no. on page 142.	
12	Clip	SJ3000-CL-1 (10 pcs.)	

#### SJ3A60K [With back pressure check valve]



# Construction **SJ1000/2000/3000/4000** Series


#### SJ4000: Connector Type

#### Symbol


2-position single




#### 2-position single



2-position double



2-position double




3-position closed center


(A)4 2(B) (EA)5 1 3(EB) (P)

3-position pressure center

3-position exhaust center



#### 3-position closed center/exhaust center/pressure center



(EA)5 13(EB) (P)

COIII	Component Parts			
No.	Description	Material	Note	
1	Spool valve assembly	Resin/HNBR (3-position solenoid valve: Aluminum/HNBR)	_	
2	Body	Aluminum die-cast	_	
3	Adapter plate	Resin	White	
4	Pilot adapter	Resin	White	
5	Pilot valve assembly	_	_	
6	Body cover	Resin	White	
7	Port block	Resin	White	
8	Bottom cover	Resin	White	
9	Light cover	Resin	Light blue	

**Replacement Parts** 


· iop.	ropidoomont raito		
No.	Description	Part no.	
10	One-touch fitting	Refer to the One-touch fitting part no. on page 142.	
11	Clip	JSY31M-19P-1A (10 pcs.)	




#### SJ4000: Connector Type

#### Symbol


4-position dual 3-port valve SJ4A60 [N.C. valve x 2]




#### **SJ4A60** [N.C. valve x 2]




#### SJ4B60 [N.O. valve x 2]




#### SJ4B60 [N.O. valve x 2]



#### SJ4C60 [N.C., N.O. valve x 1 (each)]



#### SJ4C60 [N.C. valve, N.O. valve x 1 (each)]



#### **Component Parts**

No.	Description	Material	Note
1	Spool valve assembly	Resin/HNBR	N.C. (Normally closed)
2	Spool valve assembly	Resin/HNBR	N.O. (Normally open)
3	Body	Aluminum die-cast	_
4	Adapter plate	Resin	White
5	Pilot adapter	Resin	White
6	Pilot valve assembly	_	_
7	Body cover	Resin	White
8	Port block	Resin	White
9	Bottom cover	Resin	White
10	Light cover	Resin	Light blue

#### **Replacement Parts**

No.	Description	Part no.
11	One-touch fitting	Refer to the One-touch fitting part no. on page 142.
12	Clip	JSY31M-19P-1A (10 pcs.)

#### SJ2000: Cable Type

#### **Symbol**


2-position single



2-position single with back pressure check valve




#### 2-position single




2-position double




2-position double with back pressure check valve




2-position double




3-position closed center



3-position exhaust center



3-position closed center/exhaust center/pressure center



(EA)5 1 3(EB) (P)


3-position pressure center
(A)4 2(B)

Component Parts			
No.	Description	Material	Note
1	Spool valve assembly	Resin/HNBR (3-position solenoid valve: Aluminum/HNBR)	_
2	Body	Zinc die-cast	_
3	Adapter plate	Resin	White
4	Pilot adapter	Resin	White
5	Pilot valve assembly	_	_
6	Body cover	Resin	White
7	Port block	Resin	White
8	Bottom cover assembly	Resin	White
9	Light cover	Resin	Light blue

**Replacement Parts** 

No.	Description	Part no.
10	One-touch fitting	Refer to the One-touch fitting part no. on page 142.
11	Clip	SJ2000-CL-1 (10 pcs.)

#### SJ2260K [With back pressure check valve]






## **SJ2000/3000** Series


#### SJ2000: Cable Type

#### **Symbol**


4-position dual 3-port valve SJ2A60 [N.C. valve x 2]




SJ2A60K with back pressure check valve




#### SJ2A60 [N.C. valve x 2]




#### SJ2B60 [N.O. valve x 2]




SJ2B60K with back pressure check valve




SJ2B60 [N.O. valve x 2]




SJ2C60 [N.C., N.O. valve x 1 (each)]



SJ2C60K with back pressure check valve



SJ2C60 [N.C. valve, N.O. valve x 1 (each)]




#### **Component Parts**

No.	Description	Material	Note
1	Spool valve assembly	Resin/HNBR	N.C. (Normally closed)
2	Spool valve assembly	Resin/HNBR	N.O. (Normally open)
3	Body	Zinc die-cast	_
4	Adapter plate	Resin	White
5	Pilot adapter	Resin	White
6	Pilot valve assembly	_	_
7	Body cover	Resin	White
8	Port block	Resin	White
9	Bottom cover assembly	Resin	White
10	Light cover	Resin	Light blue

**Replacement Parts** 

riepiacement raito			
No.	Description	Part no.	
11	One-touch fitting	Refer to the One-touch fitting part no. on page 142.	
12	Clip	SJ2000-CL-1 (10 pcs.)	

#### SJ2A60K [With back pressure check valve]



#### SJ3000: Cable Type


#### Symbol

2-position single


(A)4 2(B) (EA)5 1 3(EB) 2-position single with back pressure check valve




2-position double




2-position double with back pressure check valve




3-position closed center



3-position exhaust center



3-position pressure center



**Component Parts** 


No.	Description	Material	Note
1	Spool valve assembly	Resin/HNBR (3-position solenoid valve: Aluminum/HNBR)	_
2	Body	Zinc die-cast*1	_
3	Adapter plate	Resin	White
4	Pilot adapter	Resin	White
5	Pilot valve assembly	_	_
6	Body cover	Resin	White
7	Port block	Resin	White
8	Bottom cover assembly	Resin	White
9	Light cover	Resin	Light blue

\*1 Aluminum die-cast is used for the SJ3000A.


#### **Replacement Parts**

No.	Description	Part no.
10	One-touch fitting	Refer to the One-touch fitting part no. on page 142.
11	Clip	SJ3000-CL-1 (10 pcs.)


#### 2-position single




#### 2-position double



#### 3-position closed center/exhaust center/pressure center



#### SJ3260K [With back pressure check valve]




## **SJ2000/3000** Series


#### SJ3000: Cable Type

#### **Symbol**


4-position dual 3-port valve SJ3A60 [N.C. valve x 2]




SJ3A60K with back pressure check valve




#### **SJ3A60** [N.C. valve x 2]




#### SJ3B60 [N.O. valve x 2]




SJ3B60K with back pressure check valve




#### SJ3B60 [N.O. valve x 2]




# SJ3C60 [N.C., N.O. valve x 1 (each)]



SJ3C60K with back pressure check valve



#### SJ3C60 [N.C. valve, N.O. valve x 1 (each)]




#### **Component Parts**

No.	Description	Material	Note
1	Spool valve assembly	Resin/HNBR	N.C. (Normally closed)
2	Spool valve assembly	Resin/HNBR	N.O. (Normally open)
3	Body	Zinc die-cast	_
4	Adapter plate	Resin	White
5	Pilot adapter	Resin	White
6	Pilot valve assembly	_	_
7	Body cover	Resin	White
8	Port block	Resin	White
9	Bottom cover assembly	Resin	White
10	Light cover	Resin	Light blue

**Replacement Parts** 

	ricpiacement i arts			
N	lo.	Description	Part no.	
1	11	One-touch fitting	Refer to the One-touch fitting part no. on page 142.	
1	12	Clip	SJ3000-CL-1 (10 pcs.)	

#### SJ3A60K [With back pressure check valve]




# Plug-in Connector Type Manifold Cable Type Manifold

# SJ1000/2000/3000/4000 Series



Connector Type Manifold
D-sub Connector/Flat Ribbon Cable






p. 33

Cable Type Manifold
D-sub Connector/Flat Ribbon Cable






p. 61

Connector Type Manifold EX180 Integrated Type (For Output) Serial Transmission System



Connector Type Manifold EX510 Gateway Type Serial Transmission System




# Plug-in Connector Type ( CA CA **D-sub Connector/Flat Ribbon Cable** SJ1000/2000/3000 Series

How to Order

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

#### Connector type manifold



#### Series

1	SJ1000
2	SJ2000
3	SJ3000 (SJ1000/2000/3000
	mixed*1)

\*1 Select "3" for the combination of SJ1000 and SJ2000 valves.

#### Mixed mounting type

_	Standard*1	
M	Mixed mounting*2	

- \*1 For SJ1000, 2000, and 3000 series valves, leave blank when only using a single series.
- \*2 Select "M" when SJ1000, SJ2000, or SJ3000 series valves will be mounted on the same manifold base together.


#### 3 Connector type

P: Flat ribbon cable (26 pins)

Note Up to 24 solenoids

can be selected.


Symbol Stations



#### 4 Connector mounting position

Symbol	Mounting position
D	D side

#### **5** Connector entry direction



#### 6 Valve stations

#### F: D-sub connector

Symbol	Stations	Note
01	1 station	Up to 24 solenoids
:		can be selected.
24	24 stations	can be selected.

Symbol	Stations	Note
01	1 station	Up to 18 solenoids
:	:	can be selected.
18	18 stations	can be selected.

This number also includes the blanking block. Since single and double wiring

#### SUP/EXH block mounting position

	• 1	
U	U side	
D	D side	
В	B Both sides	
M*1	Special specifications	

Specify the required specifications (including port sizes other than O 8) on the manifold specification sheet.

#### PG: Flat ribbon cable (20 pins) PH: Flat ribbon cable (10 pins)

24

nbol	Stations	Note	Symbol	Stations	Note
)1	1 station	lla to 10 colonoido	01	1 station	Up to 8 solenoids
:		Up to 18 solenoids can be selected.	- :		can be selected
8	18 stations	can be selected.	08	8 stations	can be selected.

are available for the blanking block, select a model compatible with the valve wiring specification to be used. (Refer to page 105.)

#### 8 Pilot type

_	Internal pilot		
s	Internal pilot, Built-in silencer		
R	External pilot		
	External pilot, Built-in		
RS	silencer		

- There is no need to enter anything when the SUP/ EXH block mounting position "M" is selected.
- The 3/5(E) port is plugged for the built-in silencer type.

#### 9 SUP/EXH block fitting specification

Straight fitting With external pilot spec. X, PE port: Elbow fitting	Elbov (Upw With 6 X, PE

w fitting ward) external pilot spec. E port: Straight fitting



Elbow fitting (Downward) With external pilot spec. X, PE port: Elbow fitting

В

\* There is no need to enter anything when the SUP/EXH block mounting position "M" is selected.


#### 🚺 DIN rail length specified

_	Standard length					
2	2 stations	Specify a length				
:	i i longer than th					
24 24 stations the standa		the standard rail.				

Specify the number of valve stations without exceeding the max. number of stations.

# **How to Order Manifold Assembly**


#### Ordering example (SS5J3-60PD2-□) Double solenoid, individual wiring/ lead wire length 300 mm (24 VDC)



- SS5J3-60PD2-06D .....1 set (Manifold part no.) SJ3160-5CU-C6 .....2 sets (Single solenoid part no.) \* SJ3260-5CU-C6 .....2 sets (Double solenoid part no.) \* SJ3260-5CZJ-C6...... 1 set (Double solenoid, with switch part no.) SJ3260-5MZ-C6 ...... 1 set (Double solenoid, individual wiring/ lead wire length 300 mm part no.)
- The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the solenoid valves, etc.
- For the valve arrangement, the valve closest to the D side is
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.
- When ordering a manifold, specify the part nos. of the valves to be mounted on it. (An order cannot be placed with only the manifold part no.)

# D-sub Connector/Flat Ribbon Cable SJ1000/2000/3000 Series

#### **How to Order Solenoid Valves**



#### **Series**

SJ1000 SJ2000 3 SJ3000 Type of actuation

1	2-position single solenoid					
2						
3	3 3-position closed center					
4	3-position exhaust center					
5 3-position pressure center						

- \* Refer to pages 281 to 284 for the symbol.
- The large flow type ("A") is available only for actuation types "1" and "2."

Α

#### 6 Coil type

Symb	Symbol Coil type		SJ2000	SJ3000(A)
_	Standard	_		•
Т	With power-saving circuit (Continuous duty type)	•	•	•

- \* Be sure to select the power-saving circuit type if the valve is to be continuously energized for long periods of time.
- For the SJ1000 series, only the power-saving circuit type is available.

# Standard flow type

A\*1 Large flow type

\*1 SJ3000 series only

#### 4 Pilot type

_	Internal pilot				
R	External pilot				

\* The external pilot specification is not applicable for 4-position dual 3-port valves.

#### Back pressure check valve None

Dual 3-port valve: N.C./N.C.

Dual 3-port valve: N.O./N.O.

Dual 3-port valve: N.C./N.O.

	K	Built-in
*	3 -positi	on and large flow type ("A"
	solenoio	d valves cannot be equipped
	with a b	ack pressure check valve.

#### Rated voltage 5 24 VDC 12 VDC

#### **O**Common specification Positive common

Negative common Leave blank for the non-polar type.

#### **Connector entry**

	C:	M:	MN:	MO:
	Dedicated for centralized wiring	Individual wiring, With lead wire Length: 300 mm	Individual wiring, Without lead wire (With connector, socket)	Individual wiring, Without connector
Symbol	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	With linkage-printed circuit board	With linkage-printed circuit board	With linkage-printed circuit board
SJ1000	•	_	_	_
SJ2000	•	•	•	•
SJ3000	•	•	•	•

- \* Connector entries with the symbol "M\sumsymbol" cannot use the switch signal from the common wiring on the manifold. For details, refer to the "Connector Wiring Diagram" on page 17.
- When ordering a connector separately, refer to pages 144 and 145.

#### 10 Light/surge voltage suppressor


Symbol	bol Specification		SJ2000	SJ3000(A)
U	With light/surge voltage suppressor (Non-polar type)	_	•	•
Z	With light/surge voltage suppressor (Polar type)	•	•	•

\* When the type with a power-saving circuit, with a switch, or with individual wiring is used, the non-polar type cannot be selected.

#### With switch

SJ1000	SJ2000	SJ3000(A)
_	•	•

#### Manual override



#### A, B port size

#### Metric/One-touch fitting

Symbol   A, B port   SJ1000   SJ2000   SJ3000   SJ3000								
Symbol	A,	В	port	SJ1000	SJ2000	SJ3000	SJ3000A	
C2	ŧ	Q	) 2	•	•	•	_	
C4	Straight	Ø 4 • • • •	•					
C6	Ś	Q	96	_	_	•	•	
L2		ntry	Ø 2	-	•	•	_	
L4		Upward entry	Ø 4	-	•	•	•	
L6	Elbow	Npw	Ø 6	S —	_	•	•	
B2	H	entry	Ø 2	2 -	•	•	_	
B4		<b>Jownward entry</b>	Ø 4	—	•	•	•	
В6		Dowr	Ø 6	S -		•	•	

Ιh	read	nII	nınd
	ı cau	PI	ини

Symbol	A, B port	SJ1000	SJ2000	SJ3000	SJ3000A	
МЗ	M3 x 0.5	_	•	_	_	
M5	M5 x 0.8	_	_	•	•	<b>E S</b>

#### Inch/One-touch fitting

					· <u> </u>			
Symbo	ol	A, B port		SJ1000	SJ2000	SJ3000	SJ3000A	
N1	Į		Ø 1/8"	_	•	•	_	
N3	Straight	,	Ø 5/32"	_	•	•	•	
N7			Ø 1/4"	_	_	•	•	
LN1	ı	entry	Ø 1/8"	_	•	•	_	
LN3	3		Ø 5/32"	_	•	•	•	
LN7	7 Modia	Upward	Ø 1/4"	_	_	•	•	
BN1	1	entry	Ø 1/8"	_	•	•	_	
BN	3	Downward	Ø 5/32"	_	•	•	•	
BNZ	7	Dowr	Ø 1/4"	_	_	•	•	

#### Single solenoid wiring specification

_	Single wiring
D	Double wiring

Leave blank for 2-position double, 3-position, and 4-position solenoid valves Select "D" only when setting a blank number for wiring. Refer to page 17 for details.





## Plug-in Connector Type






# SJ4000 Series

**How to Order** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

#### Connector type manifold



#### Series


SJ4000

#### 2 Mixed mounting type

_	Standard (Dedicated for the SJ4000)
M	Mixed mounting

- Leave blank when only using a single series
- Select "M" when SJ1000, SJ2000, or SJ3000 series valves will be mounted on the same manifold base together.


#### Connector type



#### 4 Connector mounting position

D side

#### Connector entry direction



#### 6 Valve stations

#### F: D-sub connector

Symbol	Stations	INOTE
01	1 station	lle to 04 colonoido
:		Up to 24 solenoids can be selected.
24	24 stations	can be selected.

· on · ide instruction caste (20 pine)					
Symbol	Stations	Note			
01	1 station	llo to 10 colonoido			
:	:	Up to 18 solenoids can be selected.			
18	18 stations	can be selected.			

#### P: Flat ribbon cable (26 pins)

Symbol	Stations	Note	J
01	1 station	lle to 04 colonoide	
:	:	Up to 24 solenoids can be selected.	
24	24 stations	can be selected.	

#### PG: Flat ribbon cable (20 pins) PH: Flat ribbon cable (10 pins)

· · · · · · · · · · · · · · · · · · ·				
Symbol	Stations	Note		
01	1 station	llm to O colomoido		
:	:	Up to 8 solenoids can be selected.		
08	8 stations	can be selected.		

This number also includes the blanking block. Since single and double wiring are available for the blanking block, select a model compatible with the valve wiring specification to be used. (Refer to page 105.)

#### SUP/EXH block mounting position

M	Special specifications		
В	Both sides		
D	D side		
U	U side		

- \* Special specifications (including instructions for port sizes other than the Ø 10 of the standard SUP/EXH block) must be specified separately on a manifold specification sheet.
- \* For 11 or more valve stations. "B" (both sides) is recommended.

#### 8 Pilot type

_	Internal pilot	
S	Internal pilot, Built-in silencer	
R	External pilot	

- There is no need to enter anything when the SUP/EXH block mounting position "M" is selected.
- The 3/5(E) port is plugged for the built-in silencer type ("S").
- The SJ4000 does not have the external pilot and built-in silencer ("RS") type.


#### 9 DIN rail length specified

_	Standard length		
2	2 stations Specify a length		
	:	longer than that of	
24	24 stations	the standard rail.	

Specify the number of valve stations without exceeding the max. number of stations.

#### **How to Order Manifold Assembly**


#### Ordering example (SS5J4-60FD2-05D)



- SS5J4-60FD2-05D .....1 set (Manifold part no.) SJ4160-5CU-C8 .....2 sets (Single solenoid part no.)
- SJ4260-5CU-C8 ......3 sets (Double solenoid part no.)
- - The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the solenoid valves, etc.
- For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.
- When ordering a manifold, specify the part nos. of the valves to be mounted on it. (An order cannot be placed with only the manifold part no.)
- For the mixed mounting ("M") of SJ4000 and SJ1000/2000/3000 valves, SJ1000/2000/3000 valves are mounted on the D side of the SJ4000 D side SUP/EXH block.
- The SJ4000 series does not have an elbow One-touch fitting.



#### **How to Order Solenoid Valves**



#### 1 Type of actuation

1	2-position single solenoid
2	2-position double solenoid
3	3-position closed center
4	3-position exhaust center
5	3-position pressure center
Α	Dual 3-port valve: N.C./N.C.
В	Dual 3-port valve: N.O./N.O.
С	Dual 3-port valve: N.C./N.O.

\* Refer to pages 22 and 23 for the symbol.

#### 2 Pilot type

_	Internal pilot
R	External pilot

 The external pilot specification is not applicable for 4-position dual 3-port valves.

#### 3 Coil type

_	71
_	Standard
Т	With power-saving circuit (Continuous duty type)

\* Be sure to select the powersaving circuit type if the valve is to be continuously energized for long periods of time.

#### Rated voltage

5	24 VDC
* 12 V	DC is not available for the
SJ40	000.

#### **5** Common specification

		•	
	_	Positive common	
	N	Negative common	

\* Leave blank for the non-polar type.

#### 6 Connector entry


Dedicated for centralized wiring

## Light/surge voltage suppressor

U	With light/surge voltage suppressor (Non-polar type)
Z	With light/surge voltage suppressor (Polar type)

When the type with a power-saving circuit is used, the non-polar type cannot be selected.

#### 8 Manual override



#### 9 A, B port size Metric/One-touch fitting

C6	Straight	Ø6	
C8		Ø 8	

#### Single solenoid wiring specification

wining opcomoduon				
_	Single wiring			
D	Double wiring			

Leave blank for 2-position double, 3-position, and 4-position solenoid valves.

- \* SJ4000 series valves cannot be not equipped with a back pressure check valve.
- \* The SJ4000 series does not have an A, B port inch-size or elbow One-touch fitting.

# Plug-in Cable Type

# 

# D-sub Connector/Flat Ribbon Cable RoHS




# SJ2000/3000 Series

**How to Order** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

#### Cable type manifold



#### **Series**

2 Cable type

SJ2000 SJ3000

#### 4 Connector mounting position


Symbol	Mounting position
D	D side

#### 6 Manifold wiring specification

_	All double wiring*1
S	All single wiring*2

- \*1 All double wiring: 2-position single, 2-position double, 3-position, and 4-position valves can be used on all manifold stations.
- \*2 All single wiring: Available only for manifolds which have 2-position single valves on all stations Note that 2-position double, 3-position, or 4-position valves cannot be used.
- If a mixture of single wiring and double wiring is required, it is available as a special order.

#### Connector type



#### Valve stations

<b>F</b> : D-sub connector (25 pins)				
Symbol	Stations	Note		
02	2 stations	All double		
÷	:	wiring		
10	10 stations	wiiiig		
02	2 stations	All sinsula		
:	:	All single wiring		
20	20 stations	wiring		

PG:	Flat	ribbon	cable	(20	pins

	Symbol	Stations	Note
	02	2 stations	All double
	:	:	wiring
	09	9 stations	wiinig
	02	2 stations	All single
	:	:	All single wiring
ĺ	18	18 stations	wiring

#### P: Flat ribbon cable (26 pins)

Symbol	Stations	Note
02	2 stations	All double
i	:	wiring
10	10 stations	wiinig
02	2 stations	All singula
:	:	All single wiring
20	20 stations	wiiing

#### PH: Flat ribbon cable (10 pins)

Symbol	Stations	Note
02	2 stations	All double
i	:	wiring
04	4 stations	wiinig
02	2 stations	All simula
÷	:	All single wiring
08	8 stations	wiring


- This number also includes the blanking plate.
- \* The cable type is only applicable when there are 2 or more stations.

#### SUP/EXH block fitting specification

			_
_		L	В
Straight fitting		Elbow fitting	Elbow fitting
With external pilot spec.		(Upward)	(Downward)
X, PE port: Elbow fitting	e and	With external pilot spec.	With external pilot spec.
		X, PE port: Straight fitting	X, PE port: Elbow fitting
* There is no need to ex	nter anything whe	on the SLIP/EXH block mounting position	"M" is selected

nere is no need to enter anything when the SUP/EXH block mounting position "M" is selected.

#### Connector entry direction



#### 8 SUP/EXH block mounting position

U	U side
D	D side
В	Both sides
M*1	Special specifications

- Specify the required specifications (including port sizes other than Ø 8) on the manifold specification sheet.
- \* Due to the length of the cable, the max. number of supply and exhaust blocks that can be installed is 3 in total: one set between stations, one set on the D-side, and one set on the U-side end of the manifold.

#### Pilot type

_	Internal pilot	
S	Internal pilot, Built-in silencer	
R	External pilot	
RS	External pilot, Built-in silencer	

There is no need to enter anything when the SUP/EXH block mounting position "M" is selected.


### DIN rail length specified

_	Standard length		
3	3 stations Specify a length		
÷	:	longer than that of	
20	20 stations	the standard rail.	

Specify the number of valve stations without exceeding the max. number of stations.

#### How to Order Manifold Assembly

## Ordering example (SS5J3-60LPD2)




- SS5J3-60LPD2-06D.....1 set (Manifold part no.)
- SJ3160-5FZ-C6 .....2 sets (Single solenoid part no.)
- \* SJ3260-5FZ-C6 .....4 sets (Double solenoid part no.)

The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the solenoid valves, etc.

- For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.
- When ordering a manifold, specify the part nos. of the valves to be mounted on it. (An order cannot be placed with only the manifold part no.)

#### **How to Order Solenoid Valves**



#### Series

2	SJ2000
3	SJ3000

#### 2 Type of actuation

1	1 2-position single solenoid	
2	2-position double solenoid	
3	3-position closed center	
4	3-position exhaust center	
5	3-position pressure center	
Α	Dual 3-port valve: N.C./N.C.	
В	Dual 3-port valve: N.O./N.O.	
С	Dual 3-port valve: N.C./N.O.	

- Refer to pages 24 to 27 for the symbol.The large flow type ("A") is available only for actuation types "1" and "2."

#### 3

_	Standard flow type
<b>A</b> *1	Large flow type

\*1 SJ3000 series only

#### **5** Back pressure check valve

	•	
_	None	
K	Built-in	

\* 3-position and large flow type ("A") solenoid valves cannot be equipped with a back pressure check valve.

#### 4 Pilot type

_	Internal pilot
R	External pilot

\* The external pilot specification is not applicable for 4-position dual 3-port valves.

#### 6 Coil type

_	Standard				
Т	With power-saving circuit (Continuous duty type)				

\* Be sure to select the power-saving circuit type if the valve is to be continuously energized for long periods of time.


#### Rated voltage

5	24 VDC
6	12 VDC


## 8 Common specification

_	Positive common			
N	Negative common			

#### 9 Connector entry



#### Manual override



#### 10 Light/surge voltage suppressor

Z With light/surge voltage suppressor

#### 12 A, B port size

#### Metric/One-touch fitting

metrio/one todon numg								
Symbol		Α,	B port	SJ2000	SJ3000	SJ3000A		
C2	Straight		Ø 2	•	•	_		
C4		traigh		Ø 4	•	•	•	
C6	S		Ø 6	_	•	•		
L2		entry	Ø 2	•	•	_		
L4				Ø 4	•	•	•	
L6	Elbow	Upward	Ø 6	_	•	•		
B2	ella	entry	Ø 2	•	•	_		
B4		Downward	Ø 4	•	•	•		
В6		Dowr	Ø6	_	•	•		

#### Thread nining

Tilleau	pipilig				
Symbol	A, B port	SJ2000	SJ3000	SJ3000A	
М3	M3 x 0.5	•	_	_	
M5	M5 x 0.8	_	•	•	


#### Inch/One-touch fitting

incn/O	inch/One-touch fitting							
Symbol		Α,	B port	SJ2000	SJ3000	SJ3000A		
N1	ıt		Ø 1/8"	•	•	_		
N3	Straight	,	O 5/32"	•	•	•		
N7	S		Ø 1/4"	_	•	•		
LN1		entry	Ø 1/8"	•	•	_		
LN3			Ø 5/32"	•	•	•		
LN7	Elbow	Upward	Ø 1/4"	_	•	•		
BN1	ello Ello	entry	Ø 1/8"	•	•	_		
BN3		Downward	Ø 5/32"	•	•	•		
BN7		Dowr	Ø 1/4"	_	•	•		




#### Manifold Electrical Wiring: Connector Type (Non-polar Type)

#### Type 60F: D-sub connector (25 pins)




\* This circuit is for the specifications with up to 12 stations of 2-position double, 3-position, and 4-position dual 3-port valves. There should be wired in order 1→14→2→15 without skipping or leaving any connectors remaining.

#### Type 60P: Flat ribbon cable (26 pins)




\* This circuit is for the specifications with up to 12 stations of 2-position double, 3-position, and 4-position dual 3-port valves. There should be wired in order 1→2→3→4 without skipping or leaving any connectors remaining.

#### Type 60PG: Flat ribbon cable (20 pins)



\* This circuit is for the specifications with up to 9 stations of 2-position double, 3-position, and 4-position dual 3-port valves. There should be wired in order 1→2→3→4 without skipping or leaving any connectors remaining.

#### Type 60PH: Flat ribbon cable (10 pins)



wired in order 1→2→3→4 without skipping or leaving any connectors remaining.


## **⚠** Caution

When the non-polar U type valves are used, either positive common or negative common wiring of the manifold is possible. However, when the Z type valves are used, select the positive common or negative common according to the wiring specifications.




#### **Manifold Electrical Wiring: Cable Type**


#### Type 60LF: D-sub connector (25 pins)




#### Type 60LP: Flat ribbon cable (26 pins)



#### Type 60LPG: Flat ribbon cable (20 pins)



#### Type 60LPH: Flat ribbon cable (10 pins)




## **⚠** Caution

For electrical connections, select the positive common or negative common according to the wiring specifications.



## Dimensions: SJ1000 for D-sub Connector

#### SS5J1-60FD<sub>2</sub>-Stations U(S, R, RS)



L: D	imer	nsior	าร																				n: S	tations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	98	110.5	110.5	123	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	235.5	235.5	248	248
L2	87.5	100	100	112.5	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	225	225	237.5	237.5
L3	64.3	70.8	77.3	83.8	90.3	96.8	103.3	109.8	116.3	122.8	129.3	135.8	142.3	148.8	155.3	161.8	168.3	174.8	181.3	187.8	194.3	200.8	207.3	213.8
L4	20	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18	21	18	21	17.5	20.5	23.5	20.5	23.5	20


# 


## Dimensions: SJ1000 for D-sub Connector

#### SS5J1-60FD<sub>2</sub>-Stations B(S, R, RS)


#### [External pilot specification]


(There are piping of X and PE ports on both sides.)





(Station 1) -----(Station n)






L: 0	)imer	nsior	าร																				n: S	Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	110.5	123	123	135.5	135.5	148	148	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5	260.5
L2	100	112.5	112.5	125	125	137.5	137.5	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5	225	225	237.5	237.5	250	250
L3	79.8	86.3	92.8	99.3	105.8	112.3	118.8	125.3	131.8	138.3	144.8	151.3	157.8	164.3	170.8	177.3	183.8	190.3	196.8	203.3	209.8	216.3	222.8	229.3
L4	18.5	21.5	18	21	18	21	17.5	20.5	23.5	20.5	23.5	20	23	20	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5



## Dimensions: SJ2000 for D-sub Connector

#### SS5J2-60FD<sub>2</sub>-Stations U(S, R, RS)



22

18

20.5

19.5

20.5

19.5

18

20.5

20.5

20.5


L4

39


19.5

# Plug-in Connector Type/Cable Type D-sub Connector/Flat Ribbon Cable SJ1000/2000/3000/4000 Series

## Dimensions: SJ2000 for D-sub Connector




## Dimensions: SJ3000(A) for D-sub Connector



# Plug-in Connector Type/Cable Type D-sub Connector/Flat Ribbon Cable SJ1000/2000/3000/4000 Series

## Dimensions: SJ3000(A) for D-sub Connector



18

183.3 193.3 203.3

213.3 223.3

20

19

243.3 253.3

22.5 23.5 263.3 273.3 283.3

19.5

20.5

18.5

83.3

22.5

L4

93.3 103.3

17.5

113.3 123.3

20

21

133.3 143.3 153.3

18.5

23.5

163.3 173.3

19.5

20.5


21.5

313.3

293.3 303.3

## Dimensions: SJ4000 for D-sub Connector

#### SS5J4-60FD<sub>2</sub>-Stations D(S, R)




L: 0	)ime	nsio	าร																				n: S	tations
Ln	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	110.5	123	148	160.5	173	185.5	198	223	235.5	248	260.5	273	298	310.5	323	335.5	348	373	385.5	398	410.5	423	448	460.5
L2	100	112.5	137.5	150	162.5	175	187.5	212.5	225	237.5	250	262.5	287.5	300	312.5	325	337.5	362.5	375	387.5	400	412.5	437.5	450
L3	76.8	91.8	106.8	121.8	136.8	151.8	166.8	181.8	196.8	211.8	226.8	241.8	256.8	271.8	286.8	301.8	316.8	331.8	346.8	361.8	376.8	391.8	406.8	421.8
L4	20	18.5	23.5	22.5	21	20	18.5	23.5	22.5	21	20	18.5	23.5	22.5	21	20	18.5	23.5	22.5	21	20	18.5	23.5	22.5

## Dimensions: SJ4000 for D-sub Connector

#### SS5J4-60FD<sub>2</sub>-Stations <sup>U</sup><sub>B</sub>(S, R)

#### [External pilot specification] One-touch fitting [X: External pilot port] One-touch fitting applicable tubing O.D.: Ø 4 [PE: Pilot EXH port] Applicable tubing O.D.: Ø 4 (Connector entry direction: Upward) (Station 1) ---- (Station n) 68.2 64.5 36.5 40 32. One-touch fitting (Pitch) One-touch fitting [1(P), 3/5(E) port] [4(A), 2(B) port] Applicable tubing O.D.: Ø 10 Applicable tubing O.D.: Ø 4, Ø 6, Ø 8



#### L: Dimensions


L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	123	148	160.5	173	185.5	198	223	235.5	248	260.5	273	298	310.5	323	335.5	348	373	385.5	398	410.5	423	448	460.5	473
L2	112.5	137.5	150	162.5	175	187.5	212.5	225	237.5	250	262.5	287.5	300	312.5	325	337.5	362.5	375	387.5	400	412.5	437.5	450	462.5
L3	92.3	107.3	122.3	137.3	152.3	167.3	182.3	197.3	212.3	227.3	242.3	257.3	272.3	287.3	302.3	317.3	332.3	347.3	362.3	377.3	392.3	407.3	422.3	437.3
L4	18.5	23.5	22	21	19.5	18.5	23.5	22	21	19.5	18.5	23.5	22	21	19.5	18.5	23.5	22	21	19.5	18.5	23.5	22	21



n: Stations

## Dimensions: SJ1000/2000/3000(A) Mixed Manifold


#### SS5J3-M60FD<sub>2</sub>-Stations U(S, R, RS)




L dimension: Formula, L1 to L4 L3 =  $6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 57.8$ M = (L3 + 9.9)/12.5 + 1 Decimal fractions are truncated. L1 = M x 12.5 + 23 L2 = L1 - 10.5 L4 = (L1 - L3)/2 + 1

> n1 = Number of SJ1000 n2 = Number of SJ2000 n3 = Number of SJ3000(A)

\* The dimensions of L1 to L4 for SS5J3-M60FD1/2-Stations D are the same as those of SS5J3-M60FD1/2-Stations U.




#### SS5J3-M60FD<sub>2</sub>-Stations B(S, R, RS)



L3 =  $6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 73.3$ M = (L3 + 9.9)/12.5 + 1Decimal fractions are truncated. L1 = M x 12.5 + 23 L2 = L1 - 10.5 L4 = (L1 - L3)/2 + 1


> n1 = Number of SJ1000 n2 = Number of SJ2000 n3 = Number of SJ3000(A)



# 


## Dimensions: SJ1000/2000/3000/4000 Mixed Manifold

#### SS5J4-M60FD<sub>2</sub>-Stations D(S, R)




L dimension: Formula, L1 to L4  $L3 = 6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 15 \times n4 + 77.3$ M = (L3 + 9.9)/12.5 + 1Decimal fractions are truncated.  $L1 = M \times 12.5 + 23$ L2 = L1 - 10.5L4 = (L1-L3)/2 + 1

> n1 = Number of SJ1000 n2 = Number of SJ2000n3 = Number of SJ3000n4 = Number of SJ4000




#### SS5J4-M60FD<sub>2</sub>-Stations U(S, R)



L dimension: Formula, L1 to L4  $L3 = 6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 15 \times n4 + 92.8$ M = (L3 + 9.9)/12.5 + 1Decimal fractions are truncated.  $L1 = M \times 12.5 + 23$ L2 = L1-10.5 L4 = (L1-L3)/2 + 1


> n1 = Number of SJ1000 n2 = Number of SJ2000 n3 = Number of SJ3000 n4 = Number of SJ4000

Applicable connector: D-sub {JIS-X-5101 } equivalent 2 x M2.6




## Dimensions: SJ1000/2000/3000/4000 Mixed Manifold


#### SS5J4-M60FD<sub>2</sub>-Stations B(S, R)



L dimension: Formula, L1 to L4 L3 =  $6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 15 \times n4 + 108.3$ M = (L3 + 9.9)/12.5 + 1 Decimal fractions are truncated. L1 = M x 12.5 + 23 L2 = L1-10.5 L4 = (L1-L3)/2 + 1

> n1 = Number of SJ1000 n2 = Number of SJ2000 n3 = Number of SJ3000 n4 = Number of SJ4000






# Plug-in Connector Type/Cable Type D-sub Connector/Flat Ribbon Cable SJ1000/2000/3000/4000 Series

## Dimensions: SJ1000 for Flat Ribbon Cable

#### SS5J1-60PD<sub>2</sub>-Stations U(S, R, RS)




<sup>\*</sup> Type 60PG and 60PH differ only in their connectors, and the L1 through L4 dimensions are the same as type 60P.

L: D	imer	nsior	าร																				n: S	Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	98	110.5	110.5	123	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	235.5	235.5	248	248
L2	87.5	100	100	112.5	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	225	225	237.5	237.5
L3	64.3	70.8	77.3	83.8	90.3	96.8	103.3	109.8	116.3	122.8	129.3	135.8	142.3	148.8	155.3	161.8	168.3	174.8	181.3	187.8	194.3	200.8	207.3	213.8
L4	20	23	20	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18	21	24	21	24	20.5	23.5	20.5

## Dimensions: SJ1000 for Flat Ribbon Cable

#### SS5J1-60PD<sub>2</sub>-Stations B(S, R, RS)




<sup>\*</sup> Type 60PG and 60PH differ only in their connectors, and the L1 through L4 dimensions are the same as type 60P.


L: D	imer	nsior	าร																				n: S	tations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	110.5	123	123	135.5	135.5	148	148	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5	260.5
L2	100	112.5	112.5	125	125	137.5	137.5	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5	225	225	237.5	237.5	250	250
L3	79.8	86.3	92.8	99.3	105.8	112.3	118.8	125.3	131.8	138.3	144.8	151.3	157.8	164.3	170.8	177.3	183.8	190.3	196.8	203.3	209.8	216.3	222.8	229.3
L4	18.5	21.5	18.5	21.5	18	21	24	21	24	20.5	23.5	20.5	23.5	20	23	20	23	19.5	22.5	19.5	22.5	19	22	19


## Dimensions: SJ2000 for Flat Ribbon Cable


#### SS5J2-60PD<sub>2</sub>-Stations U(S, R, RS)



Applicable tubing O.D.: Ø 4, Ø 5/32"








#### For 60PH (10 pins) For 60PG (20 pins)

Triangle mark location



Triangle mark location

(When equipped with switch) Height to manual override Push type manual override: 40.3 Locking type manual override: 40.5

> Light/surge voltage suppressor SOL.a: Red SOL.b: Green SS5J2-60LPD2¹-□ Cable connection

L: Dimensions	-	
<ul> <li>Type 60PG and 60PH differ only in their connectors, and the L1 through L4 dimensions are the same as type 60P.</li> <li>For manifold dimensions including elbow fitting, refer to page 59.</li> </ul>		
(MIL-C-83503 compliant)		

with strain relief

(18)

L: D	imer	nsior	าร																				n: S	tations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	98	110.5	110.5	123	135.5	135.5	148	148	160.5	173	173	185.5	185.5	198	210.5	210.5	223	223	235.5	248	248	260.5	260.5	273
L2	87.5	100	100	112.5	125	125	137.5	137.5	150	162.5	162.5	175	175	187.5	200	200	212.5	212.5	225	237.5	237.5	250	250	262.5
L3	65.3	72.8	80.3	87.8	95.3	102.8	110.3	117.8	125.3	132.8	140.3	147.8	155.3	162.8	170.3	177.8	185.3	192.8	200.3	207.8	215.3	222.8	230.3	237.8
L4	19.5	22	18.5	21	23.5	19.5	22	18.5	21	23.5	19.5	22	18.5	21	23.5	19.5	22	18.5	21	23.5	19.5	22	18.5	21

Slide locking type (manual override)

 $\oplus$ 

## Dimensions: SJ2000 for Flat Ribbon Cable

#### SS5J2-60PD<sub>2</sub>-Stations B(S, R, RS) [External pilot specification] (There are piping of X and PE ports on both sides.) One-touch fitting (X: External pilot port) Applicable tubing O.D.: Ø 4, Ø 5/32" One-touch fitting [4(A), 2(B) port] One-touch fitting Applicable tubing O.D.: Ø 2, Ø 1/8" O 4, O 5/32" [1(P), 3/5(E) port] Applicable tubing O.D.: Ø 8, Ø 5/16" M3 x 0.5 [4(A), 2(B) port] 58 54 30.6 32 15.6 (Pitch) One-touch fitting 34.3 23.6 P = 7.5(PE: Pilot EXH port) Applicable tubing O.D.: Ø 4, Ø 5/32" (Station 1)---(Station n) D side U side L2 (Lead wire length) (DIN rail mounting hole pitch: 12.5) Approx. 300 switch) Manual override DIN rail holding screw Locking type: Press, equipped with then rotate it. 30.6 individual 5.3 4(A) port side: Blue 2(B) port side: Yellow Triangle mark location Silencer (Air discharge port) Manual override switch (Built-in silencer specification) DIN rail $\oplus$ 56.2 20.8 5.5 8 (9.1) (8) Valve lock switch Applicable connector: 26-pin MIL type L3 with strain relief For 60PH (10 pins) For 60PG (20 pins) (MIL-C-83503 compliant) Switch for locking a connector Triangle mark location Triangle mark location (Connector entry direction: Upward) Switch (When equipped with switch) Height to manual override Push type manual override: 40.3 Locking type manual override: 40.5 32 28) (18) Light/surge voltage suppressor 5.8 SOL.a: Red Side Applicable connector: 20-pin MIL type SS5J2-60LPD2-□ Cable connection with strain relief (MIL-C-83503 compliant) Applicable connector: 10-pin MIL type with strain relief $\oplus$ (MIL-C-83503 compliant) <del>(</del>† Type 60PG and 60PH differ only in their connectors, and the L1 through L4 dimensions are the same as type 60P. For manifold dimensions including elbow fitting, refer to page 59. L: Dimensions n: Stations 2 3 4 5 6 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 110.5 123 135.5 135.5 148 148 160.5 173 173 185.5 185.5 198 210.5 210.5 223 223 235.5 248 248 260.5 260.5 273 285.5 285.5

L2 106

L3

80.8

18

125

95.8

88.3

20.5

125

103.3 110.8

19.5 22

137.5

137.5 150

118.3

18

125.8

20.5 23

162.5

133.3

162.5 175

140.8 148.3

> 19.5 22

187.5 200

155.8 163.3 170.8

23

200

19.5

212.5

178.3 185.8

212.5 225

193.3

18

237.5

200.8 208.3

20.5 23 237.5 250

19.5

215.8 223.3

250

230.8

18

262.5 275

20.5

238.3 245.8

275

253.3


19.5

175


18

# Plug-in Connector Type/Cable Type D-sub Connector/Flat Ribbon Cable SJ1000/2000/3000/4000 Series

## Dimensions: SJ3000(A) for Flat Ribbon Cable



## Dimensions: SJ3000(A) for Flat Ribbon Cable





53

# Plug-in Connector Type/Cable Type D-sub Connector/Flat Ribbon Cable SJ1000/2000/3000/4000 Series

## Dimensions: SJ4000 for Flat Ribbon Cable

#### SS5J4-60PD<sub>2</sub>-Stations D(S, R)






L: D	)imer	nsior	าร																				n: S	tations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	110.5	123	148	160.5	173	185.5	198	223	235.5	248	260.5	273	298	310.5	323	335.5	348	373	385.5	398	410.5	423	448	460.5
L2	100	112.5	137.5	150	162.5	175	187.5	212.5	225	237.5	250	262.5	287.5	300	312.5	325	337.5	362.5	375	387.5	400	412.5	437.5	450
L3	76.8	91.8	106.8	121.8	136.8	151.8	166.8	181.8	196.8	211.8	226.8	241.8	256.8	271.8	286.8	301.8	316.8	331.8	346.8	361.8	376.8	391.8	406.8	421.8
L4	20	19	24	22.5	21.5	20	19	24	22.5	21.5	20	19	24	22.5	21.5	20	19	24	22.5	21.5	20	19	24	22.5



## Dimensions: \$\,\overline{34000}\) for Flat Ribbon Cable

SS5J4-60PD<sub>2</sub>-Stations U(S, R)




<sup>\*</sup> Type 60PG and 60PH differ only in their connectors, and the L1 through L4 dimensions are the same as type 60P.

L: I	Jimer	nsior	าร																				n: S	tations
	າ 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	123	148	160.5	173	185.5	198	223	235.5	248	260.5	273	298	310.5	323	335.5	348	373	385.5	398	410.5	423	448	460.5	473
L2	112.5	137.5	150	162.5	175	187.5	212.5	225	237.5	250	262.5	287.5	300	312.5	325	337.5	362.5	375	387.5	400	412.5	437.5	450	462.5
L3	92.3	107.3	122.3	137.3	152.3	167.3	182.3	197.3	212.3	227.3	242.3	257.3	272.3	287.3	302.3	317.3	332.3	347.3	362.3	377.3	392.3	407.3	422.3	437.3
L4	18.5	23.5	22.5	21	20	18.5	23.5	22.5	21	20	18.5	23.5	22.5	21	20	18.5	23.5	22.5	21	20	18.5	23.5	22.5	21




## Dimensions: SJ1000/2000/3000(A) Mixed Manifold

#### SS5J3-M60PD<sub>2</sub>-Stations U(S, R, RS)




#### SS5J3-M60PD<sub>2</sub>-Stations B(S, R, RS)



L dimension: Formula, L1 to L4  $L3 = 6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 57.8$ M = (L3 + 10.6)/12.5 + 1Decimal fractions are truncated.  $L1 = M \times 12.5 + 23$ L2 = L1 - 10.5L4 = (L1 - L3)/2 + 1.3

> n1 = Number of SJ1000 n2 = Number of SJ2000 n3 = Number of SJ3000(A)




The dimensions of L1 to L4 for SS5J3-M60PD1/2- Stations D are the same as those of SS5J3-M60PD1/2- Stations U.

L dimension: Formula, L1 to L4  $L3 = 6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 73.3$ M = (L3 + 10.6)/12.5 + 1Decimal fractions are truncated.  $L1 = M \times 12.5 + 23$ L2 = L1 - 10.5 L4 = (L1 - L3)/2 + 1.3

> n1 = Number of SJ1000 n2 = Number of SJ2000 n3 = Number of SJ3000(A)


Triangle mark location





## Dimensions: SJ1000/2000/3000/4000 Mixed Manifold

#### SS5J4-M60PD<sub>2</sub>-Stations D(S, R)



L dimension: Formula, L1 to L4  $L3 = 6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 15 \times n4 + 77.3$ M = (L3 + 10.6)/12.5 + 1Decimal fractions are truncated.  $L1 = M \times 12.5 + 23$ L2 = L1 - 10.5L4 = (L1 - L3)/2 + 1.3


> n1 = Number of SJ1000 n2 = Number of SJ2000n3 = Number of SJ3000 n4 = Number of SJ4000

D side U side Manual override DIN rail holding screw (4 locations) Push-turn locking slotted type: (M3)(Light/surge Press, then rotate it. 4(A) port side: Blue Switch for locking a connector voltage suppresso (\$J2000) (\$J2000)] (\$J3000)] 2(B) port side: Yellow DIN rail (SJ4000 15.5 16.1 56. 35 20.8 52 (\$J2000)] 4 (SJ1000)9.1 (13.8) (8.6) (20.8) (SJ4000) (5.3)L2 (DIN rail mounting hole pitch: 12.5)

with strain relief (MIL-C-83503 compliant) Triangle mark location

Applicable connector: 26-pin MIL type


SS5J4-M60PD<sub>2</sub>-Stations U(S, R)



L dimension: Formula, L1 to L4  $L3 = 6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 15 \times n4 + 92.8$ M = (L3 + 10.6)/12.5 + 1Decimal fractions are truncated. L1 = M x 12.5 + 23 L2 = L1 - 10.5L4 = (L1 - L3)/2 + 1.3

> n1 = Number of SJ1000 n2 = Number of SJ2000 n3 = Number of SJ3000 n4 = Number of SJ4000

Applicable connector: 26-pin MIL type with strain relief (MIL-C-83503 compliant)



Triangle mark location

57

16.1 17.2

80.

(\$J2000)] (SJ1000)

(9)

(9.1)

(5.3)

(1.8)

(DIN rail mounting hole pitch: 12.5)



15.5

14.7)

56.2

52.


8

(20

# Plug-in Connector Type/Cable Type D-sub Connector/Flat Ribbon Cable SJ1000/2000/3000/4000 Series

## Dimensions: SJ1000/2000/3000/4000 Mixed Manifold

#### SS5J4-M60PD<sub>2</sub>-Stations B(S, R)





L dimension: Formula, L1 to L4  $L3 = 6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 15 \times n4 + 108.3$ M = (L3 + 10.6)/12.5 + 1Decimal fractions are truncated.  $L1 = M \times 12.5 + 23$ L2 = L1 - 10.5 L4 = (L1 - L3)/2 + 1.3

> n1 = Number of SJ1000 n2 = Number of SJ2000

> n3 = Number of SJ3000


n4 = Number of SJ4000





## Dimensions: SJ2000 with Elbow Fittings

SS5J2-60FD<sub>2</sub>-Stations U<sub>B</sub>



## Dimensions: SJ3000 with Elbow Fittings

#### SS5J3-60FD<sub>2</sub>-Stations U<sub>B</sub>

#### [External pilot specification] One-touch fitting (PE: Pilot EXH port) 20.5 Applicable tubing O.D.: Ø 4 One-touch fitting (Station 1)----(Station n) (X: External pilot port) Applicable tubing O.D.: Ø 4 (LN7: 56.5) (L6: 54 (38.9) 50.9 (53.9) LN7: 53.6 L6: 51.1 (57.6)55.3 LN7: 36.9 L6: 34.4 LN7: 39.8 L6: 37.3 35.9 (Pitch) P = 1023.6 SS5J3-60LFD<sub>2</sub>-Stations U<sub>B</sub> Cable type [SUP/EXH block (External pilot specification)] SS5J3-60LFD2-Stations UB Cable type D side U side **(** 48.8 58. 20.8 27.6 35.2 4(A) port 1(P) port 2(B) port 3/5(E) port One-touch fitting Downward (B type) [2(B), 4(A) port] One-touch fitting Applicable tubing O.D.: Ø 2, Ø 1/8" [1(P), 3/5(E) port] [SUP/EXH block (External pilot specification)] [Valve] Ø 4, Ø 5/32" Applicable tubing O.D.: Ø 8 Ø 6, Ø 1/4" Inch sizes for elbow fittings are not available. BN7: 9 B6: 6.5 BN7: 6.1 B6: 3.6 2(B) port ∏ 3/5(E) port 4(A) 1(P) (BN7: 7.7 B6: 10.2 port BN7: 10.6 B6: 13.1 (7.3)10.3 46.2 54.5

58.2

## Plug-in Connector Type

# **EX180 Integrated Type**







# Type 60S SJ10000/2000/3000 Series

**How to Order** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

# SS5J3-60SV

#### Series

1	SJ1000
2	SJ2000
	SJ3000
3	(SJ1000/2000/
	3000 mixed*1)

\*1 Select "3" for the combination of SJ1000 and SJ2000 valves

#### Mixed mounting type

_	Standard*1					
M	Mixed mounting*2					
*1 For S	SJ1000, 2000, and 3000					

- series valves, leave blank when only using a single series.
- \*2 Select "M" when SJ1000, SJ2000, or SJ3000 series valves will be mounted on the same manifold base together.

#### Component module

0	Without SI unit	
V2	CC-Link (32 points)	
Q2 DeviceNet® (32 points		
Q3	DeviceNet® (16 points)	

\* Please contact SMC for SI unit specifications

#### Communication connector

_	T-branch type
Α	Straight type

\* The communication connector and power connector are shipped together with the manifold. The power connector is only available for the straight

#### SI unit common specification

_	Positive common
N	Negative common

### **6** Unit mounting position

#### D side

#### Valve stations

Symbol	Stations	Note
01	1 station	Lin to OO colonoido
- ;	:	Up to 32 solenoids can be selected.
32	32 stations	can be selected.

This number also includes the blanking block Since single and double wiring are available for the blanking block, select a model compatible with the valve wiring specification to be used. (Refer to page 105.)

#### 8 SUP/EXH block mounting position

<b>U</b> U side		
D	D side	
<b>B</b> Both sides		
M*1 Special specification		

\*1 Specify the required specifications (including port sizes other than Ø 8) on the manifold specification sheet.

#### Pilot type

_	Internal pilot	
S	Internal pilot, Built-in silencer	
R	External pilot	
RS	External pilot, Built-in silencer	

- There is no need to enter anything when the SUP/EXH block mounting position "M" is selected.
- The 3/5 (E) port is plugged for the built-in silencer type.

#### DIN rail length specified

_	Standard length			
2	2 stations Specify a length			
:	:	longer than that of the standard rail.		
32	32 stations			

Specify the number of valve stations without exceeding the max. number of stations.


#### SUP/EXH block fitting specification

	comoditori
	Straight fitting
_	With external pilot spec. X, PE port: Elbow fitting
	Elbow fitting (Upward)
L	With external pilot spec. X, PE port: Straight fitting
	Elbow fitting (Downward)
В	With external pilot spec. X, PE port: Elbow fitting

There is no need to enter anything when the SUP/EXH block mounting position

## Ordering example (SS5J3-60SV2□-□)

**How to Order Manifold Assembly** 



SS5J3-60SV2D-06D ...... 1 set (Manifold part no.) SJ3160-5CU-C6 ...... 2 sets (Single solenoid part no.) \* SJ3260-5CU-C6 ...... 2 sets (Double solenoid part no.) SJ3260-5CZJ-C6-----1 set (Double solenoid, with switch part no.) SJ3260-5MZ-C6 ...... 1 set (Double solenoid, individual wiring/ lead wire length 300 mm part no.)

The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the solenoid valves, etc.

- For the valve arrangement, the valve closest to the D side is considered the 1st station. · Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.
- \* When ordering a manifold, specify the part nos. of the valves to be mounted on it. (An order cannot be placed with only the manifold part no.)

#### 01 11-- '4 D - -4 N - -

SI Unit	Jnit Part Nos. Will is selected.				
Symbol	Component module/Communication connector	Common specification	SI unit part no.		
V2	CC-Link (32 points)	NPN output (Positive common)	EX180-SMJ3		
V2N	T-branch type	PNP output (Negative common)	EX180-SMJ5		
V2A	CC-Link (32 points)	NPN output (Positive common)	EX180-SMJ3A		
V2AN	Straight type	PNP output (Negative common)	EX180-SMJ5A		
Q2	DeviceNet® (32 points)	NPN output (Positive common)	EX180-SDN3		
Q2N	T-branch type	PNP output (Negative common)	EX180-SDN5		
Q2A	DeviceNet® (32 points)	NPN output (Positive common)	EX180-SDN3A		
Q2AN	Straight type	PNP output (Negative common)	EX180-SDN5A		
Q3	DeviceNet® (16 points)	NPN output (Positive common)	EX180-SDN4		
Q3N	T-branch type	PNP output (Negative common)	EX180-SDN6		
Q3A	DeviceNet® (16 points)	NPN output (Positive common)	EX180-SDN4A		
Q3AN	Straight type	PNP output (Negative common)	EX180-SDN6A		


Item		Specification	
Power source	Non-polar	24 VDC +10 %/-5 %	
for driving valve	With power-saving circuit (Continuous duty)	24 VDC +10 %/0 %	

For details on the EX180 Integrated Type (For Output) Serial Transmission System, refer to the Catalogue on https://www.smc.eu and the Operation Manual. Please download the Operation Manual via the SMC website: https://www.smc.eu



## EX180 Integrated Type (For Output) Serial Transmission System SJ1000/2000/3000 Series

#### **How to Order Solenoid Valves**



#### Series

#### SJ1000 SJ2000 3 SJ3000

#### 2 Type of actuation

1	2-position single solenoid	Α	Dual 3-port valve: N.C./N.C.
2	2-position double solenoid	В	Dual 3-port valve: N.O./N.O.
3	3-position closed center	С	Dual 3-port valve: N.C./N.O.
4	3-position exhaust center		
5	3-position pressure center		

- Refer to pages 18 to 21 for the symbol.
- The large flow type ("A") is available only for actuation types "1" and "2."

#### 6 Coil type

Symbol	Coil type	SJ1000	SJ2000	SJ3000(A)
_	Standard	_		
Т	T With power-saving circuit (Continuous duty type)		•	•


- Be sure to select the power-saving circuit type if the valve is to be continuously energized for long periods of time.
- For the SJ1000 series, only the power-saving circuit type is available.

# Standard flow type

- A\*1 Large flow type
- \*1 SJ3000 series only

### Pilot type

dual 3-port valves.



Internal pilot

#### Back pressure check valve None

Built-in


*	3 -position and large flow type ("A")
	solenoid valves cannot be equipped
	with a hack proceure check valve

#### Rated voltage 5 24 VDC

#### Common specification Positive common

- Negative common
- Leave blank for the non-polar type.
- When the standard valve and valve with a switch are used, select a common specification that matches the SI unit common specification.

## 9 Connector entry



- Connector entries with the symbol "M\sum cannot use the switch signal from the common wiring on the manifold. For details, refer to the "Connector Wiring Diagram" on page 17.
- When ordering a connector separately, refer to pages 144 and 145.

#### Light/surge voltage suppressor

Symbol	Specification	SJ1000	SJ2000	SJ3000(A)	
U	With light/surge voltage				
U	suppressor (Non-polar type)				
Z	With light/surge voltage				Ì
	suppressor (Polar type)				

- When the type with a power-saving circuit, with a switch, or with individual wiring is used, the non-polar type cannot be selected.
- Select "CU" or "CZ" for the valve when the SI unit output polarity is (positive common). Select "CU" or "NCZ" for the valve when the SI unit output polarity is N (negative common).

With switch

SJ1000	SJ2000	SJ3000(A)
_	•	•

#### Manual override

Symbol/Specification	SJ1000	SJ2000	SJ3000(A)
-: Non-locking push type	•	•	•
D: Push-turn locking slotted type	•	•	•
F: Slide locking type	_	•	•

## (B) A, B port size

#### Metric/One-touch fitting

							iiig		
Symbol	Α,	В	poi	rt	SJ1000	SJ2000	SJ3000	SJ3000A	
C2	ŧ	Q	<b>)</b> 2		•	•	•	_	
C4	Straight	Ç	ð 4		•	•	•	•	
C6	S	Q	Ö 6		_	_	•	•	
L2		ntry	Ø	2	_	•	•	_	
L4		Jpward entry	Ø	4	_	•	•	•	
L6	Elbow	Upw	Ø	6	_	_	•	•	
B2	읦	entry	Ø.	2	_	•	•	_	
В4		<b>Jownward entry</b>	Ø	4	_	•	•	•	
В6		Down	Ø	6	_	_	•	•	

Thread piping						
Symbol	A, B port	SJ1000	SJ2000	SJ3000	SJ3000A	
МЗ	M3 x 0.5	_	•	_	_	
M5	M5 x 0.8	_	_	•	•	9


#### Inch/One-touch fitting

IIICII/	ilcii/Oile-toucii ilttiilg								
Symbol		Α,	Вр	ort	SJ1000	SJ2000	SJ3000	SJ3000A	
N1	±		Ø 1	/8"	_	•	•	_	
N3	Straight	,	O 5.	/32"	_	•	•	•	
N7	S		Ø 1	/4"	_	_	•	•	
LN1		ntry	Ø	1/8"	_	•	•		
LN3		<b>Upward entry</b>	Ø	5/32"	_	•	•	•	
LN7			Ø	1/4"	_	_	•	•	
BN1	ᆲ	entry	Ø	1/8"	_	•	•		
BN3		Downward	Ø	5/32"	_	•	•	•	
BN7		Dowr	Ø	1/4"	_	_	•	•	

#### Single solenoid wiring specification

#### Single wiring D Double wiring

\* Leave blank for 2-position double, 3-position, and 4-position solenoid valves. Select "D" only when setting a blank number for wiring. Refer to page 17 for details.





## **Plug-in Connector Type EX180 Integrated Type**





# SJ4000 Series

**How to Order** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

( E UK ROHS

# SS5J4-**60S**

#### Series

SJ4000

#### 2 Mixed mounting type

_	Standard (Dedicated for the SJ4000)				
M	Mixed mounting				

- \* Leave blank when only using a single series.
- Select "M" when SJ1000, SJ2000, or SJ3000 series valves will be mounted on the same manifold base together.

#### Component module

	U	without Si unit
١	/2	CC-Link (32 points)
		DeviceNet® (32 points)
(	23	DeviceNet® (16 points)

\* Please contact SMC for SI unit specifications.

#### 4 Communication connector

_	T-branch type
Α	Straight type

The communication connector and power connector are shipped together with the manifold. The power connector is only available for the straight

#### SI unit common specification

_	Positive common
N	Negative common

#### 6 Unit mounting position

D side

#### Valve stations

Symbol	Stations	Note
01	1 station	Lin to 00 colonside
:	:	Up to 32 solenoids can be selected.
32	32 stations	can be selected.

This number also includes the blanking block. Since single and double wiring are available for the blanking block, select a model compatible with the valve wiring specification to be used. (Refer to page 105.)

#### 8 SUP/EXH block mounting position

U	U side D side	
D		
В	Both sides	
M	Special specifications	

- \* Special specifications (including instructions for port sizes other than the O 10 of the standard SUP/EXH block) must be specified separately on a manifold specification sheet
- \* For 11 or more valve stations. "B" (both sides) is recommended.

### Pilot type

_	Internal pilot	
S	Internal pilot, Built-in silencer	
R	External pilot	


- There is no need to enter anything when the SUP/EXH block mounting position "M" is selected.
- The 3/5(E) port is plugged for the built-in silencer type ("S").
- The SJ4000 does not have the external pilot and built-in silencer ("RS") type

#### DIN rail length specified

_	Standard length		
2	2 stations Specify a length		
:	: longer than that o		
32	32 stations the standard rail.		

Specify the number of valve stations without exceeding the max. number of

## **How to Order Manifold Assembly**



Prefix it to the part numbers of the solenoid valves, etc. For the valve arrangement, the valve closest to the D side is considered the 1st station.

SJ4160-5CU-C8 ......2 sets (Single solenoid part no.)

SJ4260-5CU-C8 ..... 3 sets (Double solenoid part no.) The asterisk denotes the symbol for the assembly

SS5J4-60SV2D-05D ...... 1 set (Manifold part no.)

· Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet. \* When ordering a manifold, specify the part nos, of the valves to be

mounted on it. (An order cannot be placed with only the manifold part no.)

#### SI Unit Part Nos.

Symbol	Component module/Communication connector	Common specification	SI unit part no.
V2	CC-Link (32 points)	NPN output (Positive common)	EX180-SMJ3
V2N	T-branch type	PNP output (Negative common)	EX180-SMJ5
V2A	CC-Link (32 points)	NPN output (Positive common)	EX180-SMJ3A
V2AN	Straight type	PNP output (Negative common)	EX180-SMJ5A
Q2	DeviceNet® (32 points)	NPN output (Positive common)	EX180-SDN3
Q2N	T-branch type	PNP output (Negative common)	EX180-SDN5
Q2A	DeviceNet® (32 points)	NPN output (Positive common)	EX180-SDN3A
Q2AN	Straight type	PNP output (Negative common)	EX180-SDN5A
Q3	DeviceNet® (16 points)	NPN output (Positive common)	EX180-SDN4
Q3N	T-branch type	PNP output (Negative common)	EX180-SDN6
Q3A	DeviceNet® (16 points)	NPN output (Positive common)	EX180-SDN4A
Q3AN	Straight type	PNP output (Negative common)	EX180-SDN6A

Item		Specification
Power source	Non-polar	24 VDC +10 %/-5 %
for driving valve	With power-saving circuit (Continuous duty)	24 VDC +10 %/0 %


For details on the EX180 Integrated Type (For Output) Serial Transmission System, refer to the Catalogue on https://www.smc.eu and the Operation Manual. Please download the Operation Manual via the SMC website: https://www.smc.eu



<sup>\*</sup> For the mixed mounting ("M") of SJ4000 and SJ1000/2000/3000 valves, SJ1000/2000/3000 valves are mounted on the D side of the SJ4000 D side SUP/EXH block.

The SJ4000 series does not have an elbow One-touch fitting.

#### **How to Order Solenoid Valves**



#### Type of actuation

1	2-position single solenoid	
2	2-position double solenoid	
3	3-position closed center	
4	3-position exhaust center	
5	3-position pressure center	
Α	Dual 3-port valve: N.C./N.C.	
В	Dual 3-port valve: N.O./N.O.	
С	Dual 3-port valve: N.C./N.O.	

\* Refer to pages 22 and 23 for the symbol.

#### 2 Pilot type

_	Internal pilot
R	External pilot

 The external pilot specification is not applicable for 4-position dual 3-port valves.

#### 3 Coil type

_	* *
_	Standard
т	With power-saving circuit (Continuous duty type)

\* Be sure to select the powersaving circuit type if the valve is to be continuously energized for long periods of time.

#### 4 Rated voltage

	9	24 400
*	12 V	DC is not available for the
	SJ40	000.

#### **5** Common specification

		•	
	_	Positive common	
	N	Negative common	

 Leave blank for the non-polar type.

#### **6** Connector entry


C Dedicated for centralized wiring

## Light/surge voltage suppressor

With light/surge voltage suppre (Non-polar type)	
Z	With light/surge voltage suppressor (Polar type)

 When the type with a power-saving circuit is used, the non-polar type cannot be selected.

#### 8 Manual override



#### **9** A, B port size Metric/One-touch fitting

C6	Straight	Ø6	
C8		Ø 8	

# Single solenoid wiring specification

	ing opcomoducion
_	Single wiring
D	Double wiring


 Leave blank for 2-position double, 3-position, and 4-position solenoid valves.


- \* SJ4000 series valves cannot be not equipped with a back pressure check valve.
- \* The SJ4000 series does not have an A, B port inch-size or elbow One-touch fitting.

## Dimensions: SJ1000 for EX180 Integrated Type (For Output) Serial Transmission System

#### SS5J1-60S D-Stations U(S, R, RS)

#### [External pilot specification] One-touch fitting (PE: Pilot EXH port) One-touch fitting Applicable tubing O.D.: Ø 4 [4(A), 2(B) port] 6.2 20.5 Applicable tubing O.D.: Ø 2, Ø 4 Communication connector One-touch fitting (Shipped together with manifold) [1(P), 3/5(E) port] Applicable tubing O.D.: Ø 8 (38.6) 58.2 54.5 (48.8)Straight type: 46.2 32 30. 5.6 Ground terminal (Pitch) P = 6.523.6 МЗ One-touch fitting Power connector (X: External pilot port) Applicable tubing O.D.: Ø 4 (Shipped together with manifold)






SOL.a: Red SOL.b: Green Push type manual override: 40.3 Locking type manual override: 40.5


L: Din	nensio	ns						OOL.D.	GIOOII						r	n: Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223
L2	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5
L3	94.7	101.2	107.7	114.2	120.7	127.2	133.7	140.2	146.7	153.2	159.7	166.2	172.7	179.2	185.7	192.2
L4	14	17	14	17	13.5	16.5	13.5	16.5	13	16	13	16	12.5	15.5	12.5	15.5


L_n	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	223	235.5	235.5	248	248	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323
L2	212.5	225	225	237.5	237.5	250	262.5	262.5	275	275	287.5	287.5	300	300	312.5	312.5
L3	198.7	205.2	211.7	218.2	224.7	231.2	237.7	244.2	250.7	257.2	263.7	270.2	276.7	283.2	289.7	296.2
L4	12	15	12	15	11.5	14.5	17.5	14.5	17.5	14	17	14	17	13.5	16.5	13.5

## Dimensions: SJ1000 for EX180 Integrated Type (For Output) Serial Transmission System

#### SS5J1-60S D-Stations B(S, R, RS)







L: Dimensions

SOL.b: Green n: Stations 3 4 5 8 9 10 11 12 13 14 15 16 6 L1 135.5 148 148 160.5 160.5 185.5 185.5 210.5 210.5 223 235.5 173 173 198 223 235.5 L2 125 137.5 137.5 150 150 162.5 162.5 175 175 187.5 200 200 212.5 212.5 225 225 L3 110.2 116.7 123.2 129.7 136.2 142.7 149.2 155.7 162.2 168.7 175.2 181.7 188.2 194.7 201.2 207.7 L4 12.5 15.5 12.5 15.5 12 15 12 15 11.5 14.5 17.5 14.5 17.5 14 17 14


SOL.a: Red

L	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5
L2	237.5	237.5	250	250	262.5	262.5	275	275	287.5	287.5	300	300	312.5	312.5	325	325
L3	214.2	220.7	227.2	233.7	240.2	246.7	253.2	259.7	266.2	272.7	279.2	285.7	292.2	298.7	305.2	311.7
L4	17	13.5	16.5	13.5	16.5	13	16	13	16	12.5	15.5	12.5	15.5	12	15	12

## Dimensions: SJ2000 for EX180 Integrated Type (For Output) Serial Transmission System

#### SS5J2-60S D-Stations U(S, R, RS)

67





L: Din	nensio	ns													r	n: Stations
L n	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	123	135.5	135.5	148	160.5	160.5	173	173	185.5	198	198	210.5	210.5	223	235.5	235.5
L2	112.5	125	125	137.5	150	150	162.5	162.5	175	187.5	187.5	200	200	212.5	225	225
L3	95.7	103.2	110.7	118.2	125.7	133.2	140.7	148.2	155.7	163.2	170.7	178.2	185.7	193.2	200.7	208.2
L4	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5
L	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	248	248	260.5	273	273	285.5	285.5	298	310.5	310.5	323	323	335.5	348	348	360.5
L2	237.5	237.5	250	262.5	262.5	275	275	287.5	300	300	312.5	312.5	325	337.5	337.5	350
L3	215.7	223.2	230.7	238.2	245.7	253.2	260.7	268.2	275.7	283.2	290.7	298.2	305.7	313.2	320.7	328.2
L4	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5	16

# Plug-in Connector Type EX180 Integrated Type (For Output) Serial Transmission System SJ1000/2000/3000 Series

## Dimensions: SJ2000 for EX180 Integrated Type (For Output) Serial Transmission System

#### SS5J2-60S D-Stations B(S, R, RS)





\* For manifold dimensions including elbow fitting, refer to page 59. Refer to the Web Catalog for details on the SI unit.

Height to manual override

Push type manual override: 40.3

Locking type manual override: 40.5

L: Dim	nensio	ns								i telei to	ule Web C	atalog ioi	details on	tile of till		n: Stations
L n	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	135.5	148	160.5	160.5	173	173	185.5	198	198	210.5	210.5	223	235.5	235.5	248	248
L2	125	137.5	150	150	162.5	162.5	175	187.5	187.5	200	200	212.5	225	225	237.5	237.5
L3	111.2	118.7	126.2	133.7	141.2	148.7	156.2	163.7	171.2	178.7	186.2	193.7	201.2	208.7	216.2	223.7
L4	12	14.5	17	13.5	16	12	14.5	17	13.5	16	12	14.5	17	13.5	16	12
L	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	260.5	273	273	285.5	285.5	298	310.5	310.5	323	323	335.5	348	348	360.5	360.5	373
L2	250	262.5	262.5	275	275	287.5	300	300	312.5	312.5	325	337.5	337.5	350	350	362.5
L3	231.2	238.7	246.2	253.7	261.2	268.7	276.2	283.7	291.2	298.7	306.2	313.7	321.2	328.7	336.2	343.7
L4	14.5	17	13.5	16	12	14.5	17	13.5	16	12	14.5	17	13.5	16	12	14.5


Slide locking to


SOL.a: Red

SOL.b: Green

## Dimensions: SJ3000 for EX180 Integrated Type (For Output) Serial Transmission System

#### SS5J3-60S D-Stations U(S, R, RS)







SOL.b: Green \* For manifold dimensions including elbow fitting, refer to page 60. Refer to the Web Catalog for details on the SI unit.


L: Dim	nensio	ns													r	n: Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	123	135.5	148	160.5	173	173	185.5	198	210.5	223	235.5	235.5	248	260.5	273	285.5
L2	112.5	125	137.5	150	162.5	162.5	175	187.5	200	212.5	225	225	237.5	250	262.5	275
L3	98.2	108.2	118.2	128.2	138.2	148.2	158.2	168.2	178.2	188.2	198.2	208.2	218.2	228.2	238.2	248.2
L4	12.5	13.5	14.5	16	17	12	13	14	15.5	16.5	17.5	12.5	13.5	15	16	17
L	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	285.5	298	310.5	323	335.5	348	348	360.5	373	385.5	398	398	410.5	423	435.5	448
L2	275	287.5	300	312.5	325	337.5	337.5	350	362.5	375	387.5	387.5	400	412.5	425	437.5
L3	258.2	268.2	278.2	288.2	298.2	308.2	318.2	328.2	338.2	348.2	358.2	368.2	378.2	388.2	398.2	408.2
L4	12	13	14.5	15.5	16.5	17.5	12.5	14	15	16	17	12	13.5	14.5	15.5	16.5
69	ØSWC.															

## Dimensions: SJ3000 for EX180 Integrated Type (For Output) Serial Transmission System

#### SS5J3-60S D-Stations B(S, R, RS)








L: Dim	ensio	ns							SOL.a:	: Green					r	n: Stations
L n	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	148	148	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	260.5	273	285.5	298
L2	137.5	137.5	150	162.5	175	187.5	200	200	212.5	225	237.5	250	250	262.5	275	287.5
L3	113.7	123.7	133.7	143.7	153.7	163.7	173.7	183.7	193.7	203.7	213.7	223.7	233.7	243.7	253.7	263.7
L4	17	12	13	14.5	15.5	16.5	17.5	12.5	14	15	16	17	12	13.5	14.5	15.5
L	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	310.5	310.5	323	335.5	348	360.5	373	373	385.5	398	410.5	423	423	435.5	448	460.5
L2	300	300	312.5	325	337.5	350	362.5	362.5	375	387.5	400	412.5	412.5	425	437.5	450
L3	273.7	283.7	293.7	303.7	313.7	323.7	333.7	343.7	353.7	363.7	373.7	383.7	393.7	403.7	413.7	423.7
L4	16.5	11.5	13	14	15	16	17.5	12.5	13.5	14.5	15.5	17	12	13	14	15

## SJ4000 Series

## Dimensions: SJ4000 for EX180 Integrated Type (For Output) Serial Transmission System

#### SS5J4-60S - Stations D(S, R)

#### [External pilot specification] One-touch fitting [PE: Pilot EXH port] Applicable tubing O.D.: Ø 4 One-touch fitting [X: External pilot port] One-touch fitting [1(P), 3/5(E) port] Applicable tubing O.D.: Ø 10 Applicable tubing O.D.: Ø 4 61.5 Communication connector (Shipped together with manifold) (Station 1) (Station n) Straight type: 38.6) 68.2 56.2 (48.8) 20 36.5 4 Ground terminal One-touch fitting М3 [4(A), 2(B) port] Power connector Applicable tubing O.D.: Ø 6, Ø 8 (Shipped together with manifold)



\* Refer to the **Web Catalog** for details on the SI unit.


L: Dim	nensio	ns													r	n: Stations
L n	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	135.5	148	160.5	185.5	198	210.5	223	235.5	260.5	273	285.5	298	310.5	335.5	348	360.5
L2	125	137.5	150	175	187.5	200	212.5	225	250	262.5	275	287.5	300	325	337.5	350
L3	107.2	122.2	137.2	152.2	167.2	182.2	197.2	212.2	227.2	242.2	257.2	272.2	287.2	302.2	317.2	332.2
L4	14	13	11.5	16.5	15.5	14	13	11.5	16.5	15.5	14	13	11.5	16.5	15.5	14
L	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	373	385.5	410.5	423	435.5	448	460.5	485.5	498	510.5	523	535.5	560.5	573	585.5	598
L2	362.5	375	400	412.5	425	437.5	450	475	487.5	500	512.5	525	550	562.5	575	587.5
L3	347.2	362.2	377.2	392.2	407.2	422.2	437.2	452.2	467.2	482.2	497.2	512.2	527.2	542.2	557.2	572.2
L4	13	11.5	16.5	15.5	14	13	11.5	16.5	15.5	14	13	11.5	16.5	15.5	14	13

## Dimensions: SJ4000 for EX180 Integrated Type (For Output) Serial Transmission System

#### SS5J4-60S - Stations B(S, R)

#### [External pilot specification]

<For SUP/EXH block mounting position "B" (both sides): There are piping of X and PE ports on both sides.>




#### \* Refer to the Web Catalog for details on the SI unit.

#### L: Dimensions

L. DIII	iensio	115														
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	148	173	185.5	198	210.5	223	248	260.5	273	285.5	298	323	335.5	348	360.5	373
L2	137.5	162.5	175	187.5	200	212.5	237.5	250	262.5	275	287.5	312.5	325	337.5	350	362.5
L3	122.7	137.7	152.7	167.7	182.7	197.7	212.7	227.7	242.7	257.7	272.7	287.7	302.7	317.7	332.7	347.7
L4	12.5	17.5	16.5	15	14	12.5	17.5	16.5	15	14	12.5	17.5	16.5	15	14	12.5
L n	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L n	<b>17</b> 398	<b>18</b> 410.5	<b>19</b> 423	<b>20</b> 435.5	<b>21</b> 448	<b>22</b> 473	<b>23</b> 485.5	<b>24</b> 498	<b>25</b> 510.5	<b>26</b> 523	<b>27</b> 548	<b>28</b> 560.5	<b>29</b> 573	<b>30</b> 585.5	<b>31</b> 598	<b>32</b> 623
L	17															
L1	398	410.5	423	435.5	448	473	485.5	498	510.5	523	548	560.5	573	585.5	598	623




## Dimensions: SJ1000/2000/3000 Mixed Manifold



**SMC** 


## Dimensions: SJ4000 Mixed Manifold

#### SS5J4-M60S - Stations D(S, R)




n2 = Number of SJ2000 n3 = Number of SJ3000

n3 = Number of SJ3000 n4 = Number of SJ4000




#### SS5J4-M60S - Stations U(S, R)



**多SMC** 


## Dimensions: SJ4000 Mixed Manifold

#### SS5J4-M60S - Stations B(S, R)



L dimension: Formula, L1 to L4 L3 =  $6.5 \times n1 + 7.5 \times n2 + 10 \times n3 + 15 \times n4 \times 138.7$ M = (L3 + 4)/12.5 + 1 Decimal fractions are truncated. L1 = M x 12.5 + 23 L2 = L1 - 10.5 L4 = (L1 - L3)/2 - 2

> n1 = Number of SJ1000 n2 = Number of SJ2000 n3 = Number of SJ3000 n4 = Number of SJ4000





## **Plug-in Connector Type** CE CK S **EX510 Gateway Type Serial Transmission System** (RoHS)

Type 60S6B SJ10000/2000/3000 Series

**How to Order Manifolds** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.



#### Manifold series

1	SJ1000
2	SJ2000
3	SJ3000 (SJ1000/2000/3000 mixed*1)

\*1 Select "3" for the combination of SJ1000 and SJ2000 valves.

#### 2 Mixed mounting type

• ····································	
_	Standard*1
M	Mixed mounting*2

- \*1 For SJ1000, 2000, and 3000 series valves. leave blank when only using a single series.
- \*2 Select "M" when SJ1000, SJ2000, or SJ3000 series valves will be mounted on the same manifold base together.

#### 3 SI unit common specification

_	Positive common
N	Negative common

4 Unit mounting position

<b>D</b> D side
-----------------

#### Valve stations

Symbol	Stations	Note				
01	1 station					
i	:	Up to 16 solenoids can be selected.				
16	16 stations					

This number also includes the blanking block. Since single and double wiring are available for the blanking block, select a model compatible with the valve wiring specification to be used.

#### 6 SUP/EXH block mounting position

U	U side
D	D side
В	Both sides
M*1	Special specifications

Specify the required specifications (including port sizes other than Ø 8) on the manifold specification sheet.

#### Pilot type

_	Internal pilot
S	Internal pilot, Built-in silencer
R	External pilot
RS	External pilot, Built-in silencer

- There is no need to enter anything when the SUP/ EXH block mounting position "M" is selected.
- The 3/5(E) port is plugged for the built-in silencer

#### 8 SUP/EXH block fitting specification

-	_		L		В
Straight fitting		Elbow fitting (Upwa	ard)	Elbow fitting (Do	ownward)
With external		With external		With external	
pilot spec.		pilot spec.		pilot spec.	
X, PE port:		X, PE port:		X, PE port:	
Elbow fitting		Straight fitting		Elbow fitting	

\* There is no need to enter anything when the SUP/EXH block mounting position "M" is selected.

#### 9 DIN rail length specified

_	Standard length		
2	2 stations	Specify a length	
:	:	longer than that of	
16	16 stations	the standard rail.	


Specify the number of valve stations without exceeding the max. number of stations.

#### SI Unit Part Nos.

Symbol	SI unit specification	SI unit part no.
_	NPN output (Positive common)	EX510-S002C
N	PNP output (Negative common)	EX510-S102C

For details on the EX510 Gateway Type Serial Transmission System, refer to the Catalogue on https://www.smc.eu and the Operation Manual. Please download the Operation Manual via the SMC website: https://www.smc.eu


#### **How to Order Manifold Assembly**



- SS5J3-60S6BD-05U .......... 1 set (Type 60S6B, 5-station manifold base part no.) SJ3160-5CU-C6 ...... 2 sets (Single solenoid part no.)
- SJ3260-5CU-C6 ...... 3 sets (Double solenoid part no.)
- The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the solenoid valves, etc.
- For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.
- When ordering a manifold, specify the part nos. of the valves to be mounted on it. (An order cannot be placed with only the manifold part no.)

## EX510 Gateway Type Serial Transmission System SJ1000/2000/3000 Series

#### **How to Order Solenoid Valves**



#### Series

3

#### SJ1000 SJ2000 3 SJ3000

#### Type of actuation

1	2-position single solenoid
2	2-position double solenoid
3	3-position closed center
4	3-position exhaust center
5	3-position pressure center

- Refer to pages 18 to 21 for the symbol.
- The large flow type ("A") is available only for actuation types "1" and "2."

Α

B

## 4 Pilot type

_	Standard flow type	_	
<b>A</b> *1	Large flow type	R	Ī

\*1 SJ3000 series only

- Internal pilot External pilot
- The external pilot specification is not applicable for 4-position dual 3-port valves.

## Back pressure check valve

Dual 3-port valve: N.C./N.C.

Dual 3-port valve: N.O./N.O.

Dual 3-port valve: N.C./N.O.

	_	None
	K	Built-in
*	3 -posit	ion and large flow type ("A"

solenoid valves cannot be equipped with a back pressure check valve.

#### 6 Coil type

Symbol	Coil type	SJ1000	SJ2000	SJ3000(A)
_	Standard	_		
Т	With power-saving circuit (Continuous duty type)	•	•	•

- Be sure to select the power-saving circuit type if the valve is to be continuously energized for long periods of time.
- For the SJ1000 series, only the power-saving circuit type is available.


#### Rated voltage

#### Common specification

**5** 24 VDC Positive common Negative common

- Leave blank for the non-polar type.
- When the standard valve and valve with a switch are used, select a common specification that matches the SI unit common specification.

#### 9 Connector entry



- Connector entries with the symbol "M $\square$ " cannot use the switch signal from the common wiring on the manifold. For details, refer to the "Connector Wiring Diagram" on page 17.
- When ordering a connector separately, refer to pages 144 and 145.

## Light/surge voltage suppressor


Symbol	Specification	SJ1000	SJ2000	SJ3000(A)
U	With light/surge voltage			
U	suppressor (Non-polar type)			
Z	With light/surge voltage			
	suppressor (Polar type)	•		

- When the type with a power-saving circuit, with a switch, or with
- individual wiring is used, the non-polar type cannot be selected. Select "CU" or "CZ" for the valve when the SI unit output polarity is (positive common). Select "CU" or "NCZ" for the valve when the SI unit output polarity is N (negative common).

#### With switch

	SJ1000	SJ2000	SJ3000(A)
	_	•	•

#### Manual override



#### A, B port size

Metric/One-touch fitting  Symbol A, B port   SJ1000   SJ2000   SJ3000   SJ3000													
Symbol	A,	В	рс	rt	SJ1000	SJ2000	SJ3000	SJ3000A					
C2	ŧ	Q	) 2	2	•	•	•	_					
C4	Straight	Ç	<b>5</b> 4	ļ	•	•	•	•					
C6	S	Ø 6		6	_	_	•	•					
L2		entry	Ø	2	_	•	•	_					
L4		Jpward e	Ø	4	_	•	•	•					
L6	Elbow	_	Ø	6	_	_	•	•					
B2	ell	ᆲ	entry	Ø	2		•	•		TO THE PARTY OF TH			
В4		ownward	Ø	4	_	•	•	•					
В6		Down	Ø	6	_	_	•	•					

#### Thread piping

Symbol	A, B port	SJ1000	SJ2000	SJ3000	SJ3000A	
МЗ	M3 x 0.5	_	•	_	_	
M5	M5 x 0.8		_	•	•	9


#### Inch/One-touch fitting

IIICII/	U	HE	:-נט	ucn	HUUH	ıg													
Symbol		Α,	Вр	ort	SJ1000	SJ2000	SJ3000	SJ3000A											
N1	ļ_		Ø 1/8"		_	•	•	_											
N3	Straight	Ø 5/32"		Ø 5/32"		Ø 5/32"		Ø 5/32"		Ø 5/32"		Ø 5/32"		Ø 5/32"		•	•	•	
N7	S		Ø 1	/4"	_	_	•	•											
LN1		entry	Ø	1/8"	_	•	•	_											
LN3			Ø	5/32"	_	•	•	•											
LN7	Elbow	Upward	Ø	1/4"	_	_	•	•											
BN1	H	entry	Ø	1/8"	_	•	•	_	TO THE REAL PROPERTY OF THE PARTY OF THE PAR										
BN3			Ø	5/32"	_	•	•	•											
BN7		Downward	Ø	1/4"	_	_	•	•											

#### Single solenoid wiring specification

_	Single wiring
D	Double wiring


\* Leave blank for 2-position double, 3-position, and 4-position solenoid valves. Select "D" only when setting a blank number for wiring. Refer to page 16 for details








## Dimensions: SJ1000 for EX510 Gateway Type Serial Transmission System

#### SS5J1-60S6B D-Stations U(S, R, RS)












L: Din	L: Dimensions n: Stat															n: Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	135.5	148	148	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5
L2	125	137.5	137.5	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5	225	225
L3	111.9	118.4	124.9	131.4	137.9	144.4	150.9	157.4	163.9	170.4	176.9	183.4	189.9	196.4	202.9	209.4
L4	12	15	11.5	14.5	17.5	14.5	17.5	14	17	14	17	13.5	16.5	13.5	16.5	13

## Dimensions: SJ1000 for EX510 Gateway Type Serial Transmission System

#### SS5J1-60S6B D-Stations B(S, R, RS)










L: Din	n: Station															n: Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248
L2	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5	225	225	237.5	237.5
L3	127.4	133.9	140.4	146.9	153.4	159.9	166.4	172.9	179.4	185.9	192.4	198.9	205.4	211.9	218.4	224.9
1.4	16.5	13.5	16.5	13	16	13	16	12.5	15.5	12.5	15.5	12	15	12	15	11.5

## Dimensions: SJ2000 for EX510 Gateway Type Serial Transmission System

#### SS5J2-60S6B D-Stations U(S, R, RS)







\*1 Height to manual override
Push type manual override: 40.3
Locking type manual override: 40.5

Switch

(When equipped with switch)


Light/surge voltage suppressor)
SOL.a: Red
SOL.b: Green

L: I	L: Dimensions														n: Stations		
L	n	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L	1	148	148	160.5	160.5	173	185.5	185.5	198	198	210.5	223	223	235.5	248	248	260.5
L	2	137.5	137.5	150	150	162.5	175	175	187.5	187.5	200	212.5	212.5	225	237.5	237.5	250
L	3	112.9	120.4	127.9	135.4	142.9	150.4	157.9	165.4	172.9	180.4	187.9	195.4	202.9	210.4	217.9	225.4
L	4	17.5	14	16.5	12.5	15	17.5	14	16.5	12.5	15	17.5	14	16.5	19	15	17.5

81

## Dimensions: SJ2000 for EX510 Gateway Type Serial Transmission System


#### SS5J2-60S6B D-Stations B-



\* Refer to page 68 for the external pilot specifications and page 59 for the dimensions of the manifold with elbow fittings. Refer to the **Web Catalog** for details on the SI unit.

L: 0	L: Dimensions n: Stations																
L	n 1	2		3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	160.	5 160.	5 17	73	185.5	185.5	198	198	210.5	223	223	235.5	248	248	260.5	260.5	273
L2	150	150	16	62.5	175	175	187.5	187.5	200	212.5	212.5	225	237.5	237.5	250	250	262.5
L3	128.	1 135.	9 14	43.4	150.9	158.4	165.9	173.4	180.9	188.4	195.9	203.4	210.9	218.4	225.9	233.4	240.9
L4	16	12.	5 1	15	17.5	13.5	16	12.5	15	17.5	13.5	16	18.5	15	17.5	13.5	16

## Dimensions: SJ3000 for EX510 Gateway Type Serial Transmission System




<sup>\*</sup> Refer to page 69 for the external pilot specifications and page 60 for the dimensions of the manifold with elbow fittings. Refer to the **Web Catalog** for details on the SI unit.

L: Din	L: Dimensions n: Stations															
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	148	160.5	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	273	273	285.5	298
L2	137.5	150	150	162.5	175	187.5	200	200	212.5	225	237.5	250	262.5	262.5	275	287.5
L3	115.4	125.4	135.4	145.4	155.4	165.4	175.4	185.4	195.4	205.4	215.4	225.4	235.4	245.4	255.4	265.4
L4	16.5	17.5	12.5	14	15	16.5	17.5	12.5	14	15	16.5	17.5	19	14	15	16.5

83

## Dimensions: SJ3000 for EX510 Gateway Type Serial Transmission System




<sup>\*</sup> Refer to page 70 for the external pilot specifications and page 60 for the dimensions of the manifold with elbow fittings. Refer to the **Web Catalog** for details on the SI unit.

L: Din	_: Dimensions n: Stations															
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	160.5	173	185.5	185.5	198	210.5	223	235.5	248	248	260.5	273	285.5	298	298	310.5
L2	150	162.5	175	175	187.5	200	212.5	225	237.5	237.5	250	262.5	275	287.5	287.5	300
L3	130.9	140.9	150.9	160.9	170.9	180.9	190.9	200.9	210.9	220.9	230.9	240.9	250.9	260.9	260.9	280.9
L4	15	16	17.5	12.5	13.5	15	16	17.5	18.5	13.5	15	16	17.5	18.5	13.5	15



## Dimensions: SJ1000/2000/3000 Mixed Manifold for EX510 Gateway Type Serial Transmission System






Switch for locking a connector

(7.3) ( (9.6) (

# SJ1000/2000/3000/4000 Series Manifold Exploded View

## **SJ1000/2000/3000** Connector Type



Component Parts: Plug-in (Connector Type)

No.		Description	Part no.	Note		
		Internal pilot	SJ3000-50-1A-□□	(Metric size)		
		Internal pilot, Built-in silencer	SJ3000-50-1AS-□□	C6: With Ø 6 One-touch fitting (straight)		
		External pilot	SJ3000-50-1AR-□□ (X, PE port: Metric size Ø 4 Inch size Ø 5/32"	C8: With Ø 8 One-touch fitting (straight) L6: With Ø 6 One-touch fitting (elbow upward entry)		
1	SUP/EXH block	External pilot, Built-in silencer	SJ3000-50-1ARS-  (X port: Metric size Ø 4   Inch size Ø 5/32)	B6: With Ø 6 One-touch fitting (elbow downward entry) B8: With Ø 8 One-touch fitting (elbow downward ent (Inch size)		
		For different pressures, Internal pilot*1	SJ3000-50-3A-□□			
		For different pressures, Internal pilot, Built-in silencer*1	SJ3000-50-3AS-□□	N7: With 1/4" One-touch fitting (straight) N9: With 5/16" One-touch fitting (straight)		
2	End block		SJ3000-53-1A	For the U side		
3	Connector block		SJ3000-42-□A-□	Refer to the connector block part nos. shown below.		
4	DIN rail		VZ1000-11-1-□	Refer to page 106.		
5	SI unit		EX180-□□	Refer to the SI unit part nos. on page 61.		
6	O-ring for valve connection*2		SJ3000-96-1A	The part no. shown on the left includes parts for 5 units. (10 pcs. each for the P and E ports and for the X and PE ports)		

<sup>\*1</sup> As the valves cannot be operated only with the SUP/EXH block for different pressures, select them in combination with the SUP/EXH block for internal/external pilot. \*2 Included with valves. SUP/EXH blocks, and connector blocks

#### Connector Block Part Nos.

Connector Block rait 1405.			
Connector specifications	Mounting position	Part no.	Note
For D-sub connector (Locking bracket: Metric size thread)		SJ3000-42-1A-□	
For D-sub connector (Locking bracket: Unified thread)		SJ3000-42-1AU-	
For flat ribbon cable with 26 pins		SJ3000-42-2A-□	□. 1 (O-mat-mm
For flat ribbon cable with 20 pins	D side	SJ3000-42-3A-□	☐: 1 (Connector upward) ☐: 2 (Connector lateral)
For flat ribbon cable with 10 pins		SJ3000-42-4A-	L. 2 (Confidencial fateral)
For EX180 serial wiring*1		SJ3000-42-20A	
For EX510 serial wiring*1		SJ3000-42-3A-2	

<sup>\*1</sup> An SI unit is not included.


#### **Connector Block with SI Unit**

Connector block with EX180 serial wiring D signal	• s	SJ3000-42-20A-□□	For details on the $\square\square$ portion, refer to the SI unit part nos. on page 61. Example: SJ3000-42-20A-V2 (CC-Link compliant, T-branch type)
---	-----	------------------	--



<sup>\*</sup> Refer to page 103 for the SUP/EXH block disk and method of handling parts at different pressures.

## **SJ1000/2000/3000** Cable Type




Component Parts: Plug-in (Cable Type)

No.		Description	Part no.	Note		
		Internal pilot	SJ3000-50-5A-□□	(Metric size)		
		Internal pilot, Built-in silencer	SJ3000-50-5AS-□□	,		
		External pilot	SJ3000-50-5AR-□□ (X, PE port: Metric size Ø 4 Inch size Ø 5/32'	C6: With Ø 6 One-touch fitting (straight) C8: With Ø 8 One-touch fitting (straight) L6: With Ø 6 One-touch fitting (elbow upward entry)		
1	SUP/EXH block	External pilot, Built-in silencer	SJ3000-50-5ARS-□□ (X port: Metric size Ø 4 Inch size Ø 5/32	L8: With Ø 8 One-touch fitting (elbow upward entry) B6: With Ø 6 One-touch fitting (elbow downward entry) B8: With Ø 8 One-touch fitting (elbow downward entry)		
		For different pressures, Internal pilot*1	SJ3000-50-6A-□□	(Inch size)		
		For different pressures, Internal pilot, Built-in silencer*1	SJ3000-50-6AS-□□	N7: With 1/4" One-touch fitting (straight) N9: With 5/16" One-touch fitting (straight)		
2	End block		SJ3000-53-1A	For the U side		
3	Connector block		SJ3000-42-□A-□	Refer to the connector block part nos. shown below.		
4	DIN rail		VZ1000-11-1-□	Refer to page 106.		
5	O-ring for valve connection*2		SJ3000-96-1A	The part no. shown on the left includes parts for 5 units. (10 pcs. each for the P and E ports and for the X and PE ports)		

<sup>\*1</sup> As the valves cannot be operated only with the SUP/EXH block for different pressures, select them in combination with the SUP/EXH block for internal/external pilot. \*2 Included with valves, SUP/EXH blocks, and connector blocks

#### **●**Connector Block



#### Connector type

	71	
7	For D-sub connector	
8	For flat ribbon cable with 26 pins	SJ3000
9	For flat ribbon cable with 20 pins	series
10	For flat ribbon cable with 10 pins	
11	For D-sub connector	
12	For flat ribbon cable with 26 pins	SJ2000
13	For flat ribbon cable with 20 pins	series
14	For flat ribbon cable with 10 pins	

- \* All connector block mounting positions are on the D
- side.

  \* The connector block includes the cables necessary for the number of stations.

#### 2 Locking bracket

_	Metric size thread						
U	Unified thread						
D-sub connector only							

#### 3 Connector entry direction

1	Upward
2	Lateral

#### 4 Wiring

_	All double wiring
S	All single wiring

#### **5** Valve stations


02 to 10	For D-sub connector	All double wiring		
02 to 20	For D-sub connector	All single wiring		
02 to 10	For flat ribbon cable with	All double wiring		
02 to 20	26 pins	All single wiring		
02 to 09	For flat ribbon cable with	All double wiring		
02 to 18	20 pins	All single wiring		
02 to 04	For flat ribbon cable with	All double wiring		
02 to 08	10 pins	All single wiring		



<sup>\*</sup> Refer to page 103 for the SUP/EXH block disk and method of handling parts at different pressures.

## Manifold Exploded View **SJ1000/2000/3000/4000 Series**

## SJ4000 Connector Type



Component Parts: Plug-in (Connector Type)

No.		Description	Part no.	Note
		Internal pilot	SJ4000-50-1A-□□	
	SUP/EXH block (For the U side and intermediate)	Internal pilot, Built-in silencer	SJ4000-50-1AS-□□	(Metric size)
1		External pilot	SJ4000-50-1AR-□□ (X, PE port: Metric size Ø 4)	C8: With Ø 8 One-touch fitting (straight) C10: With Ø 10 One-touch fitting (straight)
		Internal pilot	SJ4000-50-2A-□□	(Metric size) C8: With Ø 8 One-touch fitting (straight)
2	SUP/EXH block (For the D side)	Internal pilot, Built-in silencer	SJ4000-50-2AS-□□	C10: With Ø 10 One-touch fitting (straight) 00: P, E port plug (Excludes the built-in silencer)
		External pilot	SJ4000-50-2AR-□□	* This block is used as the D-side SUP/EXH block for SJ4000 valves and the converter block for SJ1000/2000/3000 valves
3	End block		SJ4000-53-1A	For the U side
4	Connector block		SJ3000-42-□A-□	Refer to the connector block part nos. shown below.
5	DIN rail		VZ1000-11-1-□	Refer to page 106.
6	SI unit		EX180-□□	Refer to the SI unit part nos. on page 61.
7	Seal for valve connection (For the SJ4000)*1		SJ4000-96-1A	The part no. shown on the left includes parts for 5 units. (10 pcs. each for the P and E ports and for the X and PE por
8	Block disk (For the SJ4000)		SJ4000-44-1A	Supplied individually (For the P and E ports)
9	Block plug (For the SJ4000)		SJ4000-44-2A	The part no. shown on the left includes parts for 5 units. (5 pcs. for the X pc

<sup>\*1</sup> Included with valves, SUP/EXH blocks, and connector blocks

#### **Connector Block Part Nos.**

Connector specifications	Mounting position	Part no.	Note
For D-sub connector (Locking bracket: Metric size thread)		SJ3000-42-1A-□	
For D-sub connector (Locking bracket: Unified thread)		SJ3000-42-1AU-	
For flat ribbon cable with 26 pins	D side	SJ3000-42-2A-□	☐: 1 (Connector upward)
For flat ribbon cable with 20 pins	Diside	SJ3000-42-3A-□	☐: 2 (Connector lateral)
For flat ribbon cable with 10 pins		SJ3000-42-4A-□	
For EX180 serial wiring*1		SJ3000-42-20A	

<sup>\*1</sup> An SI unit is not included.

#### **Connector Block with SI Unit**

Connector block with EX180 serial wiring	D side	SJ3000-42-20A-□□	For details on the $\square\square$ portion, refer to the SI unit part nos. on page 61. Example: SJ3000-42-20A-V2 (CC-Link compliant, T-branch type)
--	--------	------------------	---

**SMC** 

> on Common Specifications

Plug-in Const

EX510 EX180 Flat Ribbon

Plug-in

Individ

Manife Optio

SJ3A6

ommon spec. Construction

Plug-in

Flat Ribbon Serial

lug-in


ndividual Wiring

Specific Product Precautions

<sup>\*</sup> For the SJ4000 series, there is no internal pilot specification SUP/EXH block for different pressures. Different pressures can only be used by partitioning the P and E ports and mounting a block plug to the X port. (Refer to the pneumatic circuit diagrams on page 104.)

# SJ1000/2000/3000/4000 series Manifold Exploded View (Mixed Specification)

#### **Connector Type**



#### Component Parts: Plug-in (Connector Type)

No.		Description	Part no.	Note
		Internal pilot	SJ4000-50-1A-□□	
1	SUP/EXH block (For the U side and intermediate)	Internal pilot, Built-in silencer	SJ4000-50-1AS-□□	(Metric size)
		External pilot	<b>SJ4000-50-1AR-</b> □□ (X, PE port: Metric size Ø 4)	C8: With Ø 8 One-touch fitting (straight) C10: With Ø 10 One-touch fitting (straight)
	SUP/EXH block (For the D side)	Internal pilot	SJ4000-50-2A-□□	(Metric size) C8: With Ø 8 One-touch fitting (straight)
2		Internal pilot, Built-in silencer	SJ4000-50-2AS-□□	C10: With Ø 10 One-touch fitting (straight) 00: P, E port plug (Excludes the built-in silencer)
		External pilot	SJ4000-50-2AR-□□	* This block is used as the D-side SUP/EXH block for SJ4000 valves and the converter block for SJ1000/2000/3000 valves.
3	End block		SJ4000-53-1A	For the U side
4	Connector block	Connector block		Refer to the connector block part nos. shown below.
5	DIN rail	DIN rail		Refer to page 106.
6	SI unit		EX180-□□	Refer to the SI unit part nos. on page 61.
7	Seal for valve connection (For the SJ4000)*1		SJ4000-96-1A	The part no. shown on the left includes parts for 5 units. (10 pcs. each for the P and E ports and for the X and PE ports)

<sup>\*1</sup> Included with valves, SUP/EXH blocks, and connector blocks

#### Connector Block Part Nos.

Connector Block Fait Nos.			
Connector specifications	Mounting position	Part no.	Note
For D-sub connector (Locking bracket: Metric size thread)		SJ3000-42-1A-□	
For D-sub connector (Locking bracket: Unified thread)		SJ3000-42-1AU-□	
For flat ribbon cable with 26 pins		SJ3000-42-2A-□	□. 1 (O
For flat ribbon cable with 20 pins	D side	SJ3000-42-3A-□	<ul><li>□: 1 (Connector upward)</li><li>□: 2 (Connector lateral)</li></ul>
For flat ribbon cable with 10 pins		SJ3000-42-4A-□	L. 2 (Confidencial fateral)
For EX180 serial wiring*1		SJ3000-42-20A	
For EX510 serial wiring*1		SJ3000-42-3A-2	

<sup>\*1</sup> An SI unit is not included.

#### **Connector Block with SI Unit**


To initiation and the state of				
Connector block with EX180 serial wiring	D side	SJ3000-42-20A-□□	For details on the $\Box\Box$ portion, refer to the SI unit part nos. on page 61. Example: SJ3000-42-20A-V2 (CC-Link compliant, T-branch type)	



<sup>\*</sup> Contact SMC for details on using the SJ4000 mixed specification (SS5J4-M60 type) under different pressures.

## **How to Increase Manifold Stations**


#### **Connector Type**



- Loosen threads ⓐ, which are fixed onto the DIN rail (two locations on one side).
  - \* To replace the DIN rail, also loosen the screws (2 locations) on the connector block.]
- In the direction of the coil, slide the valve where the station is desired to add and the valve lock switch on each block.

If blocks are removed without completely releasing the valve lock switch, the connection hook of that switch could be damaged or deformed.

Install an additional valve or a SUP/EXH block on the DIN rail.



A manifold equipped with a valve or a block can be mounted on the DIN rail. However, a serial connector block cannot be mounted on the DIN rail when it is connected with another block; the serial connector block must be mounted separately.

Press the valves and blocks to each other for connection. Press the valve lock switch in the cylinder port direction until it does not go any further. Fasten threads ② onto the DIN rail.

After fixing the connector block, fasten the threads onto the end block while holding it lightly by hand. This is necessary to improve sealing.

**⚠** Caution

D-sub, Connector block for flat ribbon cable, End block M3: 0.6 N·m Connector block for EX180 serial wiring M4: 1.4 N·m Mounting bracket for EX510 serial wiring M4: 0.6 N·m

## **.** Caution

- 1. Be sure to turn off the power and stop the supply of air before disassembly. Furthermore, since air may remain inside the actuator, piping, and manifold, confirm that the air is completely exhausted before performing any work.
- After assembly and disassembly, air leakage could occur if blocks are not well connected or a thread is not tightly fastened onto the end block. Before supplying air, make sure that no gaps exist in between blocks and that the valve and block are tightly fastened onto the DIN rail. Also, make sure that air is not leaking before use.
- For the SJ3A6 series manifold with vacuum release valve with restrictor, there is no valve lock switch for connecting, so when mounting, tighten the screws after checking that there are no gaps between valves.

common ecifications

Construction

Plug-in

EX510 EX180 | D-

Plug-in

Individua Wiring

Options

order

SJ3A6

mon Spec.

Plug-in (

D-sub at Ribbon Serial


Non Jug-in

Individual Wiring

Specific Product Precautions



#### Cable Type




#### **⚠** Caution

To increase a manifold station, a housing holder (refer to the table below) is required in addition to the solenoid valve.

For the manifold with less than the max. number of stations, spare housing (for one station) for adding the manifold station is stored in the housing holder of the last station or the SUP/EXH block. To increase a manifold station, follow the steps below to disassemble and reassemble the manifold.

Series	Housing holder part no.		Material	Note
SJ2000	SJ2000-86-1		Resin	White
SJ3000	SJ3000-86-1		Hesin	vvnite

- Loosen threads ②, which are fixed onto the DIN rail (two locations).
- [\* To replace the DIN rail, also loosen the screws (2 locations) on the connector block.]
- Slide the valve lock switch on each block toward the coil, and then remove the end block and SUP/EXH block.
- Take out the stored housing for adding the manifold station and assemble it to a newly added housing holder. Insert this housing holder next to the current housing holder.



Press the valves and blocks to each other for connection.

Press the valve lock switch in the cylinder port direction until it does not go any further. Fasten threads ② onto the DIN rail. Connect the added valve and SUP/EXH block, and then fasten the DIN rail fixing screws on the end block on the U side.

After fixing the connector block, fasten the threads onto the end block while holding it lightly by hand. This is necessary to improve sealing.

⚠ Caution D-sub, Connector block for flat ribbon cable, End block M3: 0.6 N·m

## **∧** Caution


- 1. When adding a valve and SUP/EXH block, add the valve to the U side of the last station, and then add the SUP/EXH block to its U side. The SUP/EXH block cannot be added to a position adjacent to the connector block or an intermediate position.
- 2. Be sure to turn off the power and stop the supply of air before disassembly. Furthermore, since air may remain inside the actuator, piping, and manifold, confirm that the air is completely exhausted before performing any work.
- 3. After assembly and disassembly, air leakage could occur if blocks are not well connected or a thread is not tightly fastened onto the end block. Before supplying air, make sure that no gaps exist in between blocks and that the valve and block are tightly fastened onto the DIN rail. Also, make sure that air is not leaking before use.
- 4. For the SJ3Ã6 series manifold with vacuum release valve with restrictor, there is no valve lock switch for connecting, so when mounting, tighten the screws after checking that there are no gaps between valves.



## SJ4000 Series

## **How to Increase Manifold Stations**

#### **Connector Type**




1 Loosen threads @, which are fixed onto the DIN rail (two locations on one side).

[\* To replace the DIN rail, also loosen the screws (2 locations) on the connector block.]

2 Disconnect the valves and blocks where you want to increase the number of stations.

3 Install an additional valve or a SUP/EXH block on the DIN



A manifold equipped with a valve or a block can be mounted on the DIN rail. However, a serial connector block cannot be mounted on the DIN rail when it is connected with another block; the serial connector block must be mounted separately.

4 Press the valves and blocks together to connect them, and then tighten screw "a" to secure the DIN rail.

After fixing the connector block, fasten the threads onto the end block while holding it lightly by hand. This is necessary to improve sealing.

Caution (D-sub, Connector block for flat ribbon cable, End block M3: 0.6 N·m Connector block for EX180 serial wiring M4: 1.4 N·m

## ∕!∖ Caution

- 1. Be sure to turn off the power and stop the supply of air before disassembly. Furthermore, since air may remain inside the actuator, piping, and manifold, confirm that the air is completely exhausted before performing any work.
- 2. After assembly and disassembly, air leakage could occur if blocks are not well connected or a thread is not tightly fastened onto the end block. Before supplying air, make sure that no gaps exist in between blocks and that the valve and block are tightly fastened onto the DIN rail. Also, make sure that air is not leaking before use.

Construction

Plug-in

**EX510 EX180** 

Non Plug-in

SJ3A6


Plug-in



## Non Plug-in **Individual Wiring Manifold**

## **SJ2000/3000** Series

p. 95 **Individual Wiring** 




Specific Product Precautions

# Non Plug-in Individual Wiring SJ2000/3000 Series

**How to Order** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

#### Individual wiring manifold



#### 1 Series

2	SJ2000		
3	SJ3000		
3	(SJ2000/3000 mixed)		

#### 3 Valve stations

Symbol	Stations
01	1 station
:	:
20	20 stations

#### 2 Mixed mounting type

_	Standard*1
M	Mixed mounting*2

- \*1 There is no need to enter anything when you operate either the SJ2000 or SJ3000 series alone.
- \*2 Select "M" when SJ2000 or SJ3000 series valves will be mounted on the same manifold base together.

## 4 SUP/EXH block mounting position

U	U side
D	D side
В	Both sides
M*1	Special specifications

\*1 Specify the required specifications (including port sizes other than Ø 8) on the manifold specification sheet.

#### 6 Pilot type

Internal pilot	
S Internal pilot, Built-in silencer	
R External pilot	
RS	External pilot, Built-in silencer

- There is no need to enter anything when the SUP/EXH block mounting position "M" is selected.
- \* The 3/5(E) port is plugged for the built-in silencer type.

#### 6 SUP/EXH block fitting specification

_	L	В
Straight fitting	Elbow fitting (Upward)	Elbow fitting (Downward)
With external	With external	With external
pilot spec.	pilot spec.	pilot spec.
X, PE port:	X, PE port:	X, PE port:
Elbow fitting	Straight fitting	Elbow fitting


\* There is no need to enter anything when the SUP/EXH block mounting position "M" is selected.

#### 7 DIN rail length specified

_		indard length
2	2 stations	Specify a length
:	:	longer than that of
20	20 stations	the standard rail.

 Specify the number of valve stations without exceeding the max. number of stations.

#### **How to Order Manifold Assembly**




- SS5J3-60-06D.....1 set (Manifold part no.)
- \* SJ3160N-5MZ-C6......2 sets (Single solenoid part no.)

  \* SJ3260N-5MZ-C6.....4 sets (Double solenoid part no.)
- →The asterisk denotes the symbol for the assembly.

  Prefix it to the part numbers of the solenoid valves, etc.
- · For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

## Specific Product Precautions

#### **How to Order Solenoid Valves**



#### 1 Series

2	SJ2000
3	SJ3000

#### 2 Type of actuation

1	2-position single solenoid
2	2-position double solenoid
3	3-position closed center
4	3-position exhaust center
5	3-position pressure center
Α	Dual 3-port valve: N.C./N.C.
В	Dual 3-port valve: N.O./N.O.
С	Dual 3-port valve: N.C./N.O.

- \* Refer to pages 18 to 21 for the symbol.
- \* The large flow type ("A") is available only for actuation types "1" and "2."

#### 3

_	Standard flow type
<b>A</b> *1	Large flow type

Back pressure check valve

None
Built-in
3 -position and large flow type ("A")

\*1 SJ3000 series only

## Internal pilotR External pilot

4 Pilot type

The external pilot specification is not applicable for 4-position dual 3-port valves.

#### 6 Coil type

With power-saving circu	Standard							
	uit							
(Continuous duty type)	<del>)</del> )							

 Be sure to select the powersaving circuit type if the valve is to be continuously energized for long periods of time.

## **7** Non plug-in

#### 8 Rated voltage

5	24 VDC
6	12 VDC


## with a back pressure check valve. 9 Common specification


solenoid valves cannot be equipped

_	Positive common
N	Negative common

## With light/surge voltage suppressor

#### 10 Connector entry







MO:
Individual wiring,
Without
connector


Without
linkage-printed
circuit board

\* When ordering a connector separately, refer to pages 144 and 145.

## 12 Manual override







## (B) A, B port size

#### Metric/One-touch fitting

Metric/One-touch fitting																									
Symbol		Α,	B port	SJ2000	SJ3000	SJ3000A																			
C2	Ħ		Ø 2	•	•	_																			
C4	Straight	Ø 4		Ø 4		Ø 4		Ø 4		Ø 4		Ø 4		Ø 4		Ø 4		Ø 4		Ø 4		•	•	•	
C6	Š		Ø 6	_	•	•																			
L2		entry	Ø2	•	•	_																			
L4	wo		Ø 4	•	•	•																			
L6		WO	ΜO	Elbow	entry Upward	Ø 6	_	•	•																
B2	置		Ø2	•	•	_																			
B4		Downward	Ø 4	•	•	•																			
B6		Dowr	Ø 6	_	•	•																			

#### Thread nining

Tilleau	i bibilig				
Symbol	A, B port	SJ2000	SJ3000	SJ3000A	
МЗ	M3 x 0.5	•	_	_	J.
M5	M5 x 0.8	_	•	•	

#### Inch/One-touch fitting

**SMC** 


Inch/O	Inch/One-touch fitting												
Symbol		A, B port   SJ2000   SJ3000   SJ3000A											
N1	Ιŧ		Ø 1/8"	•	•	_							
N3	Straight	,	Ø 5/32"	•	•	•							
N7	ß		Ø 1/4"	_	•	•							
LN1		entry	Ø 1/8"	•	•	_							
LN3			Ø 5/32"	•	•	•							
LN7	MO	MO	Elbow	Upward	Ø 1/4"	_	•	•					
BN1	믋	entry	Ø 1/8"	•	•	_							
BN3		Downward	Ø 5/32"	•	•	•							
BN7		Dowr	Ø 1/4"	_	•	•							

## **SJ2000/3000** Series

#### **Dimensions**

#### SS5J2-60-Stations U(S, R, RS)

#### [External pilot specification]




L: Din	L: Dimensions n: Station:													Stations						
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	85.5	98	98	110.5	110.5	123	135.5	135.5	148	148	160.5	173	173	185.5	185.5	198	210.5	210.5	223	223
L2	75	87.5	87.5	100	100	112.5	125	125	137.5	137.5	150	162.5	162.5	175	175	187.5	200	200	212.5	212.5
L3	55.7	63.2	70.7	78.2	85.7	93.2	100.7	108.2	115.7	123.2	130.7	138.2	145.7	153.2	160.7	168.2	175.7	183.2	190.7	198.2
L4	15	17.5	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5	16	12.5

\* For manifold dimensions including elbow fitting, refer to page 59.


#### **Dimensions**

#### SS5J2-60-Stations B(S, R, RS)

#### [External pilot specification]



\*1 Height to manual override Push type manual override: 40.3 (Station 1)---(Station n) Locking type manual override: 40.5



\* For manifold dimensions including elbow fitting, refer to page 59.

L: Din	: Dimensions n: Sta															Stations				
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	98	110.5	110.5	123	135.5	135.5	148	148	160.5	173	173	185.5	185.5	198	210.5	210.5	223	223	235.5	248
L2	87.5	100	100	112.5	125	125	137.5	137.5	150	162.5	162.5	175	175	187.5	200	200	212.5	212.5	225	237.5
L3	71.2	78.7	86.2	93.7	101.2	108.7	116.2	123.7	131.2	138.7	146.2	153.7	161.2	168.7	176.2	183.7	191.2	198.7	206.2	213.7
L4	13.5	16	12	14.5	17	13.5	16	12	14.5	17	13.5	16	12	14.5	17	13.5	16	12	14.5	17

Construction

Plug-in

EX510 EX180

Non Plug-in

SJ3A6

Plug-in


Non Plug-in


Specific Product Precautions


## **SJ2000/3000** Series

#### **Dimensions**

#### SS5J3-60-Stations U(S, R, RS)







 $\ast\,$  For manifold dimensions including elbow fitting, refer to page 60.

SOL.a: Red SOL.b: Green


## L: Dimensions n: Stations


L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	85.5	98	110.5	123	123	135.5	148	160.5	173	185.5	185.5	198	210.5	223	235.5	235.5	248	260.5	273	285.5
L2	75	87.5	100	112.5	112.5	125	137.5	150	162.5	175	175	187.5	200	212.5	225	225	237.5	250	262.5	275
L3	58.2	68.2	78.2	88.2	98.2	108.2	118.2	128.2	138.2	148.2	158.2	168.2	178.2	188.2	198.2	208.2	218.2	228.2	238.2	248.2
L4	13.5	14.5	16	17	12	13	14	15.5	16.5	17.5	12.5	13.5	15	16	17	12	13	14.5	15.5	16.5

#### **Dimensions**

#### SS5J3-60-Stations B(S, R, RS)


#### [External pilot specification]





D side U side Valve lock switch Manual override switch Manual override 30.6 Locking type: Press, \ (Lead wire length) then rotate it. 4(A) port side: Blue 2(B) port side: Yellow DIN rail holding screw **®** 56.2 DIN rail 17.2 C6: 16.3 N7: 18.8 (9.1)18.1 9.6 12. Silencer (Air discharge port) 3-position type (Built-in silencer specification) C6: N7: SJ3160A identifying indentation C6: (DIN rail mounting hole pitch: 12.5)

Ø 6, Ø 1/4"



\* For manifold dimensions including elbow fitting, refer to page 60.

L: Din	: Dimensions n:															Stations				
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	98	110.5	123	135.5	148	148	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	260.5	273	285.5	298
L2	87.5	100	112.5	125	137.5	137.5	150	162.5	175	187.5	200	200	212.5	225	237.5	250	250	262.5	275	287.5
L3	73.7	83.7	93.7	103.7	113.7	123.7	133.7	143.7	153.7	163.7	173.7	183.7	193.7	203.7	213.7	223.7	233.7	243.7	253.7	263.7
L4	12	13	14.5	15.5	16.5	11.5	12.5	14	15	16	17.5	12	13.5	14.5	15.5	17	11.5	13	14	15

**SMC** 

Construction

Plug-in

D-sub Flat Ribbon EX510 EX180

Non Plug-in

SJ3A6

Plug-in

D-sub Flat Ribbon Serial

Non Plug-in

Individual Wiring

pecific Product
Precautions Specific

## **SJ2000/3000** Series


## Dimensions: SJ2000/3000 Mixed Manifold

SS5J3-M60-Stations U(S, R, RS)

L dimension: Formula, L1 to L4 L3 =  $7.5 \times n2 + 10 \times n3 + 48.2$ M = (L3 + 4)/12.5 + 1Decimal fractions are truncated. L1 = M × 12.5 + 23 L2 = L1 - 10.5 L4 = (L1 - L3)/2 - 2

> n2 = Number of SJ2000 n3 = Number of SJ3000

\* The dimensions of L1 to L4 for SS5J3-M60-Stations D are the same as those of SS5J3-M60-Stations U.



#### SS5J3-M60-Stations B(S, R, RS)

D side U side (Lead wire length) 11 L2 (DIN rail mounting hole pitch: 12.5) Approx. Manual override 17.2 (SJ3000) [17.5 (SJ2000)] DIN rail holding 30.6 Locking type: Press, then rotate it. 4(A) port side: Blue Manual override 2(B) port side: Yellow switch DIN rail 56. 35 (9.6) (\$J3000) [(7.3) (\$J2000)] [(16.3) (\$J3000A)] (L4) 8 Valve lock switch One-touch fitting [4(A), 2(B) port] Applicable tubing O.D.: Ø 2, Ø 1/8" One-touch fitting Ø 4, Ø 5/32" Ø 6, Ø 1/4" One-touch fitting [4(A), 2(B) port] Applicable tubing O.D.: Ø 2, Ø 1/8" [1(P), 3/5(E) port] Applicable tubing O.D.: Ø 8, Ø 5/16" Ø 4, Ø 5/32 30 32.1 (SJ3000) [32.5 (SJ2000)] (SJ3000) 15.4 (SJ3000) [15 (SJ2000)] SJ2000 SJ3000 pitch pitch P = 7.5P = 10

L dimension: Formula, L1 to L4 L3 =  $7.5 \times n2 + 10 \times n3 + 63.7$ M = (L3 + 4)/12.5 + 1 Decimal fractions are truncated. L1 = M x 12.5 + 23 L2 = L1 - 10.5 L4 = (L1 - L3)/2 - 2

> n2 = Number of SJ2000 n3 = Number of SJ3000




## **SJ2000/3000** Series

## **Manifold Exploded View**

#### **Individual Wiring**

Type 60 individual wiring (Non plug-in)

\* Refer to page 90 for "How to Increase Manifold Stations."



No.		Description	Part no.	Note
		Internal pilot	SJ3000-50-5A-□□	(Metric size)
		Internal pilot, Built-in silencer	SJ3000-50-5AS-□□	C6: With Ø 6 One-touch fitting (straight)
		External pilot	SJ3000-50-5AR-□□ (X, PE port: Metric size Ø 4 ) Inch size Ø 5/32	C8: With Ø 8 One-touch fitting (straight) L6: With Ø 6 One-touch fitting (elbow upward entry) L8: With Ø 8 One-touch fitting (elbow upward entry)
1	SUP/EXH block	External pilot, Built-in silencer	SJ3000-50-5ARS-□□ (X port: Metric size Ø 4 ) Inch size Ø 5/32)	B6: With Ø 6 One-touch fitting (elbow downward entry) B8: With Ø 8 One-touch fitting (elbow downward entry)
		For different pressures, Internal pilot*1	SJ3000-50-6A-□□	(Inch size)
		For different pressures, Internal pilot, Built-in silencer*1	SJ3000-50-6AS-□□	N7: With 1/4" One-touch fitting (straight) N9: With 5/16" One-touch fitting (straight)
2	End block		SJ3000-53-1A	For the U side
3	End block		SJ3000-53-2A	For the D side
4	DIN rail		VZ1000-11-1-□	Refer to page 106.
5	O-ring for valve	connection*2	SJ3000-96-1A	The part no. shown on the left includes parts for 5 units.  (10 pcs. each for the P and E ports and for the X and PE ports)

<sup>\*1</sup> As the valves cannot be operated only with the SUP/EXH block for different pressures, select them in combination with the SUP/EXH block for internal/external pilot.

Plug-in

EX510 EX180

SJ3A6



<sup>\*2</sup> Included with valves, SUP/EXH blocks, and connector blocks

<sup>\*</sup> Refer to page 103 for the SUP/EXH block disk and method of handling parts at different pressures.

# SJ1000/2000/3000/4000 Series Manifold Options

## SJ1000/2000/3000 Common to Connector Type/Cable Type/Individual Wiring

#### ■ SUP block disk

By placing a SUP block disk in a manifold valve's pressure supply passage, 2 different pressures (a high and a low pressure) can be supplied to 1 manifold. When supplying different pressures using the manifold of the internal pilot, fill out a manifold specification sheet to place an order for a SUP/EXH block for the internal pilot specifications and another SUP/EXH block for the different-pressure internal pilot specifications (Refer to Circuit Diagram 1).

## For the SJ1000/2000/3000


The part	number is for 1 pc
Series	Part no.
SJ1000	
SJ2000	SJ3000-44-1A
SJ3000	


#### **■ EXH block disk**

By installing an EXH block disk in a manifold valve's exhaust passage, the valve's exhaust can be separated so that it will not affect other valves.


#### [Different-pressure pneumatic circuit diagram]

• The SJ series supplies air to the pilot port of each valve using the 1(P) port of the SUP/EXH block. When using in situations where there are different pressures, etc., combine SUP/EXH blocks for internal pilot, external pilot, and different-pressure by referring to the circuit below.





Different-pressure specification using an external pilot (When using the different-pressure internal pilot specification SUP/EXH block)



- \* When operating under the different-pressure specification, supply the higher pressure to the pilot passage.
- \* If there is a need to partition the pilot passage, please contact SMC.



## Manifold Options **SJ1000/2000/3000/4000** Series

## SJ4000 Connector Type

#### ■ SUP block disk

By placing a SUP block disk in a manifold valve's pressure supply passage, 2 different pressures (a high and a low pressure) can be supplied to 1 manifold.

#### ■ EXH block disk

By installing an EXH block disk in a manifold valve's exhaust passage, the valve's exhaust can be separated so that it will not affect other valves.

#### ■ Block plug for the X port (For the SJ4000)


(For the SJ4000)

The part	number is for 5 pcs
Series	Part no.
SJ4000	SJ4000-44-2A


#### [Different-pressure pneumatic circuit diagram]

• The SJ series supplies air to the pilot port of each valve using the 1(P) port of the SUP/EXH block. When using in situations where there are different pressures, etc., combine block disks for the SUP/EXH port and a block plug for the X port by referring to the circuit below.

#### 1. Different-pressure specification using an internal pilot



2. Different-pressure specification using an external pilot (When using the external pilot SUP/EXH block)



\* To mount a block plug to the pilot (X port) of an SJ1000/2000/3000 and SJ4000 series mixed-mounted manifold, contact SMC to order it as a special-order product.

(For the SJ4000)



The part	number is for 1 pc.
Series	Part no.
SJ4000	SJ4000-44-1A

Construction Common Specification

Plug-in

EX510 EX180 | Flat Rib

Non Plug-in

Individua Wiring

Manif Optio

Madi Ord

SJ3A6

Common Spec Construction

bbon Plug-in

don ug-in

> nd ividual Wiring

Specific Product Precautions



#### Common to Connector Type/Cable Type/Individual Wiring

#### ■ Label for block disk (For the SJ1000/2000/3000)

These labels are attached to manifolds in which SUP and EXH block disks have been installed, in order to identify the installed locations. (Three sheets each included.)

#### SJ3000-155-1A

Label for SUP/EXH block disk




## Label for SUP block disk



## Label for EXH block disk





#### ■ Label for block disk (For the SJ4000)

These labels are attached to manifolds in which SUP and EXH block disks and a block plug for the X port have been installed, in order to identify the installed locations. (Three sheets each included.)

#### SJ3000-155-2A

Label for SUP/EXH block disk



Label for EXH block disk




#### Label for SUP block disk



Label for X port block plug






When a block disk is concurrently ordered by specifying on the manifold specification sheet, etc., a label will be stuck on the position where block disk is mounted.

#### ■ Blanking block


These are mounted when later addition of valves is planned, etc.

#### <Connector type/Individual wiring>



For the SJ1000/2000/3000

#### <Connector type>





For the SJ4000

Series	Part no.	Note	Width
SJ1000 SJ2000	SJ3000-49-1A	Connector type (Single wiring)	
SJ3000	SJ3000-49-2A	Connector type (Double wiring)	
SJ3A6*1	SJ3000-49-2A-N	Connector type (Double wiring)	7.5 mm
SJ2000 SJ3000	SJ3000-49-3A	Individual wiring	
SJ3A6*1	SJ3000-49-3A-N		
SJ4000*1	SJ4000-49-1A	Connector type (Single wiring)	15 mm
304000**	SJ4000-49-2A	Connector type (Double wiring)	15 11111

\*1 Valve lock switch is not available for the SJ3A6 and SJ4000.

#### <Cable type>





Series	Part no.	Width
SJ2000	SJ2000-49-4A	7.5 mm
SJ3000	SJ3000-49-4A	10 mm
SJ3A6*1	SJ3000-49-4A-N	10 mm

\*1 Valve lock switch is not available for the SJ3A6.




## Manifold Options **SJ1000/2000/3000/4000** Series

#### Common to Connector Type/Cable Type/Individual Wiring

#### ■ Silencer with One-touch fitting


This silencer can be mounted on the manifolds' port 3/5 (E: Exhaust) with a single touch.



Series	Model	Effective area	Α	В	С	Ød
SJ1000 SJ2000 (Ø 8) SJ3000	AN15-C08	20 mm <sup>2</sup>	45 mm	13 mm	20 mm	Ø 8
SJ4000 (Ø 10)	AN20-C10	30 mm <sup>2</sup>	57.5 mm	16.5 mm	30.5 mm	Ø 10


#### ■ Plug

These are inserted in unused cylinder ports and P, E ports.




Dimensions				[mm]
Applicable fitting size $\mathcal{O}$ <b>d</b>	Model	Α	L	D
2	KJP-02	8.2	17	3
4	KQ2P-04	16	32	6
6	KQ2P-06	18	35	8
8	KQ2P-08	20.5	39	10
10	KQ2P-10	27.4	43	12
1/8"	KQ2P-01	16	31.5	5
5/32"	KQ2P-03	16	32	6
1/4"	KQ2P-07	18	35	8.5
5/16"	KQ2P-09	20.5	39	10

#### ■ DIN rail




\* Enter a number from the DIN rail dimension table shown below.



																						(Uni	it: mm)
No.	S1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
L dimension	85.5	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	310.5	323	335.5	348	360.5
Weight [g]	15.4	17.6	19.9	22.1	24.4	26.6	28.9	31.1	33.4	35.6	37.9	40.1	42.4	44.6	46.9	49.1	51.4	53.6	55.9	58.1	60.4	62.6	64.9
No.	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
140.	22	20	24	23	20	21	20	23	30	J I	32	33	34	33	30	37	30	33	40	71	72	40	-7-7
L dimension	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648
Weight [g]	67.1	69.4	71.6	73.9	76.1	78.4	80.6	82.9	85.1	87.4	89.6	91.9	94.1	96.4	98.6	100.9	103.1	105.4	107.6	109.9	112.1	114.4	116.6

#### ■ Flat ribbon cable



#### Flat Ribbon Cable

Cable length (L)	10 pins	20 pins	26 pins
1.5 m	AXT100-FC10-1	AXT100-FC20-1	AXT100-FC26-1
3 m	AXT100-FC10-2	AXT100-FC20-2	AXT100-FC26-2
5 m	AXT100-FC10-3	AXT100-FC20-3	AXT100-FC26-3
Connector width (W)	17.2	30	37.5

<sup>\*</sup> For other commercial connectors, use a type with strain relief that conforms to MIL-C-83503.

#### Connector manufacturers:

- HIROSE ELECTRIC CO., LTD.
- 3M Japan Limited
- Fujitsu Limited
- Japan Aviation Electronics Industry, Limited
- J.S.T. Mfg. Co., Ltd.

Non Plug-in

ndividual Wiring


Specific Product Precautions



#### Common to Connector Type/Cable Type/Individual Wiring

#### ■ D-sub connector (25 pins)/Cable

 $\begin{array}{c} \textbf{AXT100-DS25} - \substack{015 \\ 030 \\ 050 \end{array}$ 



#### **D-sub Connector Cable**

Cable length (L)	Assembly part no.	Note	
1.5 m	AXT100-DS25-015	Cable 25 cores x 24AWG	
3 m	AXT100-DS25-030		
5 m	AXT100-DS25-050		

For other commercial connectors, use a 25 pins type with female connector conforming to MIL-C-24308.

#### Connector manufacturers:

- HIROSE ELECTRIC CO., LTD.
- Fujitsu Limited
- Japan Aviation Electronics Industry, Limited
- J.S.T. Mfg. Co., Ltd.

#### **Electric Characteristics**

Item	Characteristics
Conductor resistance Ω/km, 20 °C	65 or less
Withstand pressure VAC, 1 min	1000
Insulation resistance MΩkm, 20 °C	5 or less

\* The min. bending radius for D-sub connector cables is 20 mm.


## D-sub Connector Cable Cable Color List of Each Terminal No.

oubic ooio	LIOCOI LU	cii i ciiiiiiiai ivo.
Terminal no.	Lead wire color	Dot marking
1	Black	None
2	Brown	None
3	Red	None
4	Orange	None
5	Yellow	None
6	Pink	None
7	Blue	None
8	Purple	White
9	Gray	Black
10	White	Black
11	White	Red
12	Yellow	Red
13	Orange	Red
14	Yellow	Black
15	Pink	Black
16	Blue	White
17	Purple	None
18	Gray	None
19	Orange	Black
20	Red	White
21	Brown	White
22	Pink	Red
23	Gray	Red
24	Black	White
25	White	None

## Manifold Options SJ1000/2000/3000 Series


#### Common to Connector Type/Cable Type/Individual Wiring


■ Dual flow fitting (Set for SJ3000 series)



This is a fitting for cylinder ports which enables simultaneous actuation and increase in flow rate of valves for 2 stations. This is a One-touch fitting with port sizes of O 8 and O 5/16".

\* When arranging mounted to the valve, arrange the valve part no. using the part no. without the One-touch fitting, and then add the part no. for the dual flow fitting. If the arrangement is too complicated, please specify the details on a manifold specification sheet.






## SJ1000/2000/3000 Series

#### For Connector Type/Individual Wiring

#### ■ Regulator block/How to Order

This is used to reduce the pressure supplied from the D side inside the manifold. All valves on the U side are depressurized from the regulator block.




- \* Be sure to apply the pressure from the 1(P) port of the manifold before using the regulator block.
- When ordering with a regulator block installed in the manifold, please order using the manifold specification sheet.


#### SJ3000(N)-00-P(-H)

With manual operation of pressure adjustment screw Valve lock switch\*1 No linkage-printed circuit board is provided for individual wiring.

Pressure gauge, top mounting



Pressure gauge, side mounting




#### Without pressure gauge


\*1 The valve lock switch is available only for the SJ1000/2000/3000 series.

#### ■ Flow Rate Characteristics (Conditions: Inlet pressure 0.7 MPa when 2-position solenoid valve is mounted) SJ1000


#### P port regulation (P $\rightarrow$ A, B)



#### SJ2000




#### SJ3000 P port regulation (P → A, B)




## Manifold Options SJ1000/2000/3000 Series

#### ■ Pneumatic circuit (Regulator block mounting example)



\* Reduces supply pressure from the D side of manifold Supply pressure from the U side cannot be reduced.

#### **■** Dimensions



Construction Specification

Plug-in

EX510 EX180 Flat Ribbon

Non Plug-in

in main

order

SJ3A6

Common Spec Construction

bon Plug-in

-in Flat Rib

vidual No


Specific Product Precautions

## SJ1000/2000/3000 Series

#### For Connector Type/Individual Wiring

#### ■ SUP/EXH block with regulator and pressure switch (for internal pilot manifold)/How to Order


\* When mounting on the manifold, specify it on the manifold specification sheet.



When the knob orientation is lateral, the elbow fitting (upward entry) cannot be selected

B8: Ø 8 elbow fitting

- For the "Internal wiring" specifications, the wiring is assigned to the centralized wiring on the manifold. (For details, refer to "Electrical Wiring" on page 114.)
- For the internal wiring specifications, select an appropriate pressure switch according to the polarity of the valve to be mounted.
  For the serial manifold and non plug-in, "Q" and "S"
- (internal wiring specifications) cannot be selected.
- The analog pressure gauge is not applicable to copper-free specifications.
- A fixed unit (MPa) digital pressure switch is
- provided.
  This product is for overseas use only according to the New Measurement Act. (The SI unit type is provided for use in Japan.) Both "MPa" and "psi" are written on the unit display of the digital pressure switch.
- The digital pressure switch is equipped with a unit selection function, but it will be set to psi initially.
- \*4 For digital pressure switches







Fig. 1 Knob orientation (Regulator mounting orientation)

- Be sure to apply the pressure from the 1(P) port of the manifold before using the SUP/ EXH block with a regulator and pressure switch.
- For details on the regulator and electric circuit of the external wiring specifications, refer to the catalogue of the ARM11 series.
- Applicable only to internal pilot specification manifolds
- This regulator block cannot be combined with the vacuum release valve of the SJ3A6 series.

#### ■ SJ3000 series valve with speed controller/How to Order



Meter-in

- \*1 Set the operating torque of the speed controller to 0.1 N·m or less.
- Applicable only to the SJ3000 series However, this option is not selectable for the SJ3□60A.
- \* Specify "S0" or "S1" at the end of the valve part no.





Fig. 2 Pressure switch/pressure gauge display orientation symbol





Identification color: Black

## Manifold Options SJ1000/2000/3000 Series

Construction

Plug-in

EX510 EX180

<u>15</u>0

100

Outlet flow rate [I/min (ANR)]

125

Made to Order

SJ3A6


Plug-in


Specific Product Precautions

#### ■ Flow rate characteristics


#### Regulator unit flow rate characteristics

SJ1000 passage P → A/B





SJ3000 passage P → A/B







0.2 Outlet

0.1

Valve with speed controller flow rate characteristics Meter-out control A/B → E






\* The flow rate characteristics are characteristics of each individual product. Actual values may differ depending on the piping, circuitry, pressure conditions, etc. Also, depending on product specifications, there may be variations in the zero needle rotations position of the flow rate characteristics

#### ■ Pneumatic circuit


(Installation example of SUP/EXH block with regulator and pressure switch, valve with speed controller)



## SJ1000/2000/3000 Series

#### For Connector Type/Individual Wiring

■ SUP/EXH block with regulator and pressure switch, valve with speed controller/Dimensions




\*1 The SUP/EXH block with regulator and pressure switch cannot be mounted on the plug-in cable type manifold.





## Manifold Options SJ1000/2000/3000 Series

■ Manifold electrical wiring when the SUP/EXH block with the regulator and pressure switch is mounted (Internal wiring and pressure switch (NPN))

D-sub connector (25 pins)









Flat ribbon cable (20 pins)

Flat ribbon cable (10 pins)





- \* This figure shows when the SUP/EXH block with the regulator and pressure switch is mounted between the connector block and 1st station valve.
- \* Applicable only to the connector type manifold



Specific Product Precautions

Plug-in Construction

EX510 EX180 Plat Ribbon

Non Plug-in

Wiri

Made to M Order 0

SJ3A6

Common Spec. Construction

bon Plug-in

Flat Ribt Serial

Non Plug-in

f Individ

## SJ1000/2000/3000 Series

### For connector type

#### ■ Intermediate connector block


This connector block can be used by inserting it into the middle of the manifold.


This can be used, for example, when you wish to separate electrical control of valves in the same manifold, or when the number of control points is insufficient.

Series	Part no.	Note
SJ1000 SJ2000	SJ3000-76-1A	Flat ribbon cable (20 pins)
SJ3000	SJ3000-76-4A	Flat ribbon cable (26 pins)

\* When ordering with an intermediate connector block installed in the manifold, please order using the manifold specification sheet.

#### ■ Intermediate connector block wiring example







For flat ribbon cable (20 pins)


 Enables control of U side solenoid valves from the position where the intermediate connector block is installed

#### **■** Dimensions





with strain relief (MIL-C-83503 compliant)



\* This drawing shows the SJ3000-76-1A.



# SJ1000/2000/3000 Series Made to Order

Please contact SMC for detailed dimensions, specifications, and lead times.




Symbol

-X90

## 1 Main Valve Fluororubber Specification

Fluororubber is used for the rubber parts of the main valve to allow for use in the following situations.

- 1. When a lubricant other than the recommended turbine oil is used and there is a possibility of malfunction due to swelling of the spool valve seals
- 2. In environments where ozone may enter or is generated in the air supply




\* As fluororubber is only used for the main valve of the -X90 series, use in environments requiring heat resistance should be avoided.

Symbol

-X110

## 2 Spring Return Specification (Dual 3-port Valve N.C./N.C.)

When the supply pressure is exhausted, the main valve is forcibly returned to the OFF position by the built-in spring.



Response time: 20 ms


Max. operating frequency: 3 Hz


For other specifications, refer to the standard model.


#### **Symbol**

SJ1A60T

SJ1A60KT (With back pressure check valve)







n Specifications

Plug-in ||Construction

EX510 EX180 Plat Ribbon

on ig-in E

Individual Wiring

Manifold Options

Made to Order

SJ3A6

Common Spec Construction

bon Plug-in

D-sub Flat Ribbon Serial

Non Plug-in

Individua Wiring

Specific Product Precautions



Symbol


-X225


## 3 Low-profile SUP/EXH Block Specification


The low-profile SUP/EXH block is 10.2 mm, which is smaller than the 15.5 mm standard SUP/EXH block. This reduction results in space saving. The 1(P) port and the 3/5(E) port fittings are straight union (metric size) C6s: O 6 One-touch fittings.

4-port solenoid valve









The entry is the same as that of the standard model. However, there is no setting required for the pilot specification with a built-in silencer (S, RS).

- \* When the flow rate is insufficient, such as during the simultaneous operation of multiple valves, select the supply/exhaust block mounting position [B (both sides)] or use the standard manifold without using the -X225.
- \* When ordering a manifold, specify the part nos. of the valves to be mounted on it. (An order cannot be placed with only the manifold part no.)
- \* Check the "How to Order Manifolds" section of each valve to be mounted.
- \* There is a made-to-order option that makes it so dual-flow fittings, etc., cannot be built into the manifold. Refer to the "Manifold Specifications Sheet" for more information.
- \* When a silencer (AN10-C6) is used, it cannot be mounted next to a 3-position valve or a speed controller.

#### **Flow Rate Characteristics**

	Port	size				Flow rate ch	aracteristics			
Series	1(P)	4, 2		1 →4/2 (	P →A/B)			4/2 →3/5	(A/B →E)	
	3/5(E)	(A, B)	C [dm³/(s·bar)]	b	Cv	Q [l/min/(ANR)]*2	C [dm³/(s·bar)]	b	Cv	Q [l/min/(ANR)]*2
SJ1000	C6	C2	0.12	0.54	0.04	37	0.13	0.49	0.04	38
301000		C4	0.26	0.29	0.07	66	0.30	0.23	0.08	73
		C2	0.13	0.55	0.04	40	0.13	0.53	0.04	39
SJ2000	C6	C4	0.30	0.31	0.08	77	0.34	0.33	0.08	88
		МЗ	0.18	0.48	0.06	52	0.20	0.26	0.06	50
		C2	0.13	0.66	0.04	44	0.14	0.60	0.04	45
SJ3000	C6	C4	0.38	0.17	0.10	90	0.45	0.15	0.11	105
503000	00	C6	0.45	0.19	0.12	107	0.51	0.19	0.12	121
		M5	0.40	0.26	0.11	99	0.45	0.18	0.11	107

The values are for an individually operated 2-position type manifold base with 5 stations.



<sup>\*1</sup> These values have been calculated according to ISO 6358 and indicate the flow rate under standard conditions with an inlet pressure of 0.6 MPa (relative pressure) and a pressure drop of 0.1 MPa.

Excludes the SJ3000A (large flow type) and SJ4000


## Made to Order **SJ1000/2000/3000** Series


3 Low-profile SUP/EXH Block Specification


Symbol

-X225


#### **Dimensions**







#### [External pilot specification]



#### L: Dimensions

SS	5 <b>J</b> 1-6	0FD		U-X	225																		n: S	tations
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	98	98	110.5	110.5	123	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	210.5	210.5	223	223	235.5	235.5	248
L2	87.5	87.5	100	100	112.5	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	200	200	212.5	212.5	225	225	237.5
L3	59	65.5	72	78.5	85	91.5	98	104.5	111	117.5	124	130.5	137	143.5	150	156.5	163	169.5	176	182.5	189	195.5	202	208.5
L4	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18	21	18	21	17.5	20.5	17.5	20.5	23.5	20	23	20	23	19.5	22.5

SSS	J1-6	0FD		B-X	225																		n: S	tations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	110.5	110.5	123	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248
L2	100	100	112.5	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5	225	225	237.5	237.5
L3	69.2	75.7	82.2	88.7	95.2	101.7	108.2	114.7	121.2	127.7	134.2	140.7	147.2	153.7	160.2	166.7	173.2	179.7	186.2	192.7	199.2	205.7	212.2	218.7
L4	23.5	20.5	23.5	20	23	20	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18	21	18	21	17.5

**SMC** 

Construction Specifications

Plug-in

EX510 EX180 Flat Ribbon

Non Plug-in

> Individua Wiring

> > Options

Order

SJ3A6

Construction

Plug-in

D-sub Flat Ribbon Serial

Non Plug-in

Individual Wiring

Specific Product Precautions

## SJ1000/2000/3000 Series

3 Low-profile SUP/EXH Block Specification

L: Dimensions

SS5J1-60PD□-□U-X225

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 L1 98 110.5 110.5 123 123 135.5 135.5 148 148 160.5 160.5 173 185.5 185.5 198 198 210.5 210.5 223 223 235.5 235.5 248 L2 87.5 87.5 100 100 112.5 112.5 125 125 137.5 137.5 150 150 162.5 175 175 187.5 187.5 200 200 212.5 212.5 225 225 237.5 L3 72 78.5 85 91.5 98 104.5 111 117.5 124 130.5 137 143.5 150 156.5 163 169.5 176 182.5 189 195.5 202 208.5 19.5 19 22 19 22 18.5 21.5 18.5 21.5 24.5 21 24 21 24 20.5 23.5 20.5 23.5 23 SS5J1-60PD□-□B-X225 n: Stations 1 3 6 7 2 4 5 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 110.5 110.5 123 L1 123 135.5 135 5 148 160.5 160.5 185.5 185 5 198 210.5 210.5 235 5 235 5 248 148 173 173 198 223 223 260.5 162.5 L2 125 137.5 150 150 187.5 187.5 200 212.5 212.5 225 237.5 100 100 112.5 112.5 125 137.5 162.5 175 175 200 225 250 L3 69.2 75.7 82.2 88.7 95.2 101.7 108.2 114.7 121.2 127.7 134.2 140.7 147.2 153.7 160.2 166.7 173.2 179.7 186.2 192.7 199.2 205.7 212.2 218.7 L4 20.5 23.5 20.5 23.5 20 23 20 23 19.5 22.5 19.5 22.5 19 22 19 22 18.5 21.5 18.5 21.5 18 21 24 SS5J1-60SV/Q□D-□U-X225 n: Stations 2 3 5 6 7 8 9 10 11 12 13 14 15 16 L1 123 123 135.5 135.5 148 148 160.5 160.5 173 173 185.5 185.5 198 210.5 198 210.5 L2 112.5 112.5 125 125 137.5 137.5 150 150 162.5 162.5 175 187.5 187.5 200 200 175 L3 186.9 89.4 95.9 102.4 108.9 115.4 121.9 128.4 134.9 141.4 147.9 154.4 160.9 167.4 173.9 180.4 L4 13.5 17 16.5 13.5 16.5 13 16 13 16 12.5 15.5 12.5 15.5 12 15 12 n 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 L1 223 223 235.5 260.5 260.5 273 273 285.5 298 310.5 310.5 323 248 248 285.5 298 L2 212.5 212.5 225 237.5 250 262.5 262.5 287.5 287.5 300 300 312.5 237.5 250 275 275 L3 193.4 199.9 206.4 212.9 219.4 225.9 232.4 238.9 245.4 251.9 258.4 264.9 271.4 277.9 284.4 290.9 L4 15 11.5 14.5 17.5 14.5 17.5 14 17 14 17 13.5 16.5 13.5 16.5 13 16 SS5J1-60SV/Q□D-□B-X225 n: Stations 16 1 3 4 2 5 6 7 8 9 10 11 12 13 14 15 L1 123 135.5 148 148 160.5 160.5 173 173 185.5 185.5 198 198 210.5 210.5 223 223 187.5 L2 112.5 125 137.5 137.5 150 150 162.5 162.5 175 175 187.5 200 200 212.5 212.5 13 99 6 106.1 112.6 119.1 125 6 132 1 138 6 145.1 151.6 158 1 164.6 171.1 177.6 184 1 190.6 197.1 L4 11.5 14.5 17.5 14.5 17.5 14 17 14 17 13.5 16.5 13.5 16.5 13 16 13 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 L1 235.5 235.5 248 248 260.5 260.5 273 273 285.5 285.5 298 310.5 310.5 323 323 335.5 L2 225 225 237.5 237.5 250 250 262.5 262.5 275 275 287.5 300 300 312.5 312.5 325 L3 203.6 210.1 216.6 223.1 229.6 236.1 242.6 249.1 255.6 262.1 268.6 275.1 281.6 288.1 294.6 301.1 L4 16 12.5 15.5 12.5 15.5 12 15 12 15 11.5 14.5 17.5 14.5 17.5 14 17 SS5J1-60S6B D-U-X225 n: Stations 7 9 1 2 3 4 5 6 8 10 11 12 13 14 15 16 L1 135.5 148 148 160.5 160.5 173 173 185.5 185.5 198 198 210.5 210.5 223 223 235.5 L2 125 137.5 137.5 162.5 162.5 175 175 187.5 187.5 200 200 212.5 212.5 225 150 150 197.6 204.1 L3 106.6 113.1 119.6 139.1 145.6 152.1 158.6 165.1 178.1 184.6 191.1 17.5 14 13 15.5 14.5 17 14 17 13.5 16.5 13.5 16.5 13 16 16 12.5 SS5J1-60S6B D-B-X225 n: Stations 7 9 14 2 3 4 5 6 8 10 11 12 13 15 16 L1 148 148 160.5 160.5 173 173 185.5 185.5 198 210.5 210.5 223 235.5 235.5 248 223 137.5 162.5 237.5 L2 137.5 150 150 162.5 175 175 187.5 200 200 212.5 212.5 225 225 L3 116.8 123.3 129.8 136.3 142.8 149.3 155.8 162.3 168.8 175.3 181.8 188.3 194.8 201.3 207.8 214.3 L4 15.5 12.5 15.5 12 15 12 15 11.5 14.5 17.5 14.5 17.5 14 17 14 17

Symbol

-X225

n: Stations



## Made to Order **SJ1000/2000/3000 Series**

2000 3000 4000 -X225

Common Specifications

Construction

EX180 Plug-in Plug-in

EX510

Non Plug-in

Options

order

SJ3A6 \_\_\_\_\_ ස් ස

Common Spec.

sub libbon Plug-in rial

P-sub Flat Ribbo Serial

dual Non

Specific Product Precautions

120

3 Low-profile SUP/EXH Block Specification

L: Dimensions

SSS	J2-6	0FD	<b> </b>	U-X	225																		n: S	tations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	98	98	110.5	123	123	135.5	135.5	148	160.5	160.5	173	173	185.5	198	198	210.5	210.5	223	235.5	235.5	248	248	260.5	273
L2	87.5	87.5	100	112.5	112.5	125	125	137.5	150	150	162.5	162.5	175	187.5	187.5	200	200	212.5	225	225	237.5	237.5	250	262.5
L3	60	67.5	75	82.5	90	97.5	105	112.5	120	127.5	135	142.5	150	157.5	165	172.5	180	187.5	195	202.5	210	217.5	225	232.5
L4	22	18	20.5	23	19.5	22	18	20.5	23	19.5	22	18	20.5	23	19.5	22	18	20.5	23	19.5	22	18	20.5	23

SS5J2-60FD□-□B-X225 n: Stations 2 3 6 7 10 16 18 19 20 22 1 5 8 9 11 12 13 14 15 17 21 23 24 123 260.5 260.5 273 L1 110.5 110.5 135.5 160 5 160 5 185 5 185 5 198 210.5 235.5 235 5 248 123 148 148 173 198 223 223 273 L2 100 100 112.5 112.5 125 137.5 137.5 150 150 162.5 175 175 187.5 187.5 200 212.5 212.5 225 225 237.5 250 250 262.5 262.5 L3 70.2 77.7 85.2 92.7 100.2 107.7 115.2 122.7 130.2 137.7 145.2 152.7 160.2 167.7 175.2 182.7 190.2 197.7 205.2 212.7 220.2 227.7 235.2 242.7 19.5 L4 23 19.5 22 18 20.5 23 19.5 22 18 20.5 23 19.5 22 18 20.5 23 22 18 20.5 23 19.5 22 18

SS5J2-60PD□-□U-X225 n: Stations 1 2 3 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 L1 98 110.5 123 123 135.5 135.5 148 160.5 160.5 173 173 185.5 198 198 210.5 210.5 223 235.5 235.5 248 248 260.5 273 98 L2 87.5 87.5 125 162.5 162.5 175 212.5 225 225 237.5 237.5 250 262.5 100 112.5 112.5 125 137.5 150 150 187.5 187.5 200 200 L3 187.5 217.5 225 232.5 60 67.5 75 82.5 90 97.5 105 112.5 120 127.5 135 142.5 150 157.5 165 172.5 180 195 202.5 210 L4 22.5 18.5 21 23.5 20 22.5 18.5 23.5 20 18.5 21 23.5 20 18.5 21 20 18.5 23.5 21 22.5 22.5 23.5 22.5 21

SS5J2-60PD□-□B-X225 n: Stations 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 L1 110.5 110.5 123 123 135.5 148 148 160.5 160.5 173 185.5 185.5 198 198 210.5 223 223 235.5 235.5 248 260.5 260.5 273 273 L2 100 100 112.5 112.5 125 137.5 137.5 150 150 162.5 175 175 187.5 187.5 200 212.5 212.5 225 225 237.5 250 250 262.5 262.5 77.7 107.7 115.2 122.7 130.2 137.7 145.2 152.7 160.2 167.7 175.2 190.2 197.7 205.2 212.7 220.2 235.2 242.7 18.5 21 19.5 22 23.5 19.5 22 18.5 21 23.5 19.5 22 18.5 21 23.5 19.5 22 18.5 21 23.5 19.5 22 18.5

SS5J2-60SV/Q D-U-X225 n: Stations 1 2 3 4 7 16 5 6 8 9 10 11 12 13 14 15 135.5 160.5 160.5 185.5 L1 123 123 148 148 173 185.5 198 198 210.5 223 223 235.5 L2 150 187.5 112.5 112.5 125 137.5 137.5 150 162.5 175 175 187.5 200 212.5 212.5 225 L3 202.9 90.4 97.9 105.4 1129 120 4 127.9 135.4 142 9 150.4 157.9 165.4 172.9 180 4 187 9 195.4 17.5 L4 16.5 12.5 15 14 16.5 12.5 15 17.5 14 16.5 12.5 15 17.5 14 16.5 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 L1 235.5 248 260.5 260.5 273 273 285.5 298 298 310.5 310.5 323 335.5 335.5 348 348 L2 225 237.5 250 250 262.5 262.5 275 287.5 287.5 300 300 312.5 325 325 337.5 337.5 L3 210.4 217.9 225.4 232.9 240.4 247.9 255.4 262.9 270.4 277.9 285.4 292.9 300.4 307.9 315.4 322.9 L4 12.5 15 17.5 14 16.5 12.5 15 17.5 14 16.5 12.5 15 17.5 14 16.5 12.5

SS5J2	2-60SV	//Q□D	-□B-X	225											r	n: Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	135.5	135.5	148	148	160.5	173	173	185.5	185.5	198	210.5	210.5	223	223	235.5	248
L2	125	125	137.5	137.5	150	162.5	162.5	175	175	187.5	200	200	212.5	212.5	225	237.5
L3	100.6	108.1	115.6	123.1	130.6	138.1	145.6	153.1	160.6	168.1	175.6	183.1	190.6	198.1	205.6	213.1
L4	17.5	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5
L	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	248	260.5	260.5	273	285.5	285.5	298	298	310.5	323	323	335.5	335.5	348	360.5	360.5
L2	237.5	250	250	262.5	275	275	287.5	287.5	300	312.5	312.5	325	325	337.5	350	350
L3	220.6	228.1	235.6	243.1	250.6	258.1	265.6	273.1	280.6	288.1	295.6	303.1	310.6	318.1	325.6	333.1
L4	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5	16	12.5	15	17.5	13.5

## SJ1000/2000/3000 Series

3 Low-profile SUP/EXH Block Specification

L: Dimensions

SS5J2-60S6B D-U-X225 n: Stations 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 L1 135.5 148 148 160.5 173 173 185.5 185.5 198 210.5 210.5 223 235.5 235.5 248 248 L2 125 137.5 137.5 150 162.5 162.5 175 175 187.5 200 200 212.5 225 225 237.5 237.5 L3 107.6 115.1 137.6 145.1 152.6 160.1 167.6 175.1 182.6 190.1 197.6 205.1 212.6 220.1 17.5 14 12.5 15 19 15 17.5 14 SS5J2-60S6B D-B-X225 n: Stations 6 7 9 10 11 12 13 14 1 2 3 4 5 8 15 16 L1 148 160.5 160.5 185.5 235.5 235.5 173 173 198 198 210.5 210.5 223 248 260.5 260.5 L2 175 225 225 237.5 137.5 150 150 162.5 162.5 187.5 187.5 200 200 212.5 250 250 L3 117.8 125.3 132.8 140.3 147.8 155.3 162.8 170.3 177.8 185.3 192.8 200.3 207.8 215.3 222.8 230.3 L4 15 17.5 14 16.5 12.5 15 17.5 14 16.5 12.5 15 17.5 14 16.5 19 15 SS5J2-60-□U-X225 n: Stations 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 L1 85.5 85.5 98 110.5 123 123 135.5 135.5 148 160.5 160.5 173 173 185.5 198 198 210.5 210.5 223 98 L2 75 75 162.5 187.5 87.5 87.5 100 112.5 112.5 125 125 137.5 150 150 162.5 175 187.5 200 200 212.5 L3 50.4 57.9 65.4 72.9 95.4 102.9 117.9 125.4 132.9 162.9 170.4 177.9 185.4 192.9 80.4 87.9 110.4 140.4 147.9 155.4 17.5 L4 14 16.5 12.5 15 17.5 14 16.5 12.5 15 17.5 14 16.5 12.5 15 17.5 14 16.5 12.5 15 SS5J2-60-□B-X225 n: Stations 2 3 7 9 10 12 13 14 15 16 18 20 4 5 6 8 11 17 19 L1 85.5 110.5 110.5 123 123 135.5 148 148 160.5 160.5 173 185.5 185.5 198 198 210.5 223 223 235.5 212.5 212.5 L2 75 87.5 100 100 112.5 112.5 125 137.5 137.5 150 150 162.5 175 175 187.5 187.5 200 225 L3 60.6 90.6 98.1 113.1 120.6 128.1 135.6 143.1 150.6 165.6 173.1 180.6 188.1 195.6 203.1 L4 12.5 15 17.5 13.5 16 12.5 15 17.5 13.5 16 12.5 15 17.5 13.5 16 12.5 15 17.5 13.5 16 SS5J3-60FD□-□U-X225 n: Stations 2 3 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 210.5 223 L1 Q8 110.5 123 123 135.5 148 160.5 173 185 5 185 5 198 235 5 235 5 248 260 5 273 285 5 285 5 298 310.5 323 335.5 L2 87.5 100 112.5 112.5 125 137.5 150 162.5 175 175 187.5 200 212.5 225 225 237.5 250 262.5 275 275 287.5 300 312.5 325 L3 62.5 72.5 82 5 925 102.5 112.5 122.5 132.5 142 5 152 5 162 5 172 5 182 5 192 5 202 5 2125 222 5 232 5 242 5 252 5 262 5 272 5 282.5 292 5 L4 20.5 22 23 19 20 21.5 22.5 23.5 18.5 19.5 21 22 23 18 19 20.5 21.5 22.5 17.5 18.5 20 21 22 SS5J3-60FD□-□B-X225 n: Stations 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 L1 110.5 123 123 135.5 148 160.5 173 185.5 185.5 198 210.5 223 235.5 235.5 248 260.5 273 285.5 285.5 298 310.5 323 348 L2 100 112.5 112.5 125 137.5 150 162.5 175 175 187.5 200 212.5 225 225 237.5 250 262.5 275 275 287.5 300 312.5 325 337.5 L3 72.7 82.7 92.7 102.7 112.7 122.7 132.7 142.7 152.7 162.7 172.7 182.7 192.7 202.7 212.7 222.7 232.7 242.7 252.7 262.7 272.7 282.7 292.7 302.7 L4 22 23 18 19 20 21.5 22.5 23.5 18.5 19.5 21 22 23 19 20.5 21.5 22.5 17.5 18.5 20 21 22 23 18 SS5J3-60PD□-□U-X225 n: Stations 2 3 4 6 7 8 9 10 12 13 14 18 19 22 1 5 11 15 16 17 20 21 24 185.5 210.5 223 285.5 310.5 L1 110.5 123 135.5 148 160.5 173 185.5 198 235.5 235.5 248 260.5 273 298 298 335.5 125 150 175 175 187.5 200 212.5 225 250 262.5 275 300 325 87.5 100 112.5 112.5 137.5 162.5 225 237.5 287.5 287.5 102.5 112.5 132.5 142.5 152.5 162.5 172.5 182.5 192.5 202.5 212.5 222.5 232.5 242.5 292.5 L4 21 22 23.5 18 19.5 20.5 21.5 23 24 19 20 21 22.5 23.5 18.5 19.5 20.5 22 23 24 19 20 21.5 22.5 SS5J3-60PD□-□B-X225 n: Stations 7 1 2 3 4 5 6 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 24 23 110.5 123 123 135.5 148 160.5 173 185.5 185.5 198 210.5 223 235.5 235.5 248 260.5 273 285.5 298 298 310 5 323 335.5 348 100 112.5 112.5 125 137.5 150 162.5 175 175 187.5 200 212.5 225 225 237.5 250 262.5 275 287.5 287.5 300 312.5 325 337.5 82.7 92.7 102.7 112.7 122.7 132.7 142.7 152.7 162.7 172.7 182.7 192.7 202.7 212.7 222.7 232.7 242.7 252.7 262.7 282.7 292.7 302.7 272.7 L4 23.5 18 20.5 23 24 19 20 22.5 23.5 19.5 20.5 22 19 21.5 23.5 19.5 21.5 21 18.5 23 24 20 121 SMC

Symbol

-X225

## Made to Order **SJ1000/2000/3000** Series

Symbol

-X225

#### L: Dimensions

3 Low-profile SUP/EXH Block Specification

SS5J3	3-60SV	//Q□D	-□U-X	225											r	: Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	123	135.5	148	148	160.5	173	185.5	198	198	210.5	223	235.5	248	260.5	260.5	273
L2	112.5	125	137.5	137.5	150	162.5	175	187.5	187.5	200	212.5	225	237.5	250	250	262.5
L3	92.9	102.9	112.9	122.9	132.9	142.9	152.9	162.9	172.9	182.9	192.9	202.9	212.9	222.9	232.9	242.9
L4	15	16	17.5	12	13.5	14.5	15.5	17	11.5	13	14	15	16.5	17.5	12.5	13.5
L	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
L1	285.5	298	310.5	310.5	323	335.5	348	360.5	373	373	385.5	398	410.5	423	423	435.5
L2	275	287.5	300	300	312.5	325	337.5	350	362.5	362.5	375	387.5	400	412.5	412.5	425
L3	252.9	262.9	272.9	282.9	292.9	302.9	312.9	322.9	332.9	342.9	352.9	362.9	372.9	382.9	392.9	402.9
L4	14.5	16	17	12	13	14	15.5	16.5	17.5	12.5	13.5	15	16	17	12	13

#### SS5J3-60SV/Q□D-□B-X225 n: Stations 1 2 3 5 6 8 9 10 11 12 13 14 15 16 L1 135.5 148 148 160.5 173 185.5 198 198 210.5 223 235.5 248 260.5 260.5 273 285.5 125 237.5 L2 137.5 137.5 150 162.5 175 187.5 187.5 200 212.5 225 250 250 262.5 275 L3 103.1 113.1 123.1 173.1 223.1 233.1 243.1 253.1 133.1 143.1 153.1 163.1 183.1 193.1 203.1 213.1 L4 17.5 17.5 12.5 14.5 16 12 13.5 14.5 15.5 17 11.5 13 14 15 16.5 13.5 17 18 19 20 22 23 24 25 26 27 28 29 30 31 32 21 L1 298 310.5 335.5 360.5 410.5 435.5 310.5 323 348 373 373 385.5 398 423 423 448 L2 287.5 300 350 362.5 362.5 412.5 412.5 425 437.5 300 312.5 325 337.5 375 387.5 400 L3 263.1 283.1 353.1 393.1 403.1 413.1 273.1 293.1 303.1 313.1 323.1 333.1 343.1 363.1 373.1 383.1 L4 14.5 16 17 12 13 14 15.5 16.5 17.5 12.5 13.5 15 16 17 12 13

SS5J3	3-60S6	BD-	□U-X2	25											n	n: Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	135.5	148	160.5	173	185.5	185.5	198	210.5	223	235.5	235.5	248	260.5	273	285.5	298
L2	125	137.5	150	162.5	175	175	187.5	200	212.5	225	225	237.5	250	262.5	275	287.5
L3	110.1	120.1	130.1	140.1	150.1	160.1	170.1	180.1	190.1	200.1	210.1	220.1	230.1	240.1	250.1	260.1
L4	12.5	14	15	16.5	17.5	12.5	14	15	16.5	17.5	12.5	14	15	16.5	17.5	19

SS5J3	3-60S6	B□D-	□B-X2	25											r	n: Stations
L n	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	148	160.5	173	185.5	185.5	198	210.5	223	235.5	235.5	248	260.5	273	285.5	298	298
L2	137.5	150	162.5	175	175	187.5	200	212.5	225	225	237.5	250	262.5	275	287.5	287.5
L3	120.3	130.3	140.3	150.3	160.3	170.3	180.3	190.3	200.3	210.3	220.3	230.3	240.3	250.3	260.3	270.3
L4	14	15	16.5	17.5	12.5	14	15	16.5	17.5	12.5	14	15	16.5	17.5	19	14

SS5	J3-60	)-□U-	X225	;															n:	Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	85.5	98	98	110.5	123	135.5	148	148	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	260.5	273
L2	75	87.5	87.5	100	112.5	125	137.5	137.5	150	162.5	175	187.5	200	200	212.5	225	237.5	250	250	262.5
L3	52.9	62.9	72.9	82.9	92.9	102.9	112.9	122.9	132.9	142.9	152.9	162.9	172.9	182.9	192.9	202.9	212.9	222.9	232.9	242.9
L4	16	17.5	12.5	13.5	14.5	15.5	17	12	13	14	15	16.5	17.5	12.5	13.5	14.5	16	17	12	13

SS5	J3-60	)-□B-	-X225	;															n:	Stations
L	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	98	98	110.5	123	135.5	148	148	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	260.5	273	285.5
L2	87.5	87.5	100	112.5	125	137.5	137.5	150	162.5	175	187.5	200	200	212.5	225	237.5	250	250	262.5	275
L3	63.1	73.1	83.1	93.1	103.1	113.1	123.1	133.1	143.1	153.1	163.1	173.1	183.1	193.1	203.1	213.1	223.1	233.1	243.1	253.1
L4	17.5	12.5	13.5	14.5	15.5	17	12	13	14	15	16.5	17.5	12.5	13.5	14.5	16	17	12	13	14



Construction

Plug-in

EX510 EX180

Non Plug-in

SJ3A6

Plug-in

122

## **Vacuum Release Valve with Restrictor**

## SJ3A6 Series

## Plug-in Type


p. 127

**Connector Connection** 

**D-sub Connector** Flat Ribbon Cable Serial Wiring: EX180 Serial Wiring: EX510 p. 129

**Cable Connection** 

**D-sub Connector** Flat Ribbon Cable





## Non Plug-in Type Individual Wiring

p. 133

**Individual Wiring** 



Construction Common Specificatio

Plug-in

EX510 EX180

Non Plug-in


Made to Order

SJ3A6

Plug-in


## SJ3A6 Series

## **Common Specifications**





#### Symbol



#### **Response Time**

Valve model	Response time [ms] (at 0.5 MPa)
SJ3A6-□□-□	19

#### Weight

Valve model	Weight [g]
SJ3A6-□□-P	79

#### **Manifold Valve Specifications**

Valve construction		3-position 3-port valve with restrictor	
Fluid		Air	
Operating	Release pressure port 1(P)	0.25 to 0.7	
pressure	Vacuum pressure port 3/5(E)	−100 kPa to 0.7*1	
range [MPa]	Pilot X port	0.25 to 0.7* <sup>2</sup>	
Ambient and flu	iid temperatures [ °C]	-10 to 50 (No freezing)	
Max. operating frequency [Hz]		3	
Manual override (Manual operation)		Non-locking push type	
		Push-turn locking slotted type	
Restrictor operation		Manual	
nestrictor opera	ation	Slotted locking type	
Pilot method		External pilot/Pilot valve individual exhaust	
Lubrication		Not required	
Mounting orientation		Unrestricted	
Impact/Vibratio	n resistance [m/s²]*3	150/30	
Enclosure		Dustproof	

- \*1 Can be used with positive pressure to suit the application
- \*2 Please use with pilot X port pressure equal to or higher than the release port 1(P) pressure.
- \*3 Impact resistance : No malfunction occurred when it is tested with a drop tester in the axial direction and at the right angles to the main valve and armature in both energized and de-energized states every once for each condition. (Value in the initial state)

Vibration resistance: No malfunction occurred in one sweep test between 45 and 2000 Hz in the axial direction and at the right angles to the main valve and armature in both energized and de-energized states for each condition. (Value in the initial state)

#### **Solenoid Specifications**

Coil rated voltage		24 VDC, 12 VDC
Allowable voltage fluctuation		±10 % of rated voltage*1
Standard		0.4
Power consumption [W]	With power-saving circuit	0.15*2
consumption [w]	(Continuous duty type)	[Starting 0.4, Holding 0.15]
Surge voltage suppressor		Diode
Indicator type		LED

\*1 For the allowable voltage fluctuation for Z/T type (with power-saving circuit), please observe the following range because they have voltage drop due to internal circuit.
Z type 24 VDC: -7 % to +10 %

Z type 24 VDC: -7 % to +10 % 12 VDC: -4 % to +10 % T type 24 VDC: -5 % to +10 % 12 VDC: -6 % to +10 %

\*2 Refer to page 140 for details.


#### **Flow Rate Characteristics**

#### Flow Rate Characteristics (When restrictor is fully open)

Valve model	Fluid passage		1(P) -	→ 2(B)			2(B) →	3/5(E)	
valve model	2(B) Port size	C [dm <sup>3</sup> / (s·bar)]	р	Cv	Q [l/min/ (ANR)]*1	C [dm <sup>3</sup> / (s·bar)]	b	Cv	Q [l/min/ (ANR)]*1
SJ3A6-□□-□	M5	0.24	0.19	0.05	57	0.40	0.18	0.10	95

<sup>\*1</sup> These values have been calculated according to ISO 6358 and indicate the flow rate under standard conditions with an inlet pressure of 0.6 MPa (relative pressure) and a pressure drop of 0.1 MPa.

#### Restrictor Flow Rate Characteristics [Fluid passage: $1(P) \rightarrow 2(B)$ ]






## SJ3A6 Series


## **Construction/Circuit Example**

#### Construction

#### **Connector type**



#### Cable type



#### **Component Parts**

No.	Description	Material	Note
1	Spool valve	Resin/HNBR	A side (for release pressure switching)
2	Spool valve	Resin/HNBR	B side (for vacuum pressure switching)
3	Body	Zinc die-cast	_
4	Adapter plate	Resin	White
5	Pilot adapter	Resin	White
6	Pilot valve	_	_
7	End cover	Resin	White
8	Restrictor block*1	Resin	White
9	Bottom cover	Resin	White
10	Light cover	Resin	Light blue

 $\ast 1$  Set the operating torque of the restrictor of the restrictor block to 0.3 N·m or less.


#### **Component Parts**

No.	Description	Part no.	Note
11	Plug	M-5P	PS port with plug
12	Filter assembly	SJ3000-110-1A	1 μm White <release pressure="" side=""></release>
13	Filter	SJ3000-107-1A	1 μm White <release pressure="" side="">, 5 pcs. included</release>
14	Filter assembly	SJ3000-110-2A	30 µm Light purple <vacuum pressure="" side=""></vacuum>
15	Filter	SJ3000-107-2A	30 μm Light purple <vacuum pressure="" side="">, 5 pcs. included</vacuum>

#### <Filter replacement instructions>

If there are situations such as filter clogging, a drop in suction force, or slow response time, stop operation and replace the filter.

- 1. Using a precision driver, remove the filter assembly (② or ④) from the main unit.
- 2. Turn the filter guide by hand and remove.
- Replace the filter (<sup>3</sup> or <sup>5</sup>) and gently hand tighten the filter guide. At this time, check that there is no foreign matter on the O-ring of the filter assembly.
- 4. Return the filter assembly to the main unit. (Tightening torque: 0.12 N·m)



After tightening the plug (M-5P) with a tightening torque of 1 N·m, or manually tightening, use the tightening tool and tighten it by 1/4 turn.


1214 Filter assembly (with filter)

1315 Filter (5 pcs. included)





## **Adsorbing and Transferring System Circuit Example**



Common Specifications

in Construction

Plug-in

EX510 EX180 Plat Ril

Non Plug-in

d Indi

Ma O

SJ3A6

ımon Spec. nstruction

Plug-in

D-sub Flat Ribbon Serial

> Non Plug-in

Individual Wiring

Specific Product Precautions

## 

## Vacuum Release Valve with Restrictor RoHS




# SJ3A6 Series

**How to Order** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

#### ●Vacuum release valve manifold with restrictor



 Vacuum release valve with restrictor type

#### 2 Connector type

mbol	Mounting position	Page	Note
F	D-sub connector		
Р	Flat ribbon cable with 26 pins	20	Dorollol wiring
PG	Flat ribbon cable with 20 pins	29	Parallel wiring
РН	Flat ribbon cable with 10 pins		
S	EX180 serial transmission	61	Serial wiring
6B□	EX510 serial transmission	77	Serial Willing
֡	F P PG PH	F D-sub connector P Flat ribbon cable with 26 pins G Flat ribbon cable with 20 pins H Flat ribbon cable with 10 pins EX180 serial transmission	F D-sub connector P Flat ribbon cable with 26 pins PG Flat ribbon cable with 20 pins PH Flat ribbon cable with 10 pins EX180 serial transmission 61

#### 3 Connector entry

With parallel wiring specifications, it is necessary to select the connector entry direction (1: upward, 2: lateral). For details, refer to page 29.

#### 4 Valve stations

#### F: D-sub connector

Symbol	Stations
01	1 station
:	:
12	12 stations

Symbol	Stations
01	1 station
:	:
12	12 stations

#### P: Flat ribbon cable (26 pins) PG: Flat ribbon cable (20 pins)

Symbol	Stations
01	1 station
:	:
09	9 stations

Symbol	Stations
01	1 station
:	:
04	4 stations

Symbol	Stations
01	1 station
:	:
08	8 stations

#### PH: Flat ribbon cable (10 pins) S6B□: EX510 serial transmission S□: EX180 serial transmission

Symbol	Stations	Note
01	1 station	There are limitations on the station
	:	number, depending on the serial
16	16 stations	type. Refer to page 61 for details.

#### 5 SUP/EXH block mounting position

U U side		
D	<b>D</b> D side	
В	Both sides	
M*1 Special specification		

\*1 Specify the required specifications (including port sizes other than Ø 8) on the manifold specification sheet.

#### \* This number also includes the blanking block. For the blanking block, please select double wiring specifications.

#### 6 SUP/EXH block fitting specification

_	L	В
Straight fitting X, PE port: Elbow fitting	Elbow fitting (Upward) X, PE port: Straight fitting	Elbow fitting (Downward) X, PE port: Elbow fitting

There is no need to enter anything when the SUP/EXH block mounting position "M" is selected. Also, this manifold comes standard with external pilot specifications.


#### DIN rail length necified

- Spr	specified			
_	Standard length			
2	2 stations   Specify a length			
÷	:	longer than that of		
16	16 stations	the standard rail.		

Specify the number of valve stations without exceeding the max. number of stations.

## **How to Order Manifold Assembly**

### Ordering example (SS3J3-V60PD2-□)



- SS3J3-V60PD2-06D...... 1 set (Manifold part no.)
- SJ3A6-5CU-DP ..... 4 sets (Non-polar type, with plug part no.)
- SJ3A6-5CZJ-P .....1 set (With switch, plug part no.)
  - SJ3A6-5MZ-P..... 1 set (Individual wiring, lead wire length 300 mm, with plug part no.)

The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the solenoid valves, etc.

- For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.
- \* When ordering a manifold, specify the part nos. of the valves to be mounted on it (An order cannot be placed with only the manifold part no.)

#### SJ 1000 2000 3000 4000

Common Specifications 000

Construction

Plug-in

EX510 EX180 Flat

Non Plug-in

Individual Wiring

Manifold Options


\_\_\_\_

SJ3A6

ommon Spec. Construction

## Specific Product Precautions

#### How to Order Solenoid Valves (3-Position 3-Port with Restrictor)



#### 1 Coil type

_	Standard	
т	With power-saving circuit	
•	(Continuous duty type)	

 Be sure to select the power-saving circuit type if the valve is to be continuously energized for long periods of time.

#### 2 Rated voltage

<u> </u>	iaica voitage
5	24 VDC
6	12 VDC


 Only 24 VDC is available for manifolds compatible with serial wiring.

#### 3 Common specification

_	Positive common
N	Negative common

- \* Leave blank for the non-polar type.
- \* When the standard valve and valve with a switch are used on a manifold compatible with the serial transmission system, select a common specification that matches the SI unit common specification.

### 4 Connector entry



- $* \ \ Connector\ entries\ with\ the\ symbol\ "M\square"\ cannot\ use\ the\ switch\ signal\ from\ the\ common\ wiring\ on\ the\ manifold.$
- \* When ordering a connector assembly separately, refer to pages 144 and 145.

## 5 Light/surge voltage suppressor

8 Needle operation

-: Manual

U	With light/surge voltage suppressor (Non-polar type)
Z	With light/surge voltage suppressor (Polar type)


\* When the type with a power-saving circuit, with a switch, or with individual wiring is used, the non-polar type cannot be selected.

D: Slotted locking

#### **6** With switch




#### 9 PS port for detection



\* When mounting a pressure sensor, etc., select "—."

## Manual override



\* No slide locking type manual override setting is provided.

\* Set operation torque to 0.3 N·m or less.


\* There is no valve lock switch for linking the neighboring valve, etc., to the 3-position 3-port solenoid valve with restrictor. Please contact SMC if you wish to use the SJ1000/2000/3000 valve with a valve lock switch, or an end block or SUP/EXH block.

## Plug-in Cable Type ( CA CA CA US **Vacuum Release Valve with Restrictor** SJ3A6 Series

**How to Order** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

Vacuum release valve manifold with restrictor



- Vacuum release valve with restrictor type
- 2 Cable type
- **5** Connector entry

With parallel wiring specifications, it is necessary to select the connector entry direction (1: upward, 2: lateral). For details, refer to page 33.

#### 3 Connector type

Symbol	Mounting position	Page	Note
F	D-sub connector		
Р	Flat ribbon cable with 26 pins	33	Darallal wiring
PG	Flat ribbon cable with 20 pins	33	Parallel wiring
PH	Flat ribbon cable with 10 pins		

F: D-sub connecte	
Symbol	Stations
02	2 stations
÷	:
10	10 stations

Symbol	Stations	
02	2 stations	
:	:	
09	9 stations	

#### 6 Valve stations

P: Flat	le (26 pins	
Symbol	Stations	
02	2 stations	
:	:	
10	10 stations	

#### PG: Flat ribbon cable (20 pins) PH: Flat ribbon cable (10 pins)

Symbol	Stations
02	2 stations
:	:
04	4 stations

- This number also includes the blanking block.
- \* The cable type is only applicable when there are 2 or more stations.

#### 4 Connector mounting position

Symbol	Mounting position
D	D side

#### SUP/EXH block mounting position

U	U side			
D	D side			
В	Both sides			
M*1 Special specification				

\*1 For the special specifications, a port size of the SUP/EXH block can be specified. At this time, the mounting position becomes only U, D, or B.

#### 8 SUP/EXH block fitting specification

_	_		L		В
Straight fitting X, PE port: Elbow fitting		Elbow fitting (Upward) X, PE port: Straight fitting		Elbow fitting (Downward) X, PE port: Elbow fitting	
There is no most to enter anything when the CLID/EVII black mounting position "M" is collected. Also, this monifold comes					

There is no need to enter anything when the SUP/EXH block mounting position "M" is selected. Also, this manifold comes standard with external pilot specifications.


#### 9 DIN rail length specified

_	Standard length		
3	3 stations	Specify a length	
÷	:	longer than that of	
10	10 stations	the standard rail.	

When specifying a length longer than that of the standard rail, select the number of valve stations without exceeding the max. number of stations.

## **How to Order Manifold Assembly**

### Ordering example (SS3J3-V60LPD2-□)



- SS3J3-V60LPD2-06D .....1 set (Manifold part no.) SJ3A6-5FZ-DP .....4 sets (With plug part no.) SJ3A6-5FZ-P----2 sets (With plug part no.)
- The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the solenoid valves, etc.
- For the valve arrangement, the valve closest to the D side is
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

Construction Specifications

Plug-in


D-sub Flat Ribbon EX510 EX180

Non Plug-in

Manifold Options

## SJ3A6

#### How to Order Solenoid Valves (3-Position 3-Port with Restrictor)



#### Coil type

• • • • • • • • • • • • • • • • • • •		
	Standard	
Т	With power-saving circuit (Continuous duty type)	

\* Be sure to select the power-saving circuit type if the valve is to be continuously energized for long periods of time.


### 2 Rated voltage

5	24 VDC
6	12 VDC

#### 3 Common specification

_	Positive common
N	Negative common


#### 4 Connector entry



#### 5 Light/surge voltage suppressor


Z With light/surge voltage suppressor

#### 6 Manual override




\* No slide locking type manual override setting is provided.

#### Needle operation



\* Set operation torque to 0.3 N·m or less.

#### 8 PS port for detection




\* When mounting a pressure sensor, etc.,


\* There is no valve lock switch for the 3-position 3-port solenoid valve with restrictor.


## SJ3A6 Series

#### **Dimensions**



For EX180 serial wiring: p. 69, 70 For EX510 serial wiring: p. 83, 84





Individual Wiring Specific Product Precautions

## Non Plug-in Individual Wiring CE CA CAUS



## Vacuum Release Valve with Restrictor RoHS




# SJ3A6 Series

**How to Order** 

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

#### Individual wiring manifold



 Vacuum release valve with restrictor type

#### 2 Valve stations

Symbol	Stations
01	1 station
:	
20	20 stations

\* This number also includes the blanking block.

#### SUP/EXH block mounting position

U	U side	
D	D side	
В	Both sides	
M*1	Special specifications	

Specify the required specifications (including port sizes other than Ø 8) on the manifold specification sheet.

#### 4 SUP/EXH block fitting specification

_		L		В
Straight fitting X, PE port: Elbow fitting	Elbow fitting (Upward) X, PE port: Straight fitting		Elbow fitting (Downward) X, PE port: Elbow fitting	

\* There is no need to enter anything when the SUP/EXH block mounting position "M" is selected. Also, this manifold comes standard with external pilot specifications.

#### 5 DIN rail length specified


_	Standard length			
2	2 stations	Specify a length		
:		longer than that of		
20	10 stations	the standard rail.		

Specify the number of valve stations without exceeding the max. number of stations.

#### **How to Order Manifold Assembly**

#### Ordering example (SS3J3-V60-□) With plug (24 VDC) With plug (24 VDC) SJ3A6N-5MZ-P (2 sets) SJ3A6N-5MZ-DP (4 sets) SS3J3-V60-06D .....1 set (Manifold part no.) SUP/EXH block (D side mounting) SJ3A6N-5MZ-DP-----4 sets (With plug part no.) SJ3A6N-5MZ-P .....2 sets (With plug part no.) The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the solenoid valves, etc. For the valve arrangement, the valve closest to the D side is considered the 1st station. Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

#### How to Order Solenoid Valves (3-Position 3-Port with Restrictor)



#### Coil type

	71
	Standard
Т	With power-saving circuit (Continuous duty type)

Be sure to select the power-saving circuit type if the valve is to be continuously energized for long periods of time.

#### 2 For non plug-in only


<u> 3</u> f	Rated	١	/(	)	lta	ag	е
_		_				_	

5	24 VDC
6	12 VDC


#### 4 Common specification

_	Positive common
N	Negative common

**5** Connector entry




(With connector, socket) . Without linkage-printed circuit board



6 With light/surge voltage suppressor


\* When ordering a connector assembly separately, refer to pages 144 and 145.

#### Manual override




\* No slide locking type manual override setting is provided.

#### 8 Needle operation



\* Set operation torque to 0.3 N·m or less.

#### 9 PS port for detection





\* When mounting a pressure sensor, etc.,


## SJ3A6 Series

#### **Dimensions**

#### SS3J3-V60-Stations U/D/B








Since DIN rail dimensions are the same as the SS5J3-60- $\square$  series, refer to pages 99 and 100.



## SJ3A6 Series

## **Manifold Exploded View**

#### **Connector Type/Individual Wiring**



	ponent Parts: F	Plug-in (Connector Type)		
No.		Description	Part no.	Note
a + 1		External pilot	SJ3000-50-1AR-□□-N (X, PE port: Metric size Ø 4 Inch size Ø 5/32)	(Metric size) C6: With O 6 One-touch fitting (straight) C8: With O 8 One-touch fitting (straight) L6: With O 6 One-touch fitting (elbow upward entry) L8: With O 8 One-touch fitting (elbow upward entry)
1*1 S	SUP/EXH block	For different pressures*2	SJ3000-50-3A-□□-N	B6: With Ø 6 One-touch fitting (elbow downward entry) B8: With Ø 8 One-touch fitting (elbow downward entry) (Inch size) N7: With 1/4" One-touch fitting (straight) N9: With 5/16" One-touch fitting (straight)
2*1	End block		SJ3000-53-1A-N	For the U side
3	Connector block		SJ3000-42-□A-□	Refer to the connector block part nos. shown below.
4	4 DIN rail		VZ1000-11-1-□	Refer to page 106.
5	5 SI unit		EX180-□□	Refer to the SI unit part nos. on page 61.
7	7 O-ring for valve connection*3		SJ3000-96-1A	The part no. shown on the left includes parts for 5 units. (10 pcs. each for the P and E ports and for the X and PE ports)

#### Connector Block Part Nos.

Connector specifications	Mounting position	Part no.	Note
For D-sub connector (Locking bracket: Metric size thread)		SJ3000-42-1A-□	
For D-sub connector (Locking bracket: Unified thread)		SJ3000-42-1AU-	
For flat ribbon cable with 26 pins		SJ3000-42-2A-□	U. 1 (Connector unword)
For flat ribbon cable with 20 pins	D side	SJ3000-42-3A-□	☐: 1 (Connector upward)
For flat ribbon cable with 10 pins		SJ3000-42-4A-□	☐: 2 (Connector lateral)
For EX180 serial wiring*4		SJ3000-42-20A	
For EX510 serial wiring*4		SJ3000-42-3A-2	

\*4 An SI unit is not included.

Component Parts: Non plug-in (Individual Wiring)

No.		Description	Part no.	Note
<b>1</b> *1	CUD/EVII blook	External pilot	SJ3000-50-5AR-□□-N (X, PE port: Metric size O 4 ) Inch size O 5/32	C8: With Ø 8 One-touch fitting (straight)
1*'	SUP/EXH block	For different pressures*2	SJ3000-50-6A-□□-N	B6: With Ø 6 One-touch fitting (elbow downward entry) B8: With Ø 8 One-touch fitting (elbow downward entry) (Inch size) N7: With 1/4" One-touch fitting (straight) N9: With 5/16" One-touch fitting (straight)
2*1	End block		SJ3000-53-1A-N	For the U side
4	DIN rail		VZ1000-11-1-□	Refer to page 106.
6	End block		SJ3000-53-2A	For the D side
7	O-ring for valve connection*3		SJ3000-96-1A	The part no. shown on the left includes parts for 5 units. (10 pcs. each for the P and E ports and for the X and PE ports)

<sup>\*1</sup> For the SJ3A6 series, valve lock and manual switches are not available.

st Refer to page 103 for the SUP/EXH block disk and method of handling parts at different pressures.



ecifications

Construction

Plug-in

EX510 EX180 Flat Ribt

Non Plug-in

Maivi

Mai

SJ3A6

mon Spec. nstruction

o ui-gi

D-sub lat Ribbon Serial

> Non Plug-in

ndividual Wiring

pecific Product
Precautions


<sup>\*2</sup> As the valves cannot be operated only with the SUP/EXH block for different pressures, select them in combination with the SUP/EXH block for external pilot.

<sup>\*3</sup> Included with valves, SUP/EXH blocks, and connector blocks

#### **Cable Type**

Type V60LP (Vacuum release valve with restrictor) manifold

\* Refer to page 91 for "How to Increase Manifold Stations."




Component Parts: Plug-in (Cable Type)

No.	Des	scription	Part no.	Note
<b>4</b> ±1	SUP/EXH block	External pilot	SJ3000-50-5AR-□□-N (X, PE port: Metric size Ø 4 Inch size Ø 5/32	(Metric size) C6: With Ø 6 One-touch fitting (straight) C8: With Ø 8 One-touch fitting (straight) L6: With Ø 6 One-touch fitting (elbow upward entry) L8: With Ø 8 One-touch fitting (elbow upward entry)
1*1	SUP/EXTI DIOCK	For different pressures*2	SJ3000-50-6A-□□-N	B6: With O 6 One-touch fitting (elbow downward entry) B8: With O 8 One-touch fitting (elbow downward entry) (Inch size) N7: 1/4" One-touch fitting (straight) N9: 5/16" One-touch fitting (straight)
<b>2</b> *1	End block		SJ3000-53-1A-N	
3	Connector block		SJ3000-42-□A-□	Refer to the connector block part nos. shown below.
4	DIN rail		VZ1000-11-1-□	Refer to page 106.
5	O-ring for valve connection*3		SJ3000-96-1A	The part no. shown on the left includes parts for 5 units. (10 pcs. each for the P and E ports and for the X and PE ports)

- \*1 For the SJ3A6 series, valve lock and manual switches are not available.
- \*2 As the valves cannot be operated only with the SUP/EXH block for different pressures, select them in combination with the SUP/EXH block for external pilot.
- \*3 Included with valves, SUP/EXH blocks, and connector blocks

  \* Refer to page 103 for the SUP/EXH block disk and method of handling parts at different pressures.

#### **●**Connector Block



#### Connector type

7	D-sub connector
8	Flat ribbon cable with 26 pins
9	Flat ribbon cable with 20 pins
10	Flat ribbon cable with 10 pins

- \* All connector block mounting positions are on the D side.
- The connector block includes the cables necessary for the number of stations.

## 2 Locking bracket

_	Metric size thread
U	Unified thread

\* D-sub connector only

#### 3 Connector entry direction

1	Upward
2	Lateral

#### 4 Valve stations

02 to 10	D-sub connector
	Flat ribbon cable with 26 pins
	Flat ribbon cable with 20 pins
02 to 04	Flat ribbon cable with 10 pins





Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu

#### **Manual Override Switch Operation**

## **∕** Warning

For manual override operation, move the manual override switch to a position where letters A and B can be seen. [Manual override switch release status (refer to the figure below)] Operation with the manual override switch in a locked status can cause damage to the manual override and air leakage, so be sure to release the manual override switch before use. After manual override operation, lock the manual switch for use (when the manual override of the push-turn locking slotted type is locked, a manual override switch cannot be locked).





Manual override switch slide direction

Manual override switch locked status


### **Manual Override Operation**

## ∕∖\ Warnind

When the manual override is operated, connected equipment will be actuated. Confirm safety before operating.


#### ■Non-locking push type

Press in the direction of the arrow.



#### ■Push-turn locking slotted type


While pressing, turn in the direction of the arrow (90° clockwise). If it is not turned, it can be used in the same way as the nonlocking push type.



Enlarged view of manual override part

#### ■Slide locking type (manual override)

Slide the manual override all the way to the ON side in the arrow direction. The manual override is then locked. To unlock the manual override, slide it toward the OFF side in the arrow




When you operate the D type with a screw driver, turn it gently using a watchmaker's screw driver. [Torque: under 0.05 N·m] When you lock the manual override of the D type, be sure to push it before turning. [Load: 10 N or less] Turning without pushing can cause damage to the manual override and trouble such as air leakage, etc.

#### Valve with Switch

## **∕** Warning

When turning OFF the valve using the switch, move it to the position where the valve is locked. If the switch is at an improper position and is energized, equipment connected to the valve could be actuated.


Also, if the switch is turned OFF on the valve in the energized state, be careful because any actuators connected to a single solenoid, a dual 3-port valve, or a 3-position valve will actuate.




Normal operation: The valve is switched according to electric signals from the connector on the manifold side

The valve coil is kept in a deenergized state even when there is an electric signal from the connector on the manifold

Electric circuit diagram (with positive common and light/surge voltage suppressor)



(with negative common and light/surge voltage suppressor)



#### **Built-in Back Pressure Check Valve Type**

## **∕∖** Caution

1. Valves with built-in back pressure check valve is to protect the back pressure inside a valve. For this reason, use caution the valves with external pilot specification cannot be pressurized from exhaust port [3/5(E)].

As compared with the types which do not integrate the back pressure check valve, C value of the flow rate characteristics (sonic conductance) goes down. For details, please contact SMC.

2. Do not switch valves when A or B port is open to the atmosphere, or while the actuators and air operated equipment are in operation. The back pressure prevention seal may be peeled off, which may cause air leakage or malfunctions. Use caution especially when performing a trial operation or maintenance work.

#### **Exhaust Throttle**

## Caution

The SJ series pilot valve and main valve share a common exhaust inside the valve. Therefore, do not block the exhaust port when arranging the piping.

Construction

Plug-in

D-sub Flat Ribbon EX180 EX510

Non Plug-in

SJ3A6

Plug-in







Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu

#### Used as a 3-Port Valve

### **⚠** Caution

#### ■When using a 4-port valve as a 3-port valve


The SJ1000/2000/3000/4000 series can be used as normally closed (N.C.) or normally open (N.O.) 3-port valves by closing one of the cylinder ports 4(A) or 2(B) with a plug. However, they should be used with the exhaust ports kept open. They are convenient at times when a double solenoid type 3-port valve is required.

Plug position		2(B) port	4(A) port		
Тур	e of actuation	N.C.	N.O.		
Number of solenoids	Single	(A)4 2(B) (R1)5 1 3(R2) (P)	(A)4 2(B) (R1)513(R2) (P)		
	Double	(A)4 2(B) (R1)5 1 3(R2) (P)	(A)4 2(B) (R1)513(R2) (P)		


#### **Light/Surge Voltage Suppressor**

## **A** Caution

## ■Non-polar type Single solenoid





#### Double solenoid, 3-position type



#### ■Positive common Single solenoid


#### Double solenoid, 3-position type






## ■Negative common Single solenoid

#### Double solenoid, 3-position type





#### **Continuous Duty**

### **⚠** Caution


If a valve is energized continuously for long periods of time, the rise in temperature due to heat-up of the coil assembly may cause a decline in valve performance, reduce the service life, or have adverse effects on peripheral equipment. If the valve is energized continuously for long periods of time, be sure to use a valve with power-saving circuit (continuous duty type). In particular, if three or more adjacent stations on the manifold are energized simultaneously for extended periods of time or if the valves on A side and B side are energized simultaneously for long periods of time, take special care as the temperature rise will be greater.

If the continuously energized time exceeds three hours, please contact SMC.


#### **■**With power-saving circuit

Power consumption is decreased to approx. 1/3 (for SJ3\[
\]60(A)T and SJ4\[
\]60T) compared with the standard model by reducing the wattage required to hold the valve in an energized state. (Effective energizing time is over 67 ms at 24 VDC.)

#### Electric circuit diagram (with power-saving circuit) In case of positive common, single solenoid



#### In case of negative common, single solenoid






Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu


#### **Working Principle**

The circuit shown on page 139 reduces the power consumption for holding in order to save energy. Refer to the electrical power waveform as shown below.

Electrical power waveform of the power-saving type (SJ3□60(A)T, SJ4□60T)



Electrical power waveform of the power-saving type (SJ1□60T, SJ2□60T)



- The 12 VDC specification with power-saving circuit does not have the polarity protection diode. Do not make a mistake with the polarity.
- Since the voltage will drop by approx. 0.5 V due to the transistor, pay attention to the allowable voltage fluctuation. (For details, refer to the solenoid specifications of each type of valve.)

#### Countermeasure for Surge Voltage Intrusion

#### ■ Surge voltage intrusion

With non-polar type valves, at times of sudden interruption of the loading power supply, such as emergency shutdown, surge voltage intrusion may be generated from loading equipment with a large capacity (power consumption), and a valve in a de-energized state may switch over (see Fig. 1). When installing a breaker circuit for the loading power supply, consider using a valve with polarity (with polarity protection diode), or install a surge absorption diode between the loading equipment COM line and the output equipment COM line (see Fig. 2).




Fig. 1 Surge intrusion circuit example (NPN outlet example) (24 VDC)




Fig. 2 Surge intrusion countermeasure example (NPN outlet example) (24 VDC)

Common pecifications 000

Construction

D-sub Plug-in

EX510 EX180 Fla

vidual Non ring Plug-in

Manifold Options

Made to Order

SJ3A6

Common Spec. Construction

n Plug-in

D-sub Flat Ribbon Serial

dual Non

pecífic Product Precautions






Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu

#### **Light Indication**

## **A** Caution


When equipped with light/surge voltage suppressor, the light window turns red when solenoid a is energized, and it turns green when solenoid b is energized.



#### **Changing the Connector Entry Direction**

## **⚠** Caution

To change the connector's entry direction, set the switch on the top of the connector block to the FREE position, before turning the connector. Make sure to set the switch back to the LOCK position before connecting the connector. (When the switch is difficult to slide, move the connector a little so that it will slide easier.) If an excessive force is applied on the connector in the LOCK position, the connector block may be damaged. Also, using in such a way that the connector floats in the FREE position, it may cause the lead wire, etc., to break. Thus, refrain from using in these ways.



#### **Manifold Mounting**

When attaching a manifold to a mounting surface, etc., with bolts, if the entire bottom surface of the DIN rail contacts the mounting surface in a horizontal mounting, it can be used by simply securing both ends of the DIN rail. However, for any other mounting method or for side facing and rear facing, etc., secure the DIN rail with bolts at uniform intervals using the following as a guide: 2 to 5 stations at 2 locations, 6 to 10 stations at 3 locations, 11 to 15 stations at 4 locations, 16 to 20 stations at 5 locations, 21 to 25 stations at 6 locations, 26 to 30 stations at 7 locations, and more than 30 stations at 8 locations.

In addition, even in the case of a horizontal mounting, if the mounting surface is subject to vibration, etc., take the same measures indicated above. If secured at fewer than the specified number of locations, warping or twisting may occur in the DIN rail and manifold, causing trouble such as air leakage.





Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu

**Fitting Replacement** 

## **⚠** Caution

By replacing a valve's fitting, it is possible to change the port size of the 4(A), 2(B), 1(P), and 3/5(E) ports. When replacing it, pull out the fitting after removing the clip with a flat blade screw driver, etc. To mount a new fitting, insert it into place and then fully reinsert the clip.

#### <For the SJ1000/2000/3000> M5, M3 port block One-touch fitting (Elbow type) One-touch fitting (Long elbow type) One-touch fitting (Straight)

## <For the SJ4000> SUP/EXH block (For the D side) SJ4□60 (Valve)

#### One-touch Fitting Part Nos.

Port	Port size	Part no.		
SJ1000	Ø 2 One-touch fitting (Straight)	KQSY10-C2		
4(A), 2(B)	Ø 4 One-touch fitting (Straight)	KQSY10-C4-X1336		
	Ø 2 One-touch fitting (Straight)	KJH02-C1		
	Ø 4 One-touch fitting (Straight)	KJH04-C1		
SJ2000	Ø 2 One-touch fitting (Elbow type)	KJL02-C1		
4(A)	Ø 4 One-touch fitting (Elbow type)	KJL04-C1-N		
2(B)	Ø 2 One-touch fitting (Long elbow type)	KJW02-C1		
	Ø 4 One-touch fitting (Long elbow type)	KJW04-C1-N		
	M3 port block	SJ2000-56-1A		
	Ø 2 One-touch fitting (Straight)	KJH02-C2		
	Ø 4 One-touch fitting (Straight)	KJH04-C2		
	Ø 6 One-touch fitting (Straight)	KJH06-C2		
0.10000	Ø 2 One-touch fitting (Elbow type)	KJL02-C2		
SJ3000 4(A)	Ø 4 One-touch fitting (Elbow type)	KJL04-C2		
2(B)	Ø 6 One-touch fitting (Elbow type)	KJL06-C2-N		
_(_)	Ø 2 One-touch fitting (Long elbow type)	KJW02-C2		
	Ø 4 One-touch fitting (Long elbow type)	KJW04-C2		
	Ø 6 One-touch fitting (Long elbow type)	KJW06-C2-N		
	M5 port block	SJ3000-56-1A		
SJ4000	Ø 4 One-touch fitting (Straight)	KQSY30-C4		
4(A)	Ø 6 One-touch fitting (Straight)	KQSY30-C6		
2(B)	Ø 8 One-touch fitting (Straight)	KQSY30-C8		
	Ø 6 One-touch fitting (Straight)	VVQ1000-51A-C6		
SJ1000 SJ2000	Ø 6 One-touch fitting (Elbow type)	SZ3000-74-1A-L6		
SJ3000	Ø 6 One-touch fitting (Long elbow type)	SZ3000-74-2A-L6		
1(P)	Ø 8 One-touch fitting (Straight)	VVQ1000-51A-C8		
3/5(E)	Ø 8 One-touch fitting (Elbow type)	SZ3000-74-1A-L8		
	Ø 8 One-touch fitting (Long elbow type)	SZ3000-74-2A-L8		
SJ4000 1(P)	Ø 8 One-touch fitting (Straight)	KQSY31-C8		
3/5(E)	Ø 10 One-touch fitting (Straight)	KQSY31-C10-X133		

#### Inch Size

Port	Port size	Part no.		
	Ø 1/8" One-touch fitting (Straight)	KJH01-C1		
0.10000	Ø 5/32" One-touch fitting (Straight)	KJH03-C1		
SJ2000 4(A)	Ø 1/8" One-touch fitting (Elbow type)	KJL01-C1		
2(B)	Ø 5/32" One-touch fitting (Elbow type)	KJL03-C1		
2(0)	Ø 1/8" One-touch fitting (Long elbow type)	KJW01-C1		
	Ø 5/32" One-touch fitting (Long elbow type)	KJW03-C1		
	Ø 1/8" One-touch fitting (Straight)	KJH01-C2		
	Ø 5/32" One-touch fitting (Straight)	KJH03-C2		
	Ø 1/4" One-touch fitting (Straight)	KJH07-C2		
SJ3000	Ø 1/8" One-touch fitting (Elbow type)	KJL01-C2		
4(A)	Ø 5/32" One-touch fitting (Elbow type)	KJL03-C2		
2(B)	Ø 1/4" One-touch fitting (Elbow type)	KJL07-C2		
	Ø 1/8" One-touch fitting (Long elbow type)	KJW01-C2		
	Ø 5/32" One-touch fitting (Long elbow type)	KJW03-C2		
	Ø 1/4" One-touch fitting (Long elbow type)	KJW07-C2		
1(P)	Ø 1/4" One-touch fitting (Straight)	VVQ1000-51A-N7		
3/5(E)	Ø 5/16" One-touch fitting (Straight)	VVQ1000-51A-N9		

- \* To change the port size of the 1(P) or 3/5(E) ports into port sizes other than O 8 (straight) for the SJ1000/2000/3000 and O 10 (straight) for the SJ4000, specify the change on the manifold specification sheet.
- \* Be careful to avoid damaging or contaminating the O-rings as this can cause air leakage.
- When removing a straight-type fitting from a valve, after removing the clip, attach tubing or a plug (KJP-02, KQ2P-□□) to the One-touch fitting, and pull it out while holding the tubing or plug. If it is pulled out while holding the release button of the fitting (resin part), the release button may be damaged.
- \* Be sure to turn off the power and stop the supply of air before disassembly. Furthermore, since air may remain inside the actuator, piping, and manifold, confirm that the air is completely exhausted before starting any work.
- \* While inserting tubing into an elbow-type fitting, hold the main body of the fitting by hand. Failure to do so will exert an undue force on the valve or the fitting, resulting in air leakage or damage.
- \* Each fitting part no. contains 1 pc. Additionally, when the piping is constructed in the same direction using an elbow-type fitting, order an elbow-type and/or long elbow-type fitting. However, there are no elbow-type or inch-size fitting options for the SJ4000 series.

  \* SJ4000 series One-touch fittings are available in metric sizes (straight) only.

#### Clip Part Nos.

<u></u>							
	Part	Note					
SJ1000	SJ2000	SJ3000	SJ4000	Note			
SJ1000-CL-1	SJ2000-CL-1	SJ3000-CL-1	JSY31M-19P-1A	These part numbers contain 10 pcs. each.			



Construction

Plug-in

EX180 EX510

SJ3A6

Plug-in



Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu


#### **One-touch Fittings**

## **⚠** Caution

The pitch of the SJ series piping ports (A, B, etc.) has been set assuming the use of KJ series One-touch fittings. Therefore, when using fittings with an M3 or M5 port block, there may be some interference between fittings, depending on the type and size, so please use after checking dimensions in the catalogue for the pipe fitting being used.

#### 1. Tube attachment/detachment for One-touch fittings

- 1) Tube attachment
  - (1) Take a tube having no flaws on its periphery and cut it off at a right angle. When cutting the tube, use tube cutters TK-1, 2, or 3. Do not use pinchers, nippers, scissors, etc. If cutting is done with tools other than tube cutters, the tube may be cut diagonally or become flattened, etc., making a secure installation impossible, and causing problems such as the tube pulling out after installation or air leakage.
    - Allow some extra length in the tube.
  - (2) Grasp the tube and push it in slowly, inserting it securely all the way into the fitting.
  - (3) After inserting the tube, pull on it lightly to confirm that it will not come out. If it is not installed securely all the way into the fitting, this can cause problems such as air leakage or the tube pulling out.
- 2) Tube detachment
  - (1) The 4(A) and 2(B) ports use the KJ series, so the tube can be removed by pressing on part of the release button. However, for the 1(P) and 3/5(E) ports, please press the release button evenly as before.
  - (2) Pull out the tube while holding down the release button so that it does not come out. If the release button is not pressed down sufficiently, there will be increased bite on the tube and it will become more difficult to pull it out.
  - (3) When the removed tube is to be used again, cut off the portion which has been chewed before reusing it. If the chewed portion of the tube is used as is, this can cause trouble such as air leakage or difficulty in removing the tube.



Hold down part of the release button with your finger or a similar tool, as shown in the diagram, and pull out in the direction indicated by the arrow.

#### Other Tube Brands

### **⚠** Caution

1. When using other than SMC brand tube, confirm that the following specifications are satisfied with respect to the tube outside diameter tolerance.

1) Nylon tube within ±0.1 mm 2) Soft nylon tube within ±0.1 mm

3) Polyurethane tube within +0.15 mm, within -0.2 mm Do not use tube which does not meet these outside diameter tolerances. It may not be possible to connect them, or they may cause other trouble, such as air leakage or the tube pulling out after connection.

#### **How to Use Plug Connector**


### **∧** Caution

When attaching and detaching a connector, first shut off the electric power and the air supply.

Also, crimp the lead wires and sockets securely.


#### 1. Connector attachment/detachment

- To attach a connector, hold the lever and connector unit between your fingers and insert straight onto the pins of the solenoid valve so that the lever's pawl is pushed into the groove and locks.
- To detach a connector, remove the pawl from the groove by pushing the lever downward with your thumb, and pull the connector straight out.



#### 2. Crimping of lead wires and sockets

Peel 3.2 to 3.7 mm of the tip of the lead wire, enter the core wires neatly into a socket and crimp it with a special crimp tool. Be careful so that the cover of the lead wire does not enter into the crimping part. (Please contact SMC for the dedicated crimping tools.)







Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu

**How to Use Plug Connector** 

## **⚠** Caution


#### 3. Lead wires with sockets attachment/detachment

#### Attachment

Insert the sockets into the square holes of the connector (with A, B, C, and N indication), and continue to push the sockets all the way in until they lock by hooking into the seats in the connector. (When they are pushed in, their hooks open, and they are locked automatically.) Next, confirm that they are locked by pulling lightly on the lead wires.

#### Detachment

To detach a socket from a connector, pull out the lead wire while pressing the socket's hook with a stick having a thin tip (approx. 1 mm). If the socket is used again, spread the hook outward.



(N: Unused)

(N: Unused

#### <Positive common>

# Single solenoid (A: -) (Unused) (N: Unused)



#### <Negative common>

# (A: +) (Unused) (C: -)

Single solenoid



#### **Plug Connector Lead Wire Length**

## **A** Caution


Plug connector lead wires have a standard length of 300 mm, however, the following lengths are also available.

#### **Connector Part Nos.**


Single solenoid Double solenoid,

3-position type, 4-position type

SJ3000-46-S- $\square$  (for positive common) SJ3000-46-D- $\square$  (for positive common) SJ3000-47-S- $\square$  (for negative common) SJ3000-47-D- $\square$  (for negative common)



\*1 In case of negative common, the lead wire changes from red to yellow.



For single solenoid

Without lead wire: SJ3000-46-S-N (positive/negative common) (Connector, Socket x 2 pcs. only)

For double solenoid

Without lead wire: SJ3000-46-D-N (positive/negative common) (Connector, Socket x 3 pcs. only)

#### **How to Order**

Include the connector assembly part number together with the part number for the plug connector's solenoid valve without connector.

(Example) In case of lead wire length 2000 mm and positive common

SJ3160-5MOZ-C6 SJ3000-46-S-20

#### **Connector for Manifolds (for Junction Common)**

## **<b> ∴** Caution

Using the connector (for junction common) for solenoid valves installed in the manifold reduces the labor involved in wiring work because common wiring for all solenoid valves is integrated into a single wire.

n Common Specifications

Construction

Plug-in

EX510 EX180 Flat Ribbon

Non Plug-in

Individua Wiring

Manifold Options

lade to Order

SJ3A6

ommon Spec.

Plug-in

D-sub Flat Ribbon Serial

Non Plug-in

ndividual Wiring







Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu

#### **Connector (for Junction Common) Part Nos.**

Single solenoid

Double solenoid,

(Black)


3-position type, 4-position type

SJ3000-47-SC-□ (for negative common)

SJ3000-46-DC- (for positive common) SJ3000-46-SC- (for positive common) SJ3000-47-DC- (for negative common)


(Black) (White) (Red)\*1 (Red)\*1

\*1 In case of negative common, the lead wire changes from red to yellow



Indicate the part no. of the connector for the manifold and valve. If the arrangement is too complicated, please specify the details on a manifold specification sheet.


- Applications like connectors not wired to a valve are not possible.
- For the valve, please designate "No connector (MOZ)" for the connector type.
- Connector with lead wire for place where the signals are transmitted to the common wiring. (Only the valves of the first station and/or last station of the manifold are compatible to connector with lead wire for common.)



Wiring Instructions for Connector (for Junction Common)

### ∕!\ Caution

If only connector (for junction common) is ordered, please wire according to the instructions in the diagram below.





Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smc.eu

common ecifications 000

Construction

Plug-in

EX510 EX180 | Flat

I Non Plug-ir

Manifold Options

Made 1 Order

SJ3A6

Common Sy Constructi

D-Sub lat Ribbon Serial

lug-in

duct Indiv

#### **One-touch Fittings**

## **⚠** Caution

When fittings are used, they may interfere with one another depending on their types and sizes. Therefore, the dimensions of the fittings to be used should first be confirmed in their respective catalogues.

Fittings whose compliance with the SJ series is already confirmed are stated below. If the fitting within the applicable range is selected, there will not be any interference.

## Applicable Fittings: KQ2H, KQ2S Series KJH, KJS Series

Series	Model	Piping port	Port size	Fitting	Applicable tubing O.D.									
Series					Ø2	Ø 3.2	Ø 4	Ø 6						
SJ3000	SJ3□60-□□-M5	4A, 2B	M5	KQ2H KJH										
(10 mm pitch)				KQ2S KJS										
SJ2000	. SJ2□60-□□-M3	4A, 2B	Mo	KQ2H KJH										
(7.5 mm pitch)	5J2_6UINI3		4A, 2B   W3	4A, 2B IVIS	4A, 2B IVIS	, l	М3	IVIS	4A, 2B W3	4A, 2B   M3	KQ2S KJS			
SJ3A6	S.13Ab-	2B	M5 -	KQ2H KJH										
(10 mm pitch)				KQ2S KJS										

#### Safety Instructions

These safety instructions are intended to prevent hazardous situations and/or equipment damage. These instructions indicate the level of potential hazard with the labels of "Caution," "Warning" or "Danger." They are all important notes for safety and must be followed in addition to International Standards (ISO/IEC) 1), and other safety regulations.

♠ Danger:

Danger indicates a hazard with a high level of risk which, if not avoided, will result in death or serious

Marning:

Warning indicates a hazard with a medium level of risk which, if not avoided, could result in death or serious

Caution indicates a hazard with a low level of risk which, if not avoided, could result in minor or moderate

1) ISO 4414: Pneumatic fluid power - General rules and safety requirements for systems and their components.

ISO 4413: Hydraulic fluid power - General rules and safety requirements for systems and their components.

IEC 60204-1: Safety of machinery - Electrical equipment of machines. (Part 1: General requirements)

ISO 10218-1: Robots and robotic devices - Safety requirements for industrial robots - Part 1: Robots.

#### 

1. The compatibility of the product is the responsibility of the person who designs the equipment or decides its specifications.

Since the product specified here is used under various operating conditions, its compatibility with specific equipment must be decided by the person who designs the equipment or decides its specifications based on necessary analysis and test results. The expected performance and safety assurance of the equipment will be the responsibility of the person who has determined its compatibility with the product. This person should also continuously review all specifications of the product referring to its latest catalogue information, with a view to giving due consideration to any possibility of equipment failure when configuring the equipment.

2. Only personnel with appropriate training should operate machinery and equipment.

The product specified here may become unsafe if handled incorrectly. The assembly, operation and maintenance of machines or equipment including our products must be performed by an operator who is appropriately trained and experienced.

- 3. Do not service or attempt to remove product and machinery/ equipment until safety is confirmed.
  - 1. The inspection and maintenance of machinery/equipment should only be performed after measures to prevent falling or runaway of the driven objects have been confirmed.
  - 2. When the product is to be removed, confirm that the safety measures as mentioned above are implemented and the power from any appropriate source is cut, and read and understand the specific product precautions of all relevant products carefully.
  - 3. Before machinery/equipment is restarted, take measures to prevent unexpected operation and malfunction.
- 4. Our products cannot be used beyond their specifications. Our products are not developed, designed, and manufactured to be used under the following conditions or environments. Use under such conditions or environments is not covered.
  - 1. Conditions and environments outside of the given specifications, or use outdoors or in a place exposed to direct sunlight.
  - 2. Use for nuclear power, railways, aviation, space equipment, ships, vehicles, military application, equipment affecting human life, body, and property, fuel equipment, entertainment equipment, emergency shut-off circuits, press clutches, brake circuits, safety equipment, etc., and use for applications that do not conform to standard specifications such as catalogues and operation manuals.
  - 3. Use for interlock circuits, except for use with double interlock such as installing a mechanical protection function in case of failure. Please periodically inspect the product to confirm that the product is operating properly.

#### **∧** Caution

We develop, design, and manufacture our products to be used for automatic control equipment, and provide them for peaceful use in manufacturing industries.

Use in non-manufacturing industries is not covered.

Products we manufacture and sell cannot be used for the purpose of transactions or certification specified in the

The new Measurement Act prohibits use of any unit other than SI units in Japan.

### Limited warranty and **Disclaimer/Compliance** Requirements

The product used is subject to the following "Limited warranty and Disclaimer" and "Compliance Requirements". Read and accept them before using the product.

#### **Limited warranty and Disclaimer**

- 1. The warranty period of the product is 1 year in service or 1.5 years after the product is delivered, whichever is first. 2) Also, the product may have specified durability, running distance or replacement parts. Please consult your nearest sales
- 2. For any failure or damage reported within the warranty period which is clearly our responsibility, a replacement product or necessary parts will be provided. This limited warranty applies only to our product independently, and not to any other damage incurred due to the failure of the product.
- 3. Prior to using SMC products, please read and understand the warranty terms and disclaimers noted in the specified catalogue for the particular products.
- 2) Vacuum pads are excluded from this 1 year warranty. A vacuum pad is a consumable part, so it is warranted for a year after it is delivered. Also, even within the warranty period, the wear of a product due to the use of the vacuum pad or failure due to the deterioration of rubber material are not covered by the limited

#### **Compliance Requirements**

- 1. The use of SMC products with production equipment for the manufacture of weapons of mass destruction (WMD) or any other weapon is strictly prohibited.
- 2. The exports of SMC products or technology from one country to another are governed by the relevant security laws and regulations of the countries involved in the transaction. Prior to the shipment of a SMC product to another country, assure that all local rules governing that export are known and followed.

#### **Revision History Edition B** - A non plug-in type individual wiring manifold has been - An EX510 serial wiring compatible type has been added A PC wiring compatible type has been added. A regulator block and an intermediate connector block have been added as options. The SJ3A6 series vacuum release valve with restrictor has been added. - Number of pages has been increased from 48 to 96. **Edition C** - A plug-in cable type manifold has been added. - A SUP/EXH block with regulator and pressure switch, and a valve with speed controller have been added as - A slide locking type manual override has been added. - Number of pages has been increased from 96 to 112. - The SJ1000 series has been added. Edition D - A low-profile SUP/EXH block has been added as an option. - Number of pages has been increased from 112 to 120. - The SJ3000A and SJ4000 series have been added. Edition E - Number of pages has been increased from 120 to 148

#### **SMC Corporation (Europe)**

Austria +43 (0)2262622800 www.smc.at Belgium +32 (0)33551464 www.smc.be Bulgaria +359 (0)2807670 www.smc.ba +385 (0)13707288 www.smc.hr Croatia **Czech Republic** +420 541424611 www.smc.cz Denmark +45 70252900 www.smcdk.com Estonia +372 651 0370 www.smcee.ee Finland +358 207513513 www.smc.fi France +33 (0)164761000 www.smc-france.fr Germany +49 (0)61034020 www.smc.de Greece +30 210 2717265 www.smchellas.gr Hungary +36 23513000 www.smc.hu +353 (0)14039000 www.smcautomation.ie Ireland +39 03990691 www.smcitalia.it Italy Latvia +371 67817700 www.smc.lv

office@smc.at
info@smc.be
office@smc.bg
office@smc.hr
office@smc.cz
smc@smcdk.com
info@smcee.ee
smcfi@smc.fi
supportclient@smc-france.fr
info@smc.de
sales@smchellas.gr
office@smc.hu
sales@smcautomation.ie
mailbox@smcitalia.it
info@smc.lv

Lithuania +370 5 2308118 www.smclt.lt Netherlands +31 (0)205318888 www.smc.nl Norway +47 67129020 www.smc-norge.no +48 222119600 Poland www.smc.nl Portugal +351 214724500 www.smc.eu Romania +40 213205111 www.smcromania.ro +7 (812)3036600 Russia www.smc.eu Slovakia +421 (0)413213212 www.smc.sk Slovenia +386 (0)73885412 www.smc.si Spain +34 945184100 www.smc.eu Sweden +46 (0)86031240 www.smc.nu **Switzerland** +41 (0)523963131 www.smc.ch +90 212 489 0 440 www.smcturkey.com.tr Turkey UK +44 (0)845 121 5122 www.smc.uk

info@smclt.lt
info@smc.nl
post@smc-norge.no
sales@smc.pl
apoioclientept@smc.smces.es
smcromania@smcromania.ro
sales@smcru.com
office@smc.sk
office@smc.si
post@smc.smces.es
smc@smc.nu
info@smc.ch
info@smc.tlk

South Africa +27 10 900 1233 www.smcza.co.za zasales@smcza.co.za